

Approval Certificates

الإشارة :
التاريخ : 2010/07/03

السيد / ممثل المتعهد (الشركة الأحمدية للمقاولات والتجارة) المحترم
تحية طيبة وبعد ،،

الموضوع : محاضر اعتماد مصادر مواد من رقم (10) حتى رقم (17) مشروع: أعمال معالجة وتحسين خواص التربة الضعيفة للطرق الرئيسية وإنشاء وإنجيب وصيانة الطرق والخدمات الرئيسية وتصميم وإنشاء وإنجاز وصيانة مباني المحطة الساحلية والمحطة الأرضية ومبني الترددات ومباني الخدمات التابعة لوزارة المواصلات بمدينة جازان الأحمد السكنية
عقد رقم : م.ع.ر.س.ع/1137 - 2010/2009
تعهد : الشركة الأحمدية للمقاولات والتجارة

بالإشارة إلى الموضوع أعلاه، مرفق طيه صورة من محضر اجتماع اعتماد مصادر مواد طبقاً لما يلي:

- المحاضر أرقام (10) ، (11) ، (12) ، (13) ، (14) بتاريخ 2010/06/22 .
- المحاضر أرقام (15) ، (16) ، (17) بتاريخ 2010/06/24

بعد الاعتماد من السيد / رئيس مهندسي المنطقة الثانية وذلك للعلم والعمل بما ورد فيه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المفيم
م / حسن الدسوقي مراد
2010/7/3

محضر اعتماد مصادر مواد رقم (10)

التاريخ : 2010/06/22

المكان : مكتب المهندس المقيم

المشروع : أعمال معالجة وتحسين خواص التربة الضعيفة للطرق الرئيسية وإنشاء وإنجاز وصيانة الطرق والخدمات الرئيسية وتصميم وإنشاء وإنجاز وصيانة مباني المحطة الساحلية والمحطة الأرضية ومبني الترددات ومباني الخدمات التابعة لوزارة المواصلات بمدينة جابر الأحمد السكنية .

المتعهد : الشركة الأحمدية للمقاولات والتجارة

عقد رقم : م.ع.ر.س/ع/1137 - 2010/2009

الموضوع : طلب اعتماد مصادر مواد لأعمال عازل الرطوبة بمجرور صرف مياه الأمطار.

الحضور :

عن المؤسسة العامة للرعاية السكنية :

المهندس / حسن الدسوقي مراد

المهندس / نواف علي المسلم

عن المتعهد (الشركة الأحمدية للمقاولات والتجارة).

المهندس / شربل إلياس الشمالي

ممثّل المتعهد

وقائع الاجتماع :

اجتمع الحضور لمناقشة الموضوع أعلاه وذلك بناءً علي كتاب المتعهد رقم ACTC/JAAC/PAHW/058 بتاريخ 2010/01/17 ، بخصوص طلب المتعهد اعتماد مصادر مواد لاستخدامها في أعمال عازل الرطوبة بمجرور صرف مياه الأمطار بالعقد أعلاه ، واستنادا إلي كتاب إدارة ضبط الجودة رقم 1192 بتاريخ 2010/05/11 ، فقد تمت الموافقة الميدانية علي اعتماد مصادر المواد التالية:

م	المادة	المصنع أو الوكيل المعتمد أو الموزع	بلد المنشأ	رمز المنتج
	مادة عازلة للرطوبة لصق ذاتي Self Adhesive Water Proofing Membrane			
1	مادة عازلة للرطوبة لصق ذاتي شركة صناعات العزل العربية	شركة عوازل الكويت لمواد البناء	السعودية	R.T.W 16 /1

وذلك بالشروط التالية:

1. التوريد من مصدر واحد فقط.
2. أن يتم التصنيع والتوريد طبقا لشروط ومواصفات العقد.
3. تقديم عينات للمهندس المقيم للتدقيق عليها تمهيدا للاعتماد النهائي.
4. تخص هذه المادة العقد أعلاه فقط (حسب كتاب ضبط الجودة بالخصوص).
5. تطبيق قرارات مجلس الوزراء الموقر بخصوص الأفضلية للمصادر المحلية علي المصادر الأجنبية أو ذات المنشأ الوطني.
6. هذا الاعتماد لا يعني المنتج من إجراء الفحوصات اللازمة عند التوريد .

المؤسسة العامة للرعاية السكنية


7. يتم أخذ عينات عشوائية لكل تشوين وترسل للفحص لدى جهات الفحص المعتمدة.
8. يشترط نجاح العينات المرسله للفحص اجتياز كافة الفحوصات المطلوبة.
9. مطابقة المواد المشونة بالموقع للعينة المعتمدة.
10. يتم استخدام البرايمر الخاص بالمنتج المذكور وذلك حسب كتالوج المصنع.
11. يتم مراعاة ظروف التخزين والتشوين بالموقع.
12. يتم تركيب المنتج المعتمد حسب تعليمات الشركة المصنعة.
13. يتم استخدام ألـ Cross Laminated film الخاص بمادة Self Adhesive من شركة VALERON البلجيكية نوع XL .

وعليه ، أقفل المحضر وتم التوقيع علي ما جاء أعلاه، ولا يعتبر المحضر ساريا إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الثانية.

عن المتعهد

(الشركة الأحمدية للمقاولات والتجارة)

عن المؤسسة العامة للرعاية السكنية


22/8/2012
٢٠١٢/٨/٢٢





شهادة اعتماد

AWAZEL ASAD 1.6 CLPE

٥٠ / ١١٨
٢٠١٢ / ٣ / ١١

اسم الشركة / المصنع :

شركة عوازل الكويت لمواد البناء.

العنوان :

ت: 24826677 - 25712223 فاكس: 24826801 - 25749228

ص.ب: 42137 الشويخ - الرمز البريدي : 70652

تاريخ الانتهاء

2014 / 3 / 3

تاريخ الإصدار

2012 / 3 / 4

وصف المواد المعتمدة :

- Self Adhesive bituminous membrane, 1.6mm thickness (bonded to a cross laminated HDPE).


من إنتاج صناعات العزل العربية - السعودية.

الملاحظات:

- يتم التقدم بهذا المنتج من خلال المقاولين المعتمدين لمشاريع وزارة الأشغال العامة شريطة أن تطابق مواصفات هذا المنتج المواصفات العامة لوزارة الأشغال والمواصفات الخاصة بالعقد الذي يرغب في استخدام هذا المنتج.
- هذا الاعتماد لا يعفي هذا المنتج من إجراء الفحوصات اللازمة والدورية عند التوريد لأي مشروع.
- تلتزم وزارة الأشغال العامة بتطبيق القرار الوزاري رقم (6) لعام 1987 والقرار المعدل له رقم (282) لعام 2000 والخاص بمنح الأئولية في المشتريات الحكومية للمنتجات الوطنية وذات المنشأ الوطني.
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه ويراعى التجديد في حينه.

اوكيل وزارة الأشغال العامة

م. عواظ بن سلطان السليمان
الوكيل العام
لشؤون المركز الحكومي للتحريات
وضبط الجودة والأبحاث





دار استشارات
الخليج
CONSULT



وزارة الأشغال العامة
MINISTRY OF PUBLIC WORKS



شركة المجموعة المشتركة
COMBINED GROUP CO.

SITE TRANSMITTAL (طلب اعتماد مادة)

Project : Construction , Completion and maintenance of Box Culvert at Airport Road
مشروع : إنشاء , إكمال وصيانة مجرور طريق المطار

Contract No. RA/160

عقد رقم : ه ط / 160

DATE: 08-Oct-09

TRANSMITTAL No. M 45 REV 0

ITEM No.	DRW.,SPEC. OR BOQ. REF	DESCRIPTION (البيان)	TYPE+	COPIES	ACTION CODE *
1	G.Specs:	AWAZEL ASAD 1.6 CLPE (1.6mm thickness)	Test Report	1+2	A
	516.04.1	Self adhesive membrane			
		Manufactured and Supplied by:			
		Arabian Waterproofing Ind.Co.			

دار استشارات
الخليج
CONSULT

CONTRACT RA/160

RECEIVED

5 NOV 2009

Sign

We certify that the items submitted herewith have been reviewed in detail and are in conformance with the contract documents except as otherwise stated.

PROJECT MANAGER

مدير المشروع

Date:

RECEIVED BY CONSULTANT:

Date:

CONSULTANT'S REMARKS:

* APPROVAL STATUS "A"
1- SUBMITTED TEST RESULT FOR AWAZEL ASAD SELF ADHESIVE MEMBRANE ARE ACCEPTABLE.

M.E. *AM*
21/11/09

Correction or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specification. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming all quantities and dimensions , selecting fabrication process techniques of construction ; coordinating his work with that of other trades , and performing his work in safe and satisfactory manner.

RESIDENT ENGINEER

DATE:

Signature
21/11/09

RECEIVED BY CONTRACTOR'S REP:

DATE:

C.C PE MPW :

+ TYPE: SD: SHOP DRAWINGS
SM: SAMPLE
GT: GUARANTEE
MD: MANUFACTURER'S DATA
CT: CERTIFICATES ✓
OT: OTHERS

* ACTION CODE:
A: APPROVED ✓
B: APPROVED AS NOTED
C: NOT APPROVED
D: FURTHER INFORMATION REQUIRED
E: NOTED

SITE TRANSMITTAL (طلب اعتماد مادة)

Project : Construction , Completion and maintenance of Box Culvert at Airport Road

مشروع : إنشاء ، إكمال وصيانة مجرور طريق المطار

Contract No. RA/160

عقد رقم : ه ط / 160

DATE: 08-Oct-09

TRANSMITTAL No. M 45 REV 0

ITEM No.	DRW.,SPEC. OR BOQ. REF	DESCRIPTION (البيان)	TYPE+	COPIES	ACTION CODE *
1	G.Specs:	AWAZEL ASAD 1.6 CLPE (1.6mm thickness)	MD	3	B
	516.04.1	(Self adhesive membrane) Alternative Source	CT		
		Manufactured and Supplied by:	SM		
		Arabian Waterproofing Ind.Co.			

We certify that the items submitted herewith have been reviewed in detail and are in conformance with the contract documents except as otherwise stated.

PROJECT MANAGER

مدير المشروع

Date:

RECEIVED BY CONSULTANT:

Date:

CONSULTANT'S REMARKS:

* APPROVED AS NOTED "B"

- 1- AWAZEL ASAD SOURCE APPROVED. (ALTERNATIVE SOURCE)
- 2- SUBMITTED SAMPLE ARE ACCEPTABLE.
- 3- NO MATERIAL SHALL BE USED ON SITE, PRIOR TO TESTING.

M.E. *AL*
18/10/09

Correction or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specification. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming all quantities and dimensions , selecting fabrication process techniques of construction ; coordinating his work with that of other trades , and performing his work in safe and satisfactory manner.

RESIDENT ENGINEER

RECEIVED BY CONTRACTOR'S REP:

DATE:

DATE:

C.C PE MPW :

+ TYPE: SD: SHOP DRAWINGS
SM: SAMPLE ✓
GT: GUARANTEE
MD: MANUFACTURER'S DATA ✓
CT: CERTIFICATES
OT: OTHERS

* ACTION CODE:
A: APPROVED
B: APPROVED AS NOTED ✓
C: NOT APPROVED
D: FURTHER INFORMATION REQUIRED
E: NOTED

دار مكتب ملزن الصالح للاستشارات الهندسية
شركة الدار للهندسة و الإنشاءات

حرفه الكتاب رقم

DM/155/MZ/55-10
c.o. 13/10/2013

تقدير رقم : هـ ط / 155

تصميم وإنشاء وإنجاز وصيانة مجرى صرف
مياه الأمطار الرئيسي لمدينة الشيخ / جابر الأحمد
وضاحية الشيخ / سعد العبد الله ومنطقة أمفرة الصناعية

وزارة الأشغال العامة
إدارة التنفيذ لطواع الطرق

قائمة مصادر المواد المقبولة

2. مواد ذات المنشأ الوطني

رقم البند في جدول الكميات	المرجع في المواصفات الخاصة	الاسم التجاري	بلد المنشأ	الوكيل المحلي المعتمد
B.17 B.18	07.1.4 07.2.9	Deck guard pu nitocote EP403	الإمارات	Al-Gurg fosroc Kuwait
B.10 C.3	07.2.8.5.5	Bitu Board	الإمارات	شركة الحمرا الكويت
B.10 C.3	07.2.8.5.5	Membrane Shield 60	السعودية	شركة خاجة للمواد الخصوصية
B.10 C.3	07.2.8	Bitus Stick XL	الإمارات	شركة الحمرا الكويت
B.10 C.3	07.2.8	Asad 1.6 Clpe	السعودية	شركة خاجة للمواد الخصوصية
B.11 C.3	07.2.9	Polycoat RBE	الإمارات	شركة الحمرا الكويت
B.11 C.3	07.2.9	Specitite DPR 10	الإمارات	شركة البحر و برويل
B.11 C.3	07.2.9	Lavatex 2000	السعودية	شركة خاجة للمواد الخصوصية

مدير المشروع

م. بسام صينية

المهندس الموقع

م. محمد عبد العزيز
2010
2013

مهندس المواد

م. السيد صلاح الدين
2010
2013



STATE OF KUWAIT
MINISTRY OF PUBLIC WORKS
ROAD ENGINEERING SECTOR

PROJECT CONSULTANT'S:
Scott Wilson
www.scottwilson.com
In association with
DMSEC

CONTRACTOR



COMBINED GROUP CONTRACTING CO.
(K.S.C.C.)
TEL - 22254545 FAX - 24344610
P.O. BOX 4819 SAFAT - 13049 KUWAIT

CONTRACT NO.: RA/184

PROJECT

Project Construction, Completion and Maintenance of Interchanges on Main Highways - 6th Ring Road - Connecting to New Housing Area at South Jaha
Nos. (10, 3, 4, 5, 7)

MATERIAL APPROVAL TRANSMITTAL

TRANSMITTAL SERIAL NO.: RA/184 - M.S. 0022

REVISION NO.: 0

REF. LETTER NO.: XXXX

DWG. REFERENCE: XXXX

DESCRIPTION OF MATERIAL:

WATER PROOFING MEMBRANE -AWAZEL
1,6 mm Thickness (self adhesive)

MANUFACTURER:

AWAZEL KSA
Local agent : KHAGA SPECIALITIES Co. Kuwait

COUNTRY OF ORIGIN:

KSA

BOQ REFERENCE:

SPECIFICATION REFERENCE:

MPW Gen. Spec. 2004.Clause.

ENCLOSURE:

TEST REPORT REFERENCE:

- 2 Copies of Catalogue
previous approval From other projects, sample

TEST REPORT MPW LAB & Kuwait UNIVERSITY LAB

CONTRACTOR:

CONSULTANT:

SUBMITTED BY: Engr. Abdul-khaliq ahmad kamal (PM)

RECEIVED BY:

DATE: 13/ 11 / 2010

DATE: 13/ 11 / 20 10

TIME:

TIME:

SIGNATURE:

SIGNATURE:

RECEIVED

REVIEWED BY THE RESIDENT ENGINEER'S OFFICE:

STATUS:

ACCEPTED AS NOTED
(I) SOURCE IS ACCEPTED
(II) APPLICATION AS PER MANUFACTURE RECOMMENDATION
(III) NO MATERIAL SHALL BE USED IN SITE PRIOR TO TESTING

- ACCEPTED
- ACCEPTED AS NOTED
- ACCEPTED AS NOTED/RESUBMIT
- REVISE AND RESUBMIT
- INCOMPLETE/RESUBMIT
- APPROVAL NOT REQUIRED

CONSULTANT:

CONTRACTOR:

RE / Deputy RE:

RECEIVED:

DATE: 21/12/2010

DATE: 4/12/2010

TIME:

TIME:

SIGNATURE:

SIGNATURE:



STATE OF KUWAIT
MINISTRY OF PUBLIC WORKS
ROAD ENGINEERING SECTOR

PROJECT CONSULTANT'S:
Scott Wilson
www.scottwilson.com
in association with
DMSEC

CONTRACTOR



COMBINED GROUP CONTRACTING CO.
(K S C C)
TEL - 22254545 FAX - 24344610
P.O. BOX 4810 SAFAT 13049 KUWAIT

CONTRACT NO.: RA-188 (INTERCHANGE No.6)

PROJECT: CONSTRUCTION, COMPLETION AND MAINTENANCE OF INTERCHANGES ON MAIN HIGHWAYS-FAHIAHEEL EXPRESSWAY
CONNECTING TO SOUTH OF SABAHYA AND MANGAF AREA (IC.6), MPW.(76A)

MATERIAL APPROVAL TRANSMITTAL

TRANSMITTAL NO.: RA/188-MS-0010

REVISION NO.: 0

REF LETTER NO.:

DWG. REFERENCE:

DESCRIPTION OF MATERIAL :

WATER PROOFING MEMBRANE - AWAZEL ASAL CLPE 1.6 mm THICKNESS

MANUFACTURER/SUPPLIER:

AWAZEL K S A - Local Agent : KHAJA SPECIALITIES CO KUWAIT

COUNTRY OF ORIGIN:

K S A

BOQ REFERENCE:

SPECIFICATION REFERENCE:

M P W General Spec. 2004 Clause 516.04.1

ENCLOSURE:

2 COPIES -CATALOGUE ,PREVIOUS APPROVAL IN OTHER
PROJECT .SAMPLE

TEST REPORT REFERENCE:

TEST REPORT FROM MPW LAB & KUWAIT UNIVERSITY

CONTRACTOR:

CONSULTANT:

SUBMITTED BY: Engr. Saleh Eid Ragheb

RECEIVED BY:

DATE: 01/ 08 / 2010

DATE: / / 20

TIME:

TIME:

SIGNATURE: *[Signature]*

SIGNATURE:

REVIEWED BY THE RESIDENT ENGINEER'S OFFICE:

STATUS:

Approved as noted
(i) Source is Approved.
II - No Material shall be used in site prior to testing
III Application AS per Manufacture Recommendation

- APPROVED
- APPROVED AS NOTED
- APPROVE AS NOTED/RESUBMIT
- REVISE AND RESUBMIT
- INCOMPLETE/RESUBMIT
- APPROVAL NOT REQUIRED

SPK
24/08/2010

CONSULTANT:

CONTRACTOR:

RE / Deputy RE :

RECEIVED: *[Signature]*

DATE: 25 / 08 / 2010

DATE: 25 / 08 / 2010

TIME:

TIME:

SIGNATURE: *[Signature]*

SIGNATURE:

- Engr. Saleh
- Engr. Sadeeth



MT



TRANSMISSION OF DOCUMENTS, SAMPLES ETC

TO : LBG / PACE

Transmittal No. RA166/OT/ 136

WE ARE SENDING HERE WITH/UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW. (DELETE AS NECESSARY)


Date : 18/04/2011 Rev. 0

ACTION :

Approved A Rejected D
 Approved As Noted B
 Revised and Resubmit C

SUBMITTED FOR	
APPROVAL	1
YOUR INFORMATION	2

QTY	REF	ITEM NO	DESCRIPTION	TYPE	CODE	
					Submittal	Action
5	2011/RA166/AC/PO/OT/SM/MD/CT/ 22	1	Water Proofing Membrane Self Adhesive (1.6mm Awazel Asad 1.6 CLPE)	OT	1	
		2	Protection Boards (6mm Awazel Membrane Shield ms 60)			B
		3	Bitumen Primer (Awazel Primer -D41)			



Submitted by Contractor :-

Received By LBG /PACE :-

Signature & Date :-

[Signature]
18/04/2011

Signature & Date

REMARKS
 Jahra Road Project
 RA 166
 The Arab Contractors
 Osman Ahmed Osman
 To the Engineer &
 Consultant
 Issued Date: 18/04/11

* subject to materials compliance with specifications
 * Adherence to manufacturer's recommendations is required
 * Materials are to be used as and where shown on the drawings
 * Detailed ^{installation} mechanical statement is required
 * installation involved personnel ~~have to be experienced~~
 * Please specify the locations where ~~the material~~ ^{to be used} ~~is to be used~~

Correction and comments made relative to submittals during this review do not the Contractor from the compliance with the requirements of drawings and specifications. This check is only for review of general conformance with this design concept of the project and general quantities and dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Consultant
 Project Director
 Signature & Date

[Signature]
28/4/11

SC-SUBCONTRACTOR
 RP- REPORT
 SM - Sample
 GT - Guarantess

SU-SUPPLIER
 MD - Manufacturer's Data
 CT - Certificates
 OT - Other
 RECEIVED
 18 APR 2011
 Re: *[Signature]*
 Jahra Road Project (RA/166)

Received by Arab Contractor

Date / Time : _____



UBMITTAL FORM

CLIENT :	MINISTRY OF PUBLIC WORKS, ROAD ADMINISTRATION DEPARTMENT, STATE OF KUWAIT	Submittal No : RA - 189-MT- 0015
CONSULTANT :	URS/Scott Wilson with DMSEC	Date : 20 October 2011
CONTRACTOR :	FIRST KUWAITI TRADING & CONTRACTING COMPANY	Revision : 0
CONTRACT NO :	RA/189	Submitted For
PROJECT :	Construction, Completion And Maintenance of Interchanges on Main Highway - 6th Ring Road Connecting to New Housing Area at West of Jaleeb Al Shuyoukh Area.	code*
		Approval 1
		Information 2
		others 3
		Bill: page: Item:

SUBJECT : MATERIAL FOR APPROVAL
 To : Resident Engineer,
 URS/Scott Wilsons with DMSEC
**Material eng for check and
 comment and actioned 20/10/2011**

We are sending herewith the item listed below for your action please :

Item No.	Ref.sec'n & Clause	No. of copies	Item Description / Vender / Supplier	Type***	code	
					Submittal*	Action**
1	Gen. spc	3	Awazel ASAD 1.6 CLPE	MT	1	B
	Sect. 5		Self Adhesive bituminous membrane			
	Clouser		(1.6 mm Thick)			
2	516.4.1	3	Membrane shield 60			B
	Partic. Sp.		Bituminous protection board 60 (6mm thick)			
	III - 2		Manufacturer:			
	Div. II		Awazel K.S.A			
			Local Agent :			
			Awazel Kuwait Co. LTD - (KHAGA Specialies Co.)			
			Encosed:			
			1- data sheet			
			2- previous approval			

CONTRACT RA/189
 Scott Wilson - DMSEC
 R. E. Office
 RECEIVED
 Date 20/10/2011
 01:45 PM

Eng. Abbas Al Banna
 Project Manager
 SIGNATURE

Project Manager
 E. Abbas El-Banna

Copies	Submitted by	Received by
To	FIRST KUWAITI TRADING & CONTRACTING COMPANY.	

Notes :

* لا مانع من تقديم المواد للاعتبار طبقاً لشروط و المواصفات العامة لوزارة الأشغال
 * تحديد الاعتبارات الخاصة بالمواد مع عمل الاعتبارات اللازمة
 للماتريال الاعتقاد مع الالتزام بمواصفات وتعليمات المصنع وذلك اجراء القويات من المواد اعرج زبيد
 من المخرن الكندي قبل الاعتقاد
 M. Saleh 27/11/2011

*** Codes to be entered by contractor (MT-003 Rev-0)
 ** Codes to be entered by Engineer / Consultant
 Submittal Type
 MT - Material, SD - Shop Drawing, SM - Sample, GT - Guarantee, TC Test Certificate, MDS Material Delivered to Site, MS - Method Statement, DC - Design Calculation / Notes
 Sk - Sketches, MD - Manufacture's date CT - Certificates, TR - Test Reports OT - Others.

Project : RA-167- JAMAL ABDUL NASSER STREET - Construction, Completion and Maintenance of Roads, Overpasses, Storm Water Drainage, Sewer and other Services.



SUBMITTAL FORM

From : ROBT- Contractor JV Submittal For: ★ Approval (1) Submittal No.167-NS-GN-ST-MT-144
 To : LBG- PACE JV Your Record (2) 20/2/2012 Rev. 0

WE ARE SENDING HERE WITH/UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW. (DELETE AS NECESSARY)

DISCIPLINE (TYPE OF WORK) ★★		SUBMITTAL TYPE ★★★	
PW Preliminary Works	TM Traffic Maintenance	SD Shop Drawing	OM Operation & Maintenance Manual
RW Roads	SL Street Lighting	AB As-Built	RP Report
ST Structures	TS Intelligent Traffic System	MT Material/ Sample/ Supplier	PS Processes/Procedure/Plans
SD Storm Water Drainage	EP Environmental Protection	SP Specifications	QU Quality related submittals (Quality Plan, Inspection and Test Plan,
UT Utilities	GN General	SC Sub-Contractor Submittal	HS HSB and logistics related submittals (HSB plan, Logistics Plan,...)
LI Landscaping and Irrigation	OT Others	MS Method Statement	TR Test Report
MS Traffic Marking and signs		CL Calculations	OT Others
		CR Certificates	
		GT Guarantees	
		SR Schedules/Programme	

QTY	DOC.REF	ITEM NO	DESCRIPTION	DISCP ★★	TYPE ★★★	CODE	
						Submittal★	Action
3	General Specifications for Kuwait Motorway / Expressway System. Section 516.04.1	1	Self Adhesive Bituminous membrane ASAD 1.6 CLPE . 1.6 mm thick Supplier: Awazel Kuwait Co. Ltd. (Kuwait) Manufacturer: Arabian Waterproofing Industries Co. Ltd. (Saudi Arabia) Country of origin: Saudi Arabia	UT	MT	1	B

Submitted by Contractor :- (Deputy Project Manager)
 Signature & Date :- *[Signature]* 2-2-2012
 Received by LBG / PACE :-
 Signature & Date :-

Engineer's Representative Comments:
 1) Arabian Waterproofing Industries Co. (Saudi Arabia) is approved as a source for supplying self adhesive waterproofing membrane ASAD 1.6 CLPE as approved through the shop drawings.
 2) A compatible primer recommended by the manufacturer shall be used.
 3) Delivered product shall be tested to demonstrate compliance with clause 516.04.1 of the general specification.




Corrections and comments made relative to submittals during this review do not relief the Contractor from the compliance with the requirements of drawings and specifications.
 ACTION: A: Accepted B: Accepted with comments C: Revise and Resubmit D: For Record Only

Name: Bashir Mukadam Designation: Material Engineer Signature & Date: *[Signature]* 25/2/12
 Name: Kamal Saqqa Designation: Deputy Resident Engineer Signature & Date: *[Signature]* 27/2/12

Engineer's Representative: Project Director Contractor: Received
 Signature & Date: *[Signature]* Signature & Date:

Copies: MPW Project Engineer File Others





وزارة الكهرباء والماء

التاريخ: 14-1-2010
الأشارة: _____

KG/SG/GNRL/L- 000097

M/s. General Electric International Inc., (J. V. Leader),
1 River Road
Building 40, 3rd Floor,
Schenectady, NY 12345 - 6000
U. S. A

Attn: Project Manager , Sabiya Project, Kuwait

Dear Sirs,

Engineering, Procurement & Construction, Operation and
Maintenance of Combined Cycle Gas Turbine Project
at Sabiya Power Station
Contract No. MEW/C/4010-2009/2010

Sub- Request for approval of Tanking Membrane and Protection Board


This has reference to your letter No. GK/SC/GNRC/L- 000203, dated Dec. 5, 2009 on the captioned subject enclosed with material catalogue for the following.

No.	Item	Material	Manufacturer
1.	Tanking Membrane	Awazel Azad 1.6 CLPE (1.6mm self adhesive bituminous membrane)	Arabian Water Proofing Saudi Arabia
2.	Protection Board	Membrane Shield	Arabian Water Proofing Saudi Arabia

We have no objection to your proposed water proofing membrane and bituminous protection board MS60 to water proofing membrane to be used for project water proofing. Tanking system shall be installed and protected against damage as per Manufacturer recommendation and contract clause 5C.6.6.2 requirement.

This is for your information and necessary action.

Yours faithfully,


UNDER SECRETARY
MINISTRY OF ELECTRICITY AND WATER

CC: M/s. General Electric International Inc.
Kuwait Free Trade Zone,
P.O. Box 64585, Shuwaikh (B)
70456 Kuwait.



P.O.Box No. 12 & 54 Safat , 13001 Safat , KUWAIT - Phone : +965 - 5371000
Fax No. +965-5371420 / 1 / 2

Ref : S.E.C – RA/162 Ma - 105 -2010

Date: 16 -09-2010

المحترمين

السادة / شركة مشرف للتجارة العامة والمقاولات

المحترم

السيد / مدير المشروع

تحية طيبة وبعد،،،

**المشروع : العقد رقم هـ ط / 162 إنشاء وإنجاز وصيانة طرق ومجاري أمطار
وصحية وخدمات أخرى بمنطقة المهبولة (المرحلة الأولى)**

الموضوع : اعتماد مصدر إضافي عازل ذاتي الالتصاق

بالإشارة إلى الموضوع أعلاه ، وإلى كتابكم رقم ش م/هـ ط 2010/088/162 بتاريخ 2010/09/09 ، وطلب التقديم رقم 04A بتاريخ 2010/9/8 ، وكتاب رقم ش م/هـ ط 2010/089/162 بتاريخ 2010/09/09 ، وطلب التقديم رقم 05A بتاريخ 2010/9/8 نحيطكم علماً بأنه لا مانع لدينا من اعتماد شركة خاجه للمواد الخصوصية لتوريد مادة ASAD 1.6 CLPE-Cross Laminated Self Adhesive Water proofing Membrane سعودي من شركة (عوازل) منتج ذات المنشأ الوطني على أن يتم توريد ألواح الحماية من نفس المنتج والمصدر ويتم الإلتزام من مصدر واحد فقط مع إتباع تعليمات الصانع وجهاز الإشراف في طريقة التشوين والتنفيذ داخل الموقع وذلك شريطة النجاح بالفحص عند التوريد للموقع وقبل بدء العمل .

وتفضلوا بقبول فائق الاحترام ،،،


السيف للاستشارات الهندسية

المهندس القيم

رضوان علي عقاد

رضوان علي عقاد

السيف للاستشارات الهندسية
sief engineering consultants
Tel. (965) 1885566 - FAX : 22454647 / 22428729
P.O.Box : 21139 Safat 13072 Kuwait.



المحترم .

- نسخة للسيد المهندس المشرف

- المرفقات : كما ذكر أعلاه .

MUSHRIF / RA/162	ACTION	CC
MD & MBOD		
DO		
PD		
PE		
PLANNING ENG.		
PROJECT COORDINATOR		
QUANTITY SURVEYOR		
QA/QC-MAT. ENGINEER		
MANAGER-MT		
INFRA. ENGINEER		
WATER WORKS ENGINEER		
SR. CIVIL ENGINEER		
HSE ENGINEER		
SR. LAND SURVEYOR		
SECRETARY		
PROJECT ACCOUNTANT		
DOC. CONTROLLER		
STORE KEEPER		
TIME KEEPER		
PURCHASER		
SR. HR MANAGER		
PROC. MANAGER		
FINANCE MANAGER		
MANAGING OS		
FILE		

P.O Box21139, Safat13071 ,Kuwait, Tel: 00965-1885566, Fax: 0096522454647

E-mail: sec@sief.fastteco.com



التاريخ: 14-1-2010
الأشارة: _____

وزارة الكهرباء والماء

KG/SG/GNRL/L- 000097

M/s. General Electric International Inc., (J. V. Leader),
1 River Road
Building 40, 3rd Floor,
Schenectady, NY 12345 - 6000
U. S. A

Attn: Project Manager , Sabiya Project, Kuwait

Dear Sirs,

Engineering, Procurement & Construction, Operation and
Maintenance of Combined Cycle Gas Turbine Project
at Sabiya Power Station

Contract No. MEW/C/4010-2009/2010

Sub- Request for approval of Tanking Membrane and Protection Board

This has reference to your letter No. GK/SC/GNRC/L- 000203, dated Dec. 5, 2009 on the captioned subject enclosed with material catalogue for the following.

No.	Item	Material	Manufacturer
1.	Tanking Membrane	Awazel Azad 1.6 CLPE (1.6mm self adhesive bituminous membrane)	Arabian Water Proofing Saudi Arabia
2.	Protection Board	Membrane Shield	Arabian Water Proofing Saudi Arabia

We have no objection to your proposed water proofing membrane and bituminous protection board MS60 to water proofing membrane to be used for project water proofing. Tanking system shall be installed and protected against damage as per Manufacturer recommendation and contract clause 5C.6.6.2 requirement.

This is for your information and necessary action.





Yours faithfully,


UNDER SECRETARY
MINISTRY OF ELECTRICITY AND WATER

CC: M/s. General Electric International Inc.
Kuwait Free Trade Zone,
P.O. Box 64585, Shuwaikh (B)
70456 Kuwait.

AMMAN, JORDAN
AUS 075 10011 1000001

P.O.Box No. 12 & 54 Safat, 13001 Safat, KUWAIT - Phone : +965 - 5371000
Fax No. +965-5371420 / 1 / 2


Proj. No.: RA 140 DESIGN, BUILD, COMPLETE & MAINTAIN SHAIKH JABER AL-AHMAD AL-SABAH CAUSEWAY PROJECT (MAIN LINK)	Employer: STATE OF KUWAIT MINISTRY OF PUBLIC WORKS ROAD ENGINEERING SECTOR	Request No. RA140-32-IMD-KOC-CUL-C-0002-00
Engineer's Representative:  dar al-handasah sha'ir and partners  TYLIN INTERNATIONAL	Contractor:  HYUNDAI ENGINEERING & CONSTRUCTION  COMBINED GROUP CONTRACTING COMPANY	Date 9/6/2015 RA140-HDCG-32-PRW-IMD- 00006

Inspection of Materials Delivered to Site


1. Material / Equipment
 Description : Waterproofing Membrane Self Adhesive (1.6mm) Protection (KOC Box Culvert)
 Materials submittal ref. no. : N/A Date : N/A
 Bill of Quantities Ref. No. : N/A
 Quantity : 100 Sheet

2. Manufacturer's details
 Manufacturer : Arabian Waterproofing Ind.Co.
 Model No. : _____ Serial No. : _____
 Country of Origin: Saudia Arabia
 Date of ARRIVAL on Site : As per attached (Sheet No.1 & Delivery Notes)
 STORAGE Location : CGC Subiyah Site Store
 Submitted by : Qasem AL Bader Signature _____


3. Inspection report




Yes/No	Initials
Physical Damage ? <input type="radio"/> Yes <input checked="" type="radio"/> No	
Details given above correct ? <input checked="" type="radio"/> Yes <input type="radio"/> No	
Conform with Approved submission ? <input checked="" type="radio"/> Yes <input type="radio"/> No	
Accessories/ Spare Parts Included ? <input type="radio"/> Yes <input type="radio"/> No <u>Not applicable</u>	

Details : _____
 Remarks : checked as per attached delivery note



4. Engineer's Representative comments
 The above material has been inspected on Site and found at time of inspection to be :
 Satisfactory Unsatisfactory
 for incorporation in the permanent works.
No material is allowed to be used until tested for compliance with specs and found OK
 Signature _____ Date : 14/6/2015
 Above inspection shall not relieve Contractor of his responsibilities to incorporate in the works only such materials that are in conformity with the Contract.



Proj. No.: RA-238 CONSTRUCTION, COMPLETION AND MAINTENANCE OF THE ROADS, BRIDGES, STORM WATER DRAINAGE, SEWERS AND OTHER SERVICES FOR THE ROAD CONNECTING MINA ABDULLAH AND WAFRA	Employer:  MINISTRY OF PUBLIC WORKS ROAD ADMINISTRATION DEPARTMENT STATE OF KUWAIT	Request No. RA238-SAM-GEN-STR-0011-00
Engineer's Representative:  dar al-handasah shair and partners s.a.f.	Contractor: MUSHRIF TRADING & CONTRACTING CO.  مشرِف للجسارة والعمارة والتشييد	Date 16 / 03 / 2016

Submission for Approval of Materials ✓

1. Material description (one item only on this form) :

WATERPROOFING SYSTEM MATERIALS: 1). AWAZEL PRIMER D41 2). AWAZEL SELF ADHESIVE MEMBRANE 1.6 CLPE
3). AWAZEL DESERT SHIELD 40200 4). AWAZEL MEMBRANE SHIELD - MS 60


Area of application : BRIDGE, BOX CULVERTS, VALVE CHAMBERS & MEDIAN BARRIERS HAVING CONTACT WITH SOIL AS SHOWN ON DRAWINGS.
Drawing ref. : K10091-0100D-PK1-TD-BR-003 & 005 B.O.Q. Ref. No.: Section-5, Item: 516
Specification Ref. : MPW GENERAL SPECS: SEC-5, CLAUSE: 516.04 Standards : ASTM

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.


2. **Manufacturer / supplier**
Company Name : ARABIAN WATERPROOFING INDUSTRIES CO (AWAZEL).
Address : SECOND INDUSTRIAL CITY, ROAD NO.173, P.O. BOX 2955, RIYADH 11461, KSA.
Local Agent : AWAZEL KUWAIT CO, KUWAIT.

3. **Delivery :**
Country of origin : KINGDOM OF SAUDI ARABIA, KSA.
Availability
 Locally Manufactured Overseas

Delivery :	Ex-works/ total duration	[]	[]
	Estimated time of arrival on site	[]	[]
Program :	Date material required on site	[]	[]
	Latest date for order	[]	[]




We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : _____ Engr. Tony Curran Signature 

4. Engineer's Representative comments: <i>Prior to use material shall be tested & shall be in compliance with General Spec 516.04</i> <i>2) Delivered material shall be notified for inspection.</i> <i>3) Compliance Certificate shall be submitted with the consignment.</i> <i>4) Location to be used as per approved dwg.</i> <i>5) Storage & Application as per mfr's instruction.</i> <i>6) Detailed method statement & ITP to be submitted for approval. N/A</i>	<input type="checkbox"/>	Approved
	<input checked="" type="checkbox"/>	Approved as noted
	<input type="checkbox"/>	Revise and resubmit
	<input type="checkbox"/>	Rejected
	<input type="checkbox"/>	Sample required
	<input type="checkbox"/>	Tests required
	<input type="checkbox"/>	Additional information required
Signature _____	<input type="checkbox"/>	Manufacturer's guarantee required
Date: 20/03/2016		

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.



Proj. No. : RA-239 Construction, Completion and Maintenance of Roads, Bridges, Storm Water Drainage, Sewers and Other Services for Roads Connecting Sabah al Ahmad and Khiran New Towns	Employer:  وزارة الأشغال العامة MINISTRY OF PUBLIC WORKS	Request No. RA-239/MAK/SAM/012 REV. 0
Engineer's Representative:  دار الهندسة والشركاء dar al-handasah and partners	Contractor:  Mohammed Abdulmohsin Al Kharafi & Sons W.L.L.	Date 6/4/2016

Submittal for Approval of Materials ✓

1. Material description (one item only on this form) :
 Water Proofing Self Adhesive Membrane(Awazel Asad 1.6 CLPE (1.6 mm))

Area of application : Bridge Works

Drawing Ref. : _____ **B.O.Q. Ref. No. :** 516.1.a,c,d,&516.2.b,c

Specification Ref. : Gen.Specs of Kuwait.Section 5, **Standards :** AS Per Table 516.04.1.1

Clause 516

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name : Arabian Waterproofing Industries CO .Ltd

Address : P.O BOX 10308 -Jubail Ind.City 31961-Saudi Arabia


Local Agent : Awazel Kuwait Co. LTD.(Kuwait)

3. Delivery :

Country of origin : Saudi Arabia

Locally Manufactured Overseas

Delivery	Ex-works/ total duration	
	Estimated time of arrival on site	
Program	Date material required on site	
	Latest date for order	



We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : Eng Hassan Mohamed Signature _____

4. Engineer's Representative comments:

Source of material is approved

No material shall be used on site prior to testing as per clause 516.04.1.1 of Gen Specs.

App'l action shall be as per manufacturer recommendation

<input type="checkbox"/>	Approved
<input checked="" type="checkbox"/>	Approved as noted
<input type="checkbox"/>	Revise and resubmit
<input type="checkbox"/>	Rejected
<input type="checkbox"/>	Sample required
<input type="checkbox"/>	Tests required
<input type="checkbox"/>	Additional information required
<input type="checkbox"/>	Manufacturer's guarantee required

Signature [Signature] Date : 12/4/16

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.