

Approval Certificates

شركة الانشاء والتصنيع العقاري

الرقم ٤٠٤٤٠٧٧٧/٢٠١١ - ١٩٧٩
 انشاء وتجارة وشركة عقار
 * الترخيص رقم ٢٥٦١
 * الترخيص رقم ٢٥٦١

طلب اعتماد مواد

المؤسسة العامة للرعاية السكنية

مشروع أم الهيمان الإسكاني

التاريخ ١٠/٤/٢٠١١ Date
 صفحة ١ OF ١ Sheet
 رقم الملف NO٦ Transmittal No.

رقم Item No.	وصف المواد Description of Material	كمية Quantity	نوع المادة Kind of Material	مصدر أو المراجع Source or Reference	مخطط أو الرسم Catalog Drawing or Drawing Reference	رقم المواصفات Specification Para No	مطلوب Required	نوع المادة Kind of Material	Transmittal No.
	CONTRACT MONBAC								
	عازل حراري	١٠٠	عازل حراري	عازل حراري	مواصفات				

REMARKS: ملاحظات

(١) المصدرة معتمدة
 لا يتم اية تغيير على المواصفات
 المذكورة ولا يجوز ابدالها
 بالمواد الاخرى الا بعد موافقة
 المهندس المشرف
 We certify that the material sources indicated above have been reviewed in detail
 and that they will supply material in strict conformance with the contract
 drawings and specifications except as otherwise stated.
 اسم المصنف: المهندس المشرف
 اسم المهندس المشرف: المهندس المشرف

التاريخ: _____ Date
 توقيع ممثل المؤسسة: _____
 Name and signature of Contractor
 PAHC ACTION BY:
 PAHC REMARKS:

المهندس القيم الرئيسي
 المهندس المشرف
 المهندس المشرف

مادة حطاب: المؤسسة



س.ت. ٢١١٥٧ - رأس بلد السجل والتفريع بالتكامل مك. 2,000,000

ICG-993/465

مجمهورية
الكويت
الطويلة (١٩٨٨)

مفروع لمرافق الصالحات الاسكان مقدر رقم / ١٩٣

2007 / 07 / 22

المستلمين:

المادة / شركة التوباء للتجارة العامة والمقاولات

تحية طيبة وبعد

الموضوع: اعتماد مسود العزل

المفروع: إنشاء وجسر ومبنة عند (288) بيتاً والمباني
المنسقة والخدمات الرئيسية وتسيير النواع - تمام بالقطعة رقم
(1) بمشروع شمس الصالحات، الإسكان
عقد رقم: م.ع.ر.س. / ع / 2034/993 - 2005

بالإشارة إلى الموضوع أعلاه ... وإلى كتابكم رقم T.W/S/03/2007 بتاريخ
2007/07/16 برفس الخصوص ، نفيدكم علماً بالموافقة على منبكم استخدام عازل الرطوبة

نوع (ds - 40200) سماكة 4 مم من إنتاج شركة صناعات العزل العربية السعودية (جوارب)
ويطلب إليكم الأصرار في تنفيذ أعمال العزل لمحاولات الكهربية نموذج 4TR قبل انقضاء شهر
يوليو 2007 نظراً لأقتراب موعد تسليم المجموعة الأولى من البيوت - في السادة المؤسسة
العامة للرعاية السكنية .

وتفضلوا بقبول فائق الأبرام...

مدير المشروع

بهدن / محمد عبد القناح حناوي

C-٧٧٢٥٥

المؤسسة العامة للرعاية السكنية

الإشارة : ٧٥٥
التاريخ : 2007/08/16

السيد / ممثل المتعهد (شركة المجموعة المشتركة للمقاولات)
المحترم
بعد التحية ،،

الموضوع : محضر اجتماع اعتماد مصادر مواد رقم (59)
مشروع تخطيط وتصميم وإنشاء وإنجاز أعمال
الخدمات الرئيسية لعدد (1220) قسيمة
وإنشاء وإنجاز وصيانة المباني العامة بالقطاع
(B) بمشروع جابر الأحمد الإسكندرية
عدد رقم : م.ع.د.س/ع/1000 - 2005/2004
تعهد : شركة المجموعة المشتركة للتجارة والمقاولات

بالإشارة إلى الموضوع أعلاه ، مرفق طيه صورة من محضر اجتماع اعتماد مصادر
مواد رقم (59) بتاريخ 2007/08/04 بعد الاعتماد من السيد / رئيس مهندسي المنطقة
الثانية وذلك للطم والعسل بما ورد فيه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقدم
15/8/2007
م / حسن السوقي مراد

محضر اجتماع صادر رقم (23)

Handwritten signature and date: 11/11/06

التاريخ: 2004/11/06

المكان: مكتبة المهندس المقدم

العقد: م.ع.ر.س/ع/940 - 2002 / 2003

المتعهد: شركة الإيظاء والتدريج العقاري

المشروع: إنشاء وإجاز وصيانة عدد (1) مدرسة ابتدائية بنات + (1) مدرسة متوسطة بنين + (1) مدرسة متوسطة بنات بضاوية جابر العلي + مدرسة متوسطة بنين بقطاع (2) بمشروع القرين الإسكاني.

الموضوع: اعتماد مطاخر مواد

الحضور:-

عن المؤسسة العامة للرعاية السكنية:-

المهندس المقيم

Handwritten signature of the Engineer in Charge

المهندس / م.ع.ر.س/ع/940 محمد بن جابر العلي

مدير المختبر

Handwritten signature of the Lab Director

المهندس / م.ع.ر.س/ع/940 محمد بن جابر العلي

عن المتعهد:- (شركة الإيظاء والتدريج العقاري):-

ممثل المتعهد

Handwritten signature of the Contractor Representative

المهندس / م.ع.ر.س/ع/940 محمد بن جابر العلي

وقائع الاجتماع

اجتمع الحضور بناء على كتاب المتعهد رقم 04/C-120/10/475 بتاريخ 2004/10/16 بخصوص الموضوع أعلاه، فقد تم الاتفاق مبدئياً على اعتماد المصدر السعودي عوازل Desert Shield 48200 لأعمال عزل الرطوبة بالعقد بدلاً من المصدر المحلي لشركة الأنلوبو للكيماويات والذي تم إيقاف اعتماد بناء على مذكرة إدارة ضبط الجودة رقم (574) بتاريخ 2004/10/2 وبناء على موافقة السيد / رئيس المهندسين على حساب مهندس المتقدمة بتاريخ 2004/10/31 واعتماد المصدر المذكور للمرحلة الأولى من الأعمال.

Handwritten signature and stamp at the bottom left.

Handwritten signature at the bottom center.

Stamp of REGAECO REAL ESTATE CONSTRUCTION & FABRICATION CO. with registration number 29032002-443


Handwritten notes and stamps on the right side.

م	اسم المادة	اسم المنتج	رمز المنتج	اسم المصنع أو الوكيل المعتمد أو الموزع	بند المنشأ	ملاحظات
1	عازل معي ورطوية مع البريكر	عازل Desert Shield 40200	R.T.W2/2	الشركة المصرية لمطوية	السعودية	المصدر متوقف حالياً بتليل مركز التوكيلات لوجود مصدر مخطية


وذلك وفقاً للشروط الآتية :-

- 1- أن يتم التصنيع والتوريد طبقاً لما هو مطلوب بالمستندات التعاقدية.
 - 2- أن يكون البريكر والعازل المعالي من نوع الشرائح البيتومينية من نفس المصدر.
 - 3- أن لا يتم الاستخدام للتشوينات إلا بعد إرسال عينات للفحص وورود نتائجها محققة للمواصفات المطلوبة بالعدد.
- وأقل المحضر على ما جاء أعلاه ووقع للحضور ولا يعتبر المحضر مساري المقبول إلا بعد
إحتماله من السيد / رئيس مهندسي المنطقة الثالثة.

عن المؤسسة العامة للرقابة السكنية


المهندس القيم

عن المهندس (شركة الإنشاء والتصنيع العقاري)


مهندس

شركة الإنشاء والتصنيع العقاري
RECAFCO
REAL ESTATE CONSTRUCTION
& FABRICATION CO.
ع.ق. ٢٠٠٢-٢٠٠٣ / ٩٤٠-٢٠٠٣

المؤسسة العامة للرعاية السكنية
محضر اجتماع لاعتماد مصادر مواد لأعمال العازل رقم (59)

التاريخ : 2007/08/04

مكان الاجتماع : مكتب المهندس المقيم
المشروع : تخطيط وتصميم وإنشاء وصيانة أعمال الخدمات الرئيسية لمعد (1220) قسيمة وإنشاء وإنجاز وصيانة المباني العامة بالقطاع (B)
بمشروع مدينة جابر الأحمد الإسكافي .

14/8/07
عقد

المتعهد : شركة المجموعة المشتركة للتجارة والمقاولات .
عقد رقم : م ع ر س / ع / 1000 - 2005/2004 .
الموضوع : طلب اعتماد مصادر مواد لأعمال العازل .
الحضور :

المهندس المقيم



عن المؤسسة العامة للرعاية السكنية

المهندس / حسن الصوفي مراد

عن المتعهد (شركة المجموعة المشتركة)

المهندس / أسامة عبد الحليم

ممثل المتعهد



وقام الاجتماع :

اجتمع الحضور لمناقشة الموضوع أعلاه وذلك بنسأء علي كتاب المتعهد رقم J.A/07/1011 بتاريخ 2007/06/21 والخاص بطلب المتعهد اعتماد مصادر مواد لاستخدامها في أعمال حماية الطبقات العازلة للرطوبة بأسطح المباني العامة (تحت بلايات التغطية بالمياه) بالعقد أعلاه ، واستنادا إلي كتاب إدارة ضبط الجودة رقم 794 بتاريخ 2007/07/30 بنفس الخصوص، فقد تم الموافقة المبدئية علي اعتماد مصادر المواد التالية :


رقم	المادة	المصنع أو الوكيل المعتمد أو الموزع	بلد المنشأ	رمز المنتج
مواد حماية الطبقات العازلة للرطوبة				
1	PROTECTION BOARD مواد حماية الطبقات العازلة للرطوبة (تحت بلايات التغطية بالمياه)	المصدر السعودي (عازل)	السعودية	R.T.W 2/10


وذلك بالشروط التالية :-

1. أن يتم التصنيع والتوريد طبقا لشروط ومواصفات العقد .
 2. أن تكون المواد الموردة مطابقة للعينات المقدمة .
 3. أن يتم الاستخدام حسب الأماكن المحددة بالمخططات وطبقا لشروط ومواصفات العقد .
 4. أن يتم إرسال عينات للفحص من التثوينات بالموقع ولا تستخدم إلا بعد مطابقة المادة المقدمة للمطلوب بالمستندات التعاقدية وإنجاحها في الفحوصات .
- وعليه أذلل المحضر وتم التوقيع علي ما جاء أعلاه ، ولا يعتبر المحضر ساريا إلا بعد اعتماده من السيد/ رئيس مهندسي المنطقة السكنية .

عن المؤسسة العامة للرعاية السكنية

عن المتعهد (شركة المجموعة المشتركة)




م / محمد البريحي



محضر اعتماد مصادر مواد رقم (18)

التاريخ : 13 / 10 / 2009 م

المكان : مكتب المهندس المقيم

المشروع : إنشاء وإنجاز وصيانة عدد (263) بيتاً + المباني العامة + الخدمات الرئيسية بالقطعة (8) بمشروع مدينة سعد العبد الله الإسكاني

تسقة رقم : م. ع. ر. س / ع / 1111 - 2008 / 2009 م.

المتعهد : شركة كنار للتجارة والمقاولات ذ.م.م.

الموضوع : اعتماد مصادر مواد .

الحضور

عن المؤسسة العامة للرعاية السكنية :

المهندس / موسى أحمد الاتصاري

المهندس / بدر جاسم حسن

السيد / محمد النبوي عبد الرازق


من المتعهد (شركة كنار للتجارة والمقاولات ذ.م.م) :

المهندس / محمد حسين الباز

الوقائع

اجتمع الحضور لمناقشة ما ورد بكتاب ممثل المتعهد رقم 2009/603 بتاريخ 2009/10/12 الموجه إلى المهندس المقيم بخصوص طلبه اعتماد مصادر مواد لأعمال العقد ، واستناداً إلى دليل مصادر المواد المعتمد بالمؤسسة ، فقد تم الاتفاق مبدئياً على اعتماد مصدر المواد التالي لاستخدامه بأعمال العقد:-

اسم المادة	رقم المادة	الصنع أو الوكيل المتعهد	المصدر	ملاحظات
عازل مائي ورطوبه مع البرايمر				
عازل Desert Shield 40200	R.T.W2/9	شركة عوازل الكويت لمواد البناء	السعودية	



مواضع التوقيع: 

المؤسسة العامة للرعاية السكنية

وبالشروط التالية:

- 1 - أن يتم التصنيع والتوريد طبقا لشروط ومواصفات العقد .
 - 2 - أن يتم التوريد من مصدر واحد فقط بالعقد ، وفي حالة الاحتياج إلى التوريد من مصدر آخر يتم إعلام المهندس المقيم خطيا وأخذ الموافقة قبل المباشرة بالتوريد من المصدر الجديد .
 - 3 - أن تعطى أولوية التوريد للعقد للمنتجات الوطنية ويتم تطبيق قرارات وزارة التجارة والصناعة في شأن دعم وحماية المنتجات الوطنية (تم اعتماد مصدر محلي بالمحضر رقم 3 بتاريخ 20/10/2008) .
 - 4 - الالتزام عند الاستخدام والتنفيذ بما هو مطلوب بالمستندات التعاقدية .
 - 5 - تقديم عينات للمهندس المقيم للتدقيق عليها تمهيدا للاعتماد النهائي .
 - 6 - لا يصرح باستخدام عازل الرطوبة إلا بعد إجراء الفحوصات التعاقدية وتحقيقها لمتطلبات العقد .
 - 7 - أن يتم تقديم المواد الموردة فور وصولها للموقع للجهاز المشرف بالعقد للتدقيق عليها ويمنع استخدامها قبل الموافقة على ذلك .
- واقفل المحضر على ما جاء به أعلاه، ويرفع للسيد / رئيس مهندسي المنطقة الأولى للاعتماد.

عن المؤسسة العامة للرعاية السكنية



مهندس المقيم
موسى العبد العبد

عن المتعهد



شركة كمار للتجارة والبناء
NAR
عشر رجب
BUILDING & CONTRACTING CO.

المحترم

السيد / ممثل المتعهد

تحية طيبة وبعد ،،،

الموضوع: استخدام المصدر السعودي عوازل (DS 40200) لتوريد عازل الرطوبة

مشروع: إنشاء وإنجاز وصيانة عدد (263) بيتا +

المباني العامة + الخدمات العامة بالقطعة رقم (8)

بمشروع مدينة سعد العبد الله الإسكاني

مقد رقم: م. ع. ر. س / ع / 1111 — 2008 / 2009

تعهد: شركة كنار للتجارة والمقاولات ذ.م.م

بالإشارة إلى الموضوع أعلاه ، وإلى كتابكم رقم 2010/810 بتاريخ 2010/01/12م بنفس

الخصوص ، نفيدكم على الموافقة على طلبكم باستخدام المنتج من المصدر السعودي (شركة عوازل الكويت

لمواد البناء) عوازل (DS 40200) لتوريد عازل الرطوبة لأعمال العقد أعلاه ، وذلك طبقاً لمحضر

اجتماع لجنة إجراءات إعطاء الأولوية للمنتجات الوطنية بتاريخ 2010/01/27م (مرفق صورة) .

أملين حسن تعاونكم معنا.


المهندس المقيم

موسى أحمد الأنصاري

٢٠١٠ / ١٤ / ٢

كتابنا رقم 2010/810 [مرفق صورة]

عادل مهدي



المحترم

السيد / ممثل المتعهد

(شركة كنار للتجارة والمقاولات)

تعية طيبة وبعد ...

الموضوع : العازل المائي (عوازل DS40200) من المصدر السعودي

مشروع : إنشاء وإنجاز وصيانة عدد (282) بيتاً + المباني

العامة + الخدمات الرئيسية بمشروع مدينة سعد العبدالله قطعة رقم (8)

عقد رقم : م . ع . ر . س / ع / 1112 / 2009/2008

بالإشارة إلى الموضوع أعلاه ... وإلى كتابكم رقم : 4/CAP - 42 / 27 بتاريخ 2010/1/11

وبنفس الخصوص .

وإلى ما جاء بمحضر إجتماع لجنة إعطاء الأولوية للمنتجات الوطنية المنعقد معكم بغرفة إجتماعات إدارة ضبط الجودة بتاريخ 2010 /2/2 المعتمد من السيد / المدير العام بتاريخ 2010/2/3 وموافقة إدارة ضبط الجودة بالمذكرة رقم (996) بتاريخ 2010/2/8 ، حيث وجد أن نسبة التفضيل لفروق الأسعار بين سعر المنتج الوطني (المصدر المحلي للشركة الأهلية للكيمياويات) وبين المنشأ ذي المنشأ الوطني (عوازل DS40200) للمصدر السعودي / شركة عوازل الكويت لمواد البناء تساوى (19.1 %) وهذه النسبة تزيد عن (5 %) نسبة الحماية المقررة بالقرار الوزاري رقم (1987/6) .

وفي ضوء ما تقدم فإننا نفيدكم بأنه لا مانع من استخدام المنتج ذات المنشأ الوطني (عوازل DS40200) من المصدر السعودي (شركة عوازل الكويت لمواد البناء) لتوريد عازل الرطوبة لأعمال العقد أعلاه .

وتفضلوا بقبول فائق الاحترام ...

المهندس المقيم

عبدالحسن علي الجناسي

* نائب مدير المشروع
* نستمع لكم والعامل (مع كتاب)
* الملف

المحترم

... نسخة السيد / رئيس مهندسي المنطقة الرابعة

21.2.2010

المؤسسة العامة للرعاية السكنية

الإشارة : م 2 / 1113 / 546

التاريخ : 03 / 11 / 2009

المحترم

السيد / ممثل المتعهد

تحية طيبة وبعد ،،،

الموضوع : المحضر المعتمد لمصادر المواد

رقم (16) لأعمال العازل

مشروع إنشاء وإتجاز وصيانة عدد (279)

بيتاً + المباني العامة + الخدمات الرئيسية

بمشروع مدينة سعد العبد الله بالقطعة (8)

عقد رقم : م.ع.ر.س/ع/1113-2008/2009

المتعهد : شركة كويست دابنمكس

المح دودة للمة اولات.

بالإشارة إلى الموضوع أعلاه ، مرفق طيه النسخة المعتمدة من محضر اعتماد مصادر المواد

رقم (16) لأعمال العازل والمنعقد بتاريخ 2009/10/28 بالعقد أعلاه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم

شكري أبو سريع

المرفقات :

المذكورة أعلاه .

المؤسسة العامة للرعاية السكنية
المنطقة الثانية عقد رقم 1113

محضر اعتماد مصادر مواد رقم (16)

التاريخ : 2009 / 10 / 28

المكان : مكتب المهندس المقيم .

المشروع : مشروع إنشاء وإجاز وصيانة عدد (279) بيتا + المباني العامة + الخدمات الرئيسية
بمشروع مدينة سعد العبد الله بالقطعة (8) .

تعهد : شركة كويت داينمكس المحدودة للمقاولات .

عقد رقم : م.ع.ر.س/ع/1113-2008/2009 .

الموضوع : اعتماد مصادر مواد لأعمال العازل .

الحضور : عن المؤسسة العامة للرعاية السكنية :

المهندس المقيم

نائب المهندس المقيم

نائب المهندس المقيم

المهندس / شكري أبو سريع

المهندس / عبد الرحمن بوطينان

المهندس / حمد حسين الهلال

عن المتعهد شركة كويت داينمكس المحدودة للمقاولات

ممثل المتعهد

المهندس / سمير وهيب جورجوس

وقائع الاجتماع


اجتمع الحضور لمناقشة ، ما جاء بكتاب المتعهد رقم KDL/623/2009 ، بتاريخ
2009/10/21 ، الموجه إلى المهندس المقيم ، والخاص بطلبه اعتماد مصادر مواد لأعمال العازل
بالعقد ، وقد اتفق الحضور على الموافقة المبدئية على اعتماد المصادر الموضحة بكتاب المتعهد
أعلاه حسب الجدول المرفق :

الاستخدام	المصنع أو الوكيل المعتمد (الموزع)	بلد المنشأ	الرمز	اسم المنتج	م
أعمال العازل بالعقد				كوبنتا رغوية FOAM	1
		الشركة الأهلية للكيماويات	الكويت	FOAMIX	A
		مصنع الخصوصية للكيماويات البناء	الكويت	KUT PLAST LWC	B
				عازل مائي ورطوية مع البرايمر	2
		الشركة الأهلية للكيماويات	الكويت	TURBAL	A
		شركة عوازل الكويت لمواد البناء	السعودية	DESERT SHIELD 40200	B
		مصنع القاتم للمواد الخصوصية (تم تغيير الاسم)	مصر	NILOBIT - PH	C

يتبع ... 2







المؤسسة العامة للرعاية السكنية
المنطقة الثانية عقد رقم 1113

(2)

الاستخدام	المصنع أو الوكيل المعتمد (الموزع)	بلد المنشأ	الرمز	اسم المنتج	م.
أعمال العازل بالعقد				قضبان أسفنجية للفواصل	3
	مصنع العمار	السعودية	R.T.W4/ 2	BAKAUP - ROD	A
	شركة صناعات الأسفنج الكويتية	الكويت	R.T.W4/ 4	قضبان أسفنجية للفواصل محلي	B
				معجون فواصل تمدد مع البرايمر	4
	الشركة الأهلية للكيماويات	الكويت	R.T.W5/7	PG - 10 (عبير)	A
	مصنع الخصوصية لكيماويات البناء	الكويت	R.T.W5/8	KUT THOSEAL 227	B
				عازل حراري	5
	شركة مصانع المواد العازلة للحرارة والتبريد - ليسوفوم	الكويت	R.T.W7/1	EXTRUDED POLY STYRENE	A
	شركة الخليج لتجارة وصناعة المواد العازلة	الكويت	R.T.W7/3	يسكو فوم 35 ESSCO FOAM	B
				ضربط لموتوم اصلي للعازل الحراري	6
	مصنع الخصوصية لكيماويات البناء	انجلترا	R.T.W8/1	IDENDEN ALUMUT LTD	A
	مؤسسة عبد الرضا غضنفر	الإمارات	R.T.W8/6	ANCHOR LIED	B
				رقائق بولي ايثيلين كيج 1000	7
	الشركة الكويتية لصناعة الحصر والمنتجات للبلاستيكية	الكويت	R.T.W11/1	رقائق بولي ايثيلين كيج 1000 محلي	A
	شركة التعبئة والصناعات لبلاستيكية	الكويت	R.T.W11/2	رقائق بولي ايثيلين كيج 1000 محلي	B
للشركة الأهلية للبلاستيك	الكويت	R.T.W11/3	رقائق بولي ايثيلين كيج 1000 محلي	C	
المصنع العربي للبلاستيك	الكويت	R.T.W11/4	رقائق بولي ايثيلين كيج 1000 محلي	D	
شركة الصناعات البلاستيكية	الكويت	R.T.W11/5	رقائق بولي ايثيلين كيج 1000 محلي	E	

وذلك بالشروط التالية :-

1. الأولوية للمصادر المحلية .
2. التوريد من مصدر واحد فقط .
3. تقديم عينات للمهندس المقيم لتدقيق عليها طبقاً للمطلوب بالعقد .
4. الاستخدام حسب شروط ومواصفات العقد والمخططات المعتمدة .

وأقبل المحضر ووقع الحضور بالموافقة على ما جاء أعلاه ولا يعمل بهذا المحضر إلا بعد

اعتماده من السيد / رئيس مهندسي المنطقة الثانية .

عن المؤسسة العامة للرعاية السكنية

عن المتعهد

المهندس

شاذي المهندس
عبد الوهاب
عبد الوهاب

نائب المهندس
عبد الوهاب
عبد الوهاب

شركة كويت ديبكس المحدودة للمقاولات ش.م.ك.
عقد رقم: 1113

المؤسسة العامة للرعاية السكنية

الإشارة : م 2 / 1113 / 665

التاريخ : 07 / 01 / 2010

المحترم

السيد / ممثل المتعهد

تحية طيبة وبعد ،،،

الموضوع : توريد عازل الرطوبة مع البرايمر الخاص

بـه المصـدر السـعودي

مشروع إنشاء وإنجاز وصيانة عدد (279)

بيتاً + المباني العامة + الخدمات الرئيسية

بمشروع مدينة سعد العبد الله بالقطعة (8)

عقد رقم : م.ع.ر.س/ع/1113-2008/2009

المتعهد : شركة كويت داينمكس


المحـددة للمقـاولات

بالإشارة إلى الموضوع أعلاه ، نفيدكم بأنه لا مانع من استخدام المنتج الخليجي
(شركة عوازل السعودية) وممثلها بالكويت " شركة عوازل الكويت لمواد البناء " لتوريد عازل
الرطوبة مع البرايمر الخاص به لأعمال العقد أعلاه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم

شكري أبو سريع



الرجاء -> فائق وارد المحيى
صورة - 1 - 12 صورة

- صاوي

- حرة الطبخ - مع الكبة المرفقة



المؤسسة العامة للرعاية السكنية

الإشارة : 237
التاريخ : 2007/08/14

السيد/ ممثل المتعهد (الشركة الكويتية الأولى للتجارة العامة والمقاولات)
المحترم تحية طيبة وبعد ...

الموضوع : طلبكم اعتماد عازل الرطوبة من المصدر السعودي
مشروع تخطيط وتصميم وإنشاء وإنجاز وصيانة
أعمال الطرق والبنية التحتية لعدد (840) قسيمة
وإنشاء وإنجاز وصيانة المباني العامة ومحطات
المحولات بالقطاع (A5) بمشروع مدينة جابر الأحمد
عقد رقم : م.ع.ر.س/ع/1028 - 2006/2005
تمهد : الشركة الكويتية الأولى للتجارة العامة والمقاولات

بالإشارة إلى الموضوع أعلاه ، وإلى كتابكم رقم ج.أ/367/2007 بتاريخ
2007/08/07 والمتضمن طلبكم اعتماد العازل (DESERT SHIELD 40200) من
المصدر السعودي السادة/ شركة عوازل السعودية وذلك بسبب توقف إنتاج المنتج المحلي
(طربال) المعتمد بالعقد أعلاه من المصدر المحلي السادة/ الشركة الأهلية للكيماويات نظراً
للحريق بمصنع الشركة الإنجليزية .
تعلمكم ، استناداً إلى كتاب إدارة ضبط الجودة بالمؤسسة رقم (768) بتاريخ 2007/07/23
بأنه لا مانع من استخدام المنتج السعودي في أعمال العقد أعلاه مؤقتاً وذلك لحين إصلاح
المصنع المحلي وعودة الإنتاج مرة أخرى.

وتفضلوا بقبول فائق الاحترام ...

المهندس المقدم
م / احسن الدسوقي مراد

استاذ
م / احسن الدسوقي مراد

المؤسسة العامة للرعاية السكنية

المنطقة الثالثة

عقد 1128

الإشارة : م.ع 2009/182

التاريخ : 13 / 12 / 2009

المحترم

السيد / ممثل المتعهد

تحية طيبة وبعد ،

الموضوع : اعتماد محضر مصادر مواد رقم (9)

مشروع : إنشاء وإنجاز وصيانة الطرق ومواقف السيارات

وشبكات خدمات البنية التحتية الرئيسية وتحديد القسائم لعدد

(1564) قسيمة + عدد (40) محطة محولات كهرباء فرعية

نموذج (4 محول) + عدد (8) محطات محولات كهرباء فرعية

نموذج (2 محول) للضاحية (C) بمشروع مدينة صباح الأحمد

عقد رقم : م.ع.ر.س/ع/1128 - 2010/2009

تعهد : SINO HYDRO CORPORATION (الصينية)

وكيلها المحلي / المركز العربي للتجارة والعقار

بالإشارة إلى الموضوع أعلاه، وإلى كتابكم رقم SHC/E/226/2009 بتاريخ


2009/12/06 ، مرفق لكم نسخة من محضر اعتماد مصادر المواد رقم (9) وذلك بعد

اعتماده للعمل بموجبه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم

شهاب أحمد علي


2009/12/13

2009/12/13
م.ع.ر.س/ع/1128

رستم
حسني
٢٠٠٩/١٢/١٠

محضر اعتماد مصادر مواد رقم (9)

م/عبدالمجيد الدويش
مساعد رئيس مهنسي المنطقة الثالثة

التاريخ: 2009/ 12 /09

المكان : مكتب المهندس المقيم .

المشروع : إنشاء وإنجاز وصيانة الطرق ومواقف السيارات وشبكات خدمات البنية التحتية الرئيسية وتحديد القسائم لعدد (1564) قسيمة + عدد (40) محطة محولات كهربائية فرعية (نموذج 4 محول) + عدد (8) محطات محولات كهرباء فرعية (نموذج 2 محول) للضاحية (C) بمشروع مدينة صباح الأحمد.

عقد رقم : م.ع.ر.س / ع / 1128 - 2010/2009

تعهد : SINO HYDRO CORPORATION (الصينية)

وكيلها المحلي / المركز العربي للتجارة والعقار

الموضوع : اعتماد مصادر مواد .

الحضور :

عن المؤسسة العامة للرعاية السكنية :

المهندس المقيم

فني مختبر

ممثل المتعهد

المهندس / شهاب أحمد علي 2009/12/9
السيد / عبدالمنعم الإمام محمد
عبدالمجيد

عن المتعهد :

المهندس / عبدالرحمن موسى فارس

وقائم الاجتماع

اجتمع الحضور لمناقشة الموضوع أعلاه ، بناء على كتاب المتعهد رقم SHC/E/226/2009

الموجه إلى المهندس المقيم بتاريخ 06 / 12 / 2009 (مرفق 1) بخصوص طلب المتعهد الموافقة على

اعتماد مصادر مواد لأعمال العقد أعلاه واتفق الحضور على ما يلي :-

أولاً : الموافقة المبدئية على اعتماد مصادر المواد الواردة بالجدول التالي :-

2009/12/9
مهندس
شهاب أحمد علي
١٠٠١٨

ممثل المتعهد ومدير المشروع
عبدالرحمن موسى فارس
عبدالمجيد

SINO HYDRO CORPORATION

* تابع محضر اعتماد مصادر مواد رقم (9) (عقد رقم 1128)

م	اسم المادة	اسم المنتج أو المصدر	بلد المنشأ	رمز المنتج	المصنع أو الوكيل المحلي المعتمد أو الموزعون
1	قطع البريكاست	قطع البريكاست للواجهات محلي	الكويت	G.F.W4/1	مصنع شركة الإنشاء والتصنيع العقاري - ميناء عبدالله
		قطع البريكاست لحوائط الواجهات للمحولات الكهربائية	الكويت	G.F.W4/3	الشركة العالمية للمباني
		قطع البريكاست	الكويت	G.F.W4/4	شركة هاي سلات للتجارة والمقاولات مبارك جاسم المطوع وشركاه
		قطع البريكاست	الكويت	G.F.W4/5	الشركة الصناعية للمباني والإنشاءات
2	براغي تثبيت قطع البريكاست	Rawl Plug anchor bolts	انجلترا	G.F.W7/1	-
3	سلك لحام	KOBELCPO	اليابان	G.F.W8/2	-
		TiAnjin METALS	الصين	G.F.W8/5	-
4	باب حديد مقاوم للحريق	باب حديد مقاوم للحريق	الكويت	S.T.M.W4/3	شركة خالد علي الخرافي
5	عازل مائي ورطوبة مع البرايمر	عازل TURBAL طربال محلي	الكويت	R.T.W2/3	الشركة الأهلية للكيماويات
		عوازل Desert Shield 40200	السعودية	R.T.W2/9	شركة عوازل الكويت لمواد البناء
		دير مابت 4200	السعودية	R.T.W2/1	شركة خليفة الجاسم للتجارة والمقاولات
6	بلاط موزايك	البلاط الموزايك محلي	الكويت	G.F.W16/5	مصنع الكويت الكبير للكاشي والموزايك
		البلاط الموزايك محلي	الكويت	G.F.W16/3	مصنع الساند
		البلاط الموزايك محلي	الكويت	G.F.W16/2	مصنع الدعيج والسيديراوي
		مصنع الكويت للكاشي	الكويت	G.F.W16/13	مصنع الكويت للكاشي (شركة الأعمال المتكاملة للتجارة العامة والمقاولات)
7	قضبان أسفنجية للفواصل	Roundex copex - SA	اسبانيا	R.T.W4/1	مصنع الخصوصية لكيماويات البناء
		قضبان أسفنجية للفواصل محلي	الكويت	R.T.W4/4	شركة صناعة الاسفنج الكويتية
		شركة عوازل الشرقية المحدودة	السعودية	R.T.W4/3	شركة عوازل الشرقية المحدودة
8	أصباغ داخلية وخارجية	أصباغ داخلي وخارجي محلي	الكويت	p.w1/1	شركة أصباغ جي تي سي المحدودة
		أصباغ داخلي وخارجي محلي (أصباغ فوجو)	الكويت	p.w1/6	مصنع المتروك للأصباغ
		أصباغ داخلي وخارجي محلي SERCOTE PAINT	الكويت	p.w1/5	شركة الصانع للمنتجات الكيماوية
		أصباغ داخلي وخارجي محلي	الكويت	p.w1/3	شركة أصباغ الكويت

ثانياً : - بالنسبة للمواد المقبولة مصادرهما بالجدول أعلاه يشترط الآتي :


- (1) أن يتم التصنيع والتوريد طبقاً لما هو مطلوب بمستندات العقد .
- (2) أن يتم استخدام مصدر واحد فقط للمادة الواحدة بالعقد .
- (3) أن يتم تقديم عينات للمهندس المقيم للتدقيق عليها ونجاحها بالفحوصات طبقاً لما هو مطلوب بمستندات العقد تمهيداً للاعتماد النهائي .
- (4) أن يتم تقديم التوثيق للمورد الموقع المعتمد على نتائجها للتدقيق عليها أولاً بأول وأن يتم الاستخدام طبقاً للمطلوب بمستندات العقد .

* تابع محضر اعتماد مصادر مواد رقم (9) (عقد رقم 1128)

- 5^٧ أن تكون المواد الموردة للموقع مطابقة للمواصفات والمخططات التعاقدية وان لا يستخدم أي منها بالمشروع إلا بعد ورود نتائج الفحص بالاعتماد .
- 6^٧ يتم اعتماد جميع المخططات من الإدارة العامة للإطفاء للمواد المستخدمة بالحريق قبل التوريد.
- 7^٧ الالتزام بالقرارات الصادرة من مجلس الوزراء ووزارة التجارة والصناعة والجهات المعنية والمتعلقة بدعم المنتجات الوطنية ثم المنتجات ذات المنشأ الوطني وذلك حسب الشروط والمواصفات التعاقدية.
- 8^٧ الالتزام بجميع المواصفات الفنية لوزارة الكهرباء والماء (وزارة الطاقة) بالنسبة للبند رقم (4) .
- 9^٧ تنفذ الأعمال بواسطة مقاول الباطن لأعمال المدنية الإنشائية (الخاصة بأعمال محطات المحولات الكهربائية الفرعية) بالنسبة للبنود أرقام (1 ، 2 ، 3 ، 4) وذلك حسب الشروط الخاصة بالعقد .


وعلى ما جاء أعلاه تم الاتفاق ووقع الحضور بالموافقة على ألا يعمل به إلا بعد اعتماده من السيد/ رئيس مهندسي المنطقة الثالثة .

عن المؤسسة العامة للرعاية السكنية


2009/12/9


مهندس
شهاب أحمد علي



2009/12/9


عن المتعهد

ممثل المتعهد ومدير المشروع
عبدالرحمن موسى فارس





المؤسسة العامة للرعاية السكنية

محضر اجتماع مصادر مواد رقم (2)

التاريخ : 2010/01/24
 المكان : مكتب المهندس المقيم
 المشروع : أعمال معالجة وتحسين خواص التربة الضعيفة للطرق الرئيسية وإنشاء وإنجاز وصيانة الطرق والخدمات الرئيسية وتصميم وإنشاء وإنجاز وصيانة مباني المحطة الساحلية والمحطة الأرضية ومبني الترددات ومباني الخدمات التابعة لوزارة المواصلات بمدينة جابر الأحمد السكنية .

المتهم : الشركة الأحمدية للمقاولات والتجارة
 عقد رقم : م.ع.ر.س/ع/1137 - 2010/2009
 الموضوع : طلب اعتماد مصادر مواد لأعمال العازل بمجرور صرف مياه الأمطار.
 الحضور :

عن المؤسسة العامة للرعاية السكنية :

المهندس / حسن الدسوقي مراد

المهندس / نواف علي المسلم

عن المتعهد (الشركة الأحمدية للمقاولات والتجارة).

المهندس / شربل إلياس الشمالي

ممثل المتعهد

وقائع الاجتماع :

اجتمع الحضور لمناقشة الموضوع أعلاه وذلك بناءً على كتاب المتعهد رقم ACTC/JAAC/PAHW/063 بتاريخ 2010/01/17 ، بخصوص طلب المتعهد اعتماد مصادر مواد لاستخدامها في أعمال العازل بمجرور صرف مياه الأمطار بالعقد أعلاه ، وقد تمت الموافقة الميدانية على اعتماد مصادر المواد التالية:

م	المصنعة	المصنع أو الوكيل المعتمد أو الموزع	بلد المنشأ	رمز المنتج
	عازل مالي ورطوبة مع البرايمر			
1	PROTECTION BOARD عوازل		السعودية	

وذلك بالشروط التالية:

1. الأولوية للمصادر المحلية
2. تقديم عينات للتدقيق عليها قبل الاستخدام وأن يتم إرسال عينات للفحص ومطابقتها بالمواصفات التعاقدية وأن يتم التوريد من مصدر واحد.
3. أن يتم التصنيع والتوريد طبقاً للمستندات التعاقدية.
4. أن يتم الاستخدام بالأماكن المحددة وطبقاً للمخططات التعاقدية.

المؤسسة العامة للرعاية السكنية

5. أن يتم وضع علامة المنتج واضحة إما بالحفر أو الطباعة علي كل المواد التي يتم توريدها للموقع.


6. الالتزام بالقرارات الصادرة من مجلس الوزراء ووزارة التجارة والصناعة والجهات المعنية والمتعلقة بتدعيم المنتجات الوطنية ثم المنتجات ذات المنشأ الوطني وحسب التفاصيل المشار إليها بالباب الرابع من الشروط الخاصة بالعقد.


وعليه ، أقفل المحضر وتم التوقيع علي ما جاء أعلاه، ولا يعتبر المحضر ساريا إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الثانية.


عن المتعهد

(الشركة الأحمدية للمقاولات والتجارة)

عن المؤسسة العامة للرعاية السكنية


2013 / 11/24




C.O. 1/11/13

المؤسسة العامة للرعاية السكنية

الإشارة : ١٨٢
التاريخ : 2010/07/05

السيد / ممثل المتعهد (الشركة الأحمدية للمقاولات والتجارة) المحترم
تحية طيبة وبعد ،،

الموضوع : محاضر اعتماد مصادر مواد أرقام (18) ، (19) مشروع: أعمال معالجة وتحسين خواص التربة الضعيفة للطرق الرئيسية وإنشاء وإنجاز وصيانة الطرق والخدمات الرئيسية وتصميم وإنشاء وإنجاز وصيانة مباني المحطة الساحلية والمحطة الأرضية ومبني الترددات ومباني الخدمات التابعة لوزارة المواصلات بمدينة جابر الأحمد السكنية عقد رقم : م.ع.ر.س/ع/1137 - 2010/2009
تعهد : الشركة الأحمدية للمقاولات والتجارة

بالإشارة إلى الموضوع أعلاه، مرفق طيه صورة من محضر اجتماع اعتماد مصادر مواد أرقام (18) ، (19) بتاريخ 2010/06/24 بعد الاعتماد من السيد / رئيس مهندسي المنطقة الثانية وذلك للعلم والعمل بما ورد فيه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم
م / حسن الدسوقي مراد
2010/7/5

المؤسسة العامة للرعاية السكنية

محضر اعتماد مصادر مواد رقم (18)

التاريخ : 2010/06/24

المكان : مكتب المهندس المقيم
المشروع : أعمال معالجة وتحسين خواص التربة الضعيفة للطرق الرئيسية وإنشاء وإنجاز وصيانة الطرق والخدمات الرئيسية وتصميم وإنشاء وإنجاز وصيانة مباني المحطة الساحلية والمحطة الأرضية ومبني الترددات ومباني الخدمات التابعة لوزارة المواصلات بمدينة جابر الأحمد السكنية .

المتعهد : الشركة الأحمدية للمقاولات والتجارة
عقد رقم : م.ع.ر.س/ع/1137 - 2010/2009
الموضوع : طلب اعتماد مصادر مواد لأعمال شبكات المياه والعازل وأعمال مكملة للخرسانة بالعقد.

الحضور :

عن المؤسسة العامة للرعاية السكنية :

المهندس / حسن الدسوقي مراد

المهندس / نواف علي المسلم

عن المتعهد (الشركة الأحمدية للمقاولات والتجارة).

ممثل المتعهد

المهندس / شريل إلياس الشمالي

وقائع الاجتماع :

اجتمع الحضور لمناقشة الموضوع أعلاه وذلك بناءً على كتاب المتعهد رقم ACTC/JAAC/PAHW/177 بتاريخ 2010/06/19 ، بخصوص طلب المتعهد اعتماد مصادر مواد لاستخدامها في أعمال شبكات المياه والعازل وأعمال مكملة للخرسانة بالعقد أعلاه ، وقد تمت الموافقة المبدئية على اعتماد مصادر المواد التالية:

م	المادة	المصنع أو الوكيل المعتمد أو الموزع	بلد المنشأ	رمز المنتج
بوليثيلين لتغليف أنابيب الدكتايل				
1	بوليثيلين لتغليف أنابيب الدكتايل محلي	شركة التعبئة والصناعات البلاستيكية	الكويت	W.S.W 7 /3
2	بوليثيلين لتغليف أنابيب الدكتايل محلي	الشركة الأهلية للبلاستيك	الكويت	W.S.W 7 /4

المؤسسة العامة للرعاية السكنية

م	المادة	المصنع أو الوكيل المعتمد أو الموزع	بلد المنشأ	رمز المنتج
دهان للأساسات				
3	Capseal	الشركة الأهلية للكيماويات	الكويت	C.C.W2 /1
4	Capseal Special	الشركة الأهلية للكيماويات	الكويت	C.C.W2 /2
إضافات للخرسانة				
5	KUT PLAST SP 100	مصنع الخصوصية لكيماويات البناء	الكويت	C.C.W4 /9
معجون فواصل تمدد مع البرايمر (مركب منع التسرب)				
6	KUT-THOSEAL 227	مصنع الخصوصية لكيماويات البناء	الكويت	C.C.W12 /8
عازل مائي ورطوبة مع البرايمر				
7	عازل TURBAL طريال محلي	الشركة الأهلية للكيماويات	الكويت	R.T.W2 /3
8	عوازل Desert Shield 40200	شركة عوازل الكويت لمواد البناء	السعودية	R.T.W2 /9

وذلك بالشروط التالية:

1. التوريد من مصدر واحد فقط.
2. أن يتم التصنيع والتوريد طبقاً لشروط ومواصفات العقد.
3. تقديم عينات للمهندس المقيم للتدقيق عليها تمهيداً للاعتماد النهائي.
4. تطبيق قرارات مجلس الوزراء الموقر بخصوص الأفضلية للمصادر المحلية علي المصادر الأجنبية أو ذات المنشأ الوطني.
5. هذا الاعتماد لا يعفي المنتج من إجراء الفحوصات اللازمة عند التوريد .
6. يتم أخذ عينات عشوائية لكل تشوين وترسل للفحص لدي جهات الفحص المعتمدة.
7. يشترط نجاح العينات المرسله للفحص اجتياز كافة الفحوصات المطلوبة.
8. مطابقة المواد المشونة بالموقع للعينة المعتمدة.
9. يتم مراعاة ظروف التخزين والتشوين بالموقع.
10. يتم استخدام المنتج المعتمد حسب تعليمات الشركة المصنعة.

وعليه ، أقل المحضر وتم التوقيع علي ما جاء أعلاه، ولا يعتبر المحضر سارياً إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الثانية.

عن المتعهد

عن المؤسسة العامة للرعاية السكنية

(الشركة الأحمدية للمقاولات والتجارة)

2010/6/28



التاريخ: 2007/07/03

رقم: ص.د. 07/K.D.L/02

المحترمين ،،
المحترم ،،

السادة / مؤسسة درة الخليج للمواد العازلة ومقاولاتها
عناية السيد / نديم نقولا
تحية طيبة وبعد ،،

الموضوع: اعتماد مصدر توريد مواد
مشروع: إنشاء وإنجاز وصيانة عدد (321) بيتاً + الميقاتي العامة
+ الخدمات الرئيسية بالقطعة رقم (10) بمدينة سعد العبد الله
(قطعة رقم "2" ضاحية سعد العبد الله سابقاً)
عقد رقم: م.ع.ر.س.ع/ع/1039-2005/2006

بالإشارة إلى الموضوع أعلاه،، وإلى كتابكم رقم (-) بتاريخ 2007/06/17 والخاص بطلبكم اعتماد المصدر السعودي (عوازل Desert shield 40200) لتصنيع وتوريد العازل المائي (عازل الرطوبة) مع البرايمر الخاص به ، وذلك عن طريق الوكيل المحلي المعتمد السادة/ شركة عوازل الكويت لمواد البناء .
مرفق طيه صورة من كتاب المهندس المقيم رقم (788) بتاريخ 2007/07/02 والمرفق معه أيضاً صورة محضر اعتماد المواد رقم (29) "البند رقم - 1" بعد الاعتماد وذلك للعمل بموجبه .

وتفضلوا بقبول وافر الاحترام ،،

مدير المشروع

م. سمير وهيب

استلمت الاصل
المرفقت :
كما ذكر اعلاه

المؤسسة العامة للرعاية السكنية

المنطقة الثانية

محضر الاجتماع رقم (49)

التاريخ : 2007 / 07 / 16

المكان : مكتب المهندس المقيم .

المشروع : إنشاء وإنجاز وصيانة أعمال الخدمات الرئيسية لعدد (714) قسيمة والمباني العامة للقطعة (9) بمشروع مدينة سعد العبد الله الإسكاني (قطعة -1- ضاحية سعد العبد الله سابقاً) .

تعهد : شركة مشرف للتجارة والمقاولات .

عقد رقم : م.ع.ر.س/ع/1027 - 2006/2005 .

الموضوع : اعتماد مصادر مواد .

الحضور : عن المؤسسة العامة للرعاية السكنية :

المهندس المقيم
مهندس ضبط جودة رئيسي



المهندس / جاسم حسن إبراهيم

المهندس / نواف علي خليفة المسلم

عن المتعهد شركة مشرف للتجارة والمقاولات

ممثل المتعهد



المهندس / محمد الشرييني


وقائع الاجتماع

اجتمع الحضور لمناقشة ما جاء بكتاب المتعهد رقم ك.م / 431/1027/2007 بتاريخ 2007/07/15 الموجه إلى المهندس المقيم والخاص باعتماد المصدر السعودي السادة / شركة عوازل الكويت لمواد البناء لأعمال العازل بدلا من السادة / مصنع الأهلية للكيماويات والذي توقف عن توريد مواد العازل للترطوية (طربال) بسبب الحريق الذي نشب به .

وإلى كتاب المتعهد رقم ك.م / 432/1027/2007 بتاريخ 2007/07/15 ، والخاص باعتماد السادة / شركة أصباغ الكويت كمصدر لتوريد الأصباغ ، فقد تمت الموافقة المبدئية على اعتماد مصادر المواد حسب الجدول الآتي :

م	اسم المادة	رمز المنتج	بلد المنشأ	المصنع أو الوكيل المحلي للمنتج
1	عوازل 40200 Desert Shield	R.T.W 2/9	السعودية	شركة عوازل الكويت لمواد البناء
2	أصباغ داخلي وخارجي "مطي"	P.W 1/3	الكويت	شركة أصباغ الكويت

يتبع ص 2



MUSHRIF
مشراف
التجارة والمقاولات
CONTRACT NO. PAHW /1027

المؤسسة العامة للرعاية السكنية

(2)


وذلك بالشروط التالية :

1. أن يتم التوريد من مصدر واحد فقط .
2. تقديم كتالوج للمهندس المقيم للاعتماد النهائي .
3. أن يتم التصنيع والتوريد طبقاً لشروط ومستندات العقد .
4. الأولوية للتوريد والاستخدام للمصادر المحلية ثم المصادر ذات المنشأ الوطني طبقاً لقرار وزارة التجارة والصناعة رقم (6) لعام 1987 والشروط التعاقدية .

وأقبل المحضر ووقع الحضور بالموافقة على ما جاء أعلاه ولا يعمل بهذا المحضر إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الثانية .

عن المؤسسة العامة للرعاية السكنية

عن شركة مشرف للتجارة والمقاولات



مهندس المواد الرئيسي
م. ز. ع. ع. ع.



مشرف للتجارة والمقاولات
CONTRACT NO. PAHW /1027

المؤسسة العامة للرعاية السكنية
المنطقة الثانية

صادر
عقد 1039
تاريخ: 2007/07/02
رقم الكتاب: 788

المحترم

السيد / ممثل المتعهد
تحية طيبة وبعد ،،،

الموضوع : محضر اعتماد المواد رقم (29)
مشروع إنشاء وإنجاز وصيانة عدد (321) بيتاً +
المباني العامة + الخدمات الرئيسية بالقطعة (10)
بمدينة سعد العبدالله (ضاحية سعد العبدالله قطعة 2 سابقاً)
عقد : م.ع.ر.س / ع / 1039 - 2005/2006
تعهد : شركة كويت داينمكس المحدودة للمقاولات

بالإشارة للموضوع أعلاه ، نرفق لكم محضر اعتماد المواد رقم (29) بعد
الاعتماد وذلك للعمل بموجبه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم

بزرع
بزرع

المرفقات :

المنكور أعلاه .

محضر اجتماع اعتماد مصادر مواد رقم (29)

تاريخ : 2007/06/19 م.
المكان : مكتب المهندس المقيم بالمقد .
العدد : م.ع.ر.م.ص/ع/1039-2006/2005 .
المشروع : مشروع إنشاء وإنجاز وصيانة صناد (321) بيتاً + البياني العام 2 + الخدمات
الرئيسية بالقطعة (10) بمدينة سعد العبد الله (ضاحية سعد العبد الله قطعة 2 سابقاً) .
المتعهد : شركة كويت داينمكس المحدودة للمقاولات .
الموضوع : اعتماد مصادر مواد .
الحضور :-

محضر
مهندس المقيم
نائب المهندس المقيم

عن المؤسسة العامة للرعاية السكنية :-
المهندس / بدر علي صالح الحداد
المهندس / عبد الرحمن محمد بوظيان

عن المتعهد (شركة كويت داينمكس المحدودة للمقاولات) :-

المهندس / سمير وهيب جورجوس
ممثل المتعهد

وقائع الاجتماع

اجتمع الحضور لمنقشة ما جاء بكتابي المتعهد رقم (K.D.L/1027/2007) بتاريخ (2007/06/17) ،
(K.D.L/1026/2007) بتاريخ (2007/06/17) والموجه للمهندس المقيم ، وللخاص بطلبه اعتماد مصادر
المواد الموضح بالكتب أعلاه ، وقد تمت الموافقة المبدئية على اعتماد المصادر حسب الجدول التالي :-

م	اسم المادة	رمز المنتج	بدا المنشأ	المصنع أو الوكيل المتعهد	مكان الاستخدام
1	أغطية وإطارات الجالبيات للجلفنة	S.W.W 14/1	الكويت	مصنع المر لإنتاج وحدات التحكم	شبكة صرف مياه الأمطار (الخدمات الخارجية)
2	عازل مائي ورطوية مع البرايمر (عوازل Desert Shield 40200)	R.T.W 2/4	السعودية	شركة عوازل الكريت لمواد البناء	الأسطح والحمامات

المؤسسة العامة للرعاية السكنية
المنطقة الثانية



مخبر رقم (29)

وذلك بالشروط التالية :-


1. الأولوية للمصادر المحلية طبقاً لقرار مجلس الوزراء وقرار وزير التجارة والصناعة .
2. التوريد من مصدر واحد .
3. تقديم عينات للمهندس المقيم لتدقيق عليها طبقاً للمطلوب بمستندات العقد .
4. التصنيع والتوريد والاستخدام حسب شروط ومواصفات العقد والمخططات المعتمدة .
5. أن تحمل التثوينات المورد العلامة التجارية الخاصة بالمصدر .

وعلى ما جاء أعلاه أقل المحضر بتوقيع الحضور ولا يعتبر هذا المحضر مسارياً إلا بعد
اعتماده من السيد / رئيس مهندسي المنطقة الثانية .

عن / المؤسسة العامة للرعاية السكنية



٢٠٠٧
١٥٦
١٥
١١

عن / المتعهد


مدير المشروع
سعيد وهيبا محمد جويش
شركة كوين ديليفريز الهندسة المعمارية والمعماريين
مخبر رقم 1039

محضر اجتماع رقم (13)

التاريخ : 2007 / 4 / 30 .

المكان : مكتب المهندس المقيم بالعقد .

المشروع : إنشاء وإنجاز وصيانة [روضة أطفال + مسجد محلي + سكن إمام +

مجموعة محلات + فرع غاز] بالجزء (2) + [مدرسة ابتدائية بنين +

مدرسة متوسطة بنين + مسجد محلي + سكن إمام + مجموعة محلات] بالجزء

(4) بمشروع أبو حليفة - المنقف الإسكاني .

رقم العقد : م.ع.ر.س / ع / 1042 - 2006 / 2007 .

المتعهد : شركة كويت داينمكس للمحودة للتجارة العامة والمقاولات

الموضوع : اعتماد مصادر مواد

الحضور :-

عن المؤسسة العامة للرعاية السكنية :

المهندس المقيم
فني المختبر

1 - المهندس / حسين دشتي

2 - السيد / السيد فهمي الأديب

عن المتعهد :

ممثل المتعهد

1 - المهندس / محمود جلا الله

وقائع الاجتماع

اجتمع الحضور لمناقشة ما جاء بكتاب المتعهد رقم [202 / KDL / 2007] بتاريخ 17 / 3 / 2007 وإلى منكرة إدارة ضبط الجودة رقم (369) بتاريخ 2007/4/25 بخصوص اعتماد المصدر السعودي عوازل DS40200 لتوريد لفات العزل المائي والبريمر الخاص به بعد تحقيقه للقرار الوزاري رقم (6) لسنة 1987 وقد اتفق الحضور على اعتماد المصدر أعلاه بالعقد وتم مراجعتها حسب برنامج مصادر المواد :-

م	المادة	اسم المنتج	رمز المنتج	المصنع أو الوكيل	المصدر
1	عازل مائي ورطوبة مع البريمر	Desert Shield 40200 عوازل	R.T.W2/4	شركة عوازل للكويت لمواد البناء	السعودية


بالنسبة للمواد المقبولة مصادرهما أعلاه يشترط الآتي :-

1- أن يتم التصنيع والتوريد طبقا لشروط ومواصفات العقد .

2- أن يتم التوريد من مصدر واحد للعقد .

- 3- أن يتم الاستخدام حسب الأماكن المحددة بالمخططات طبقاً لشروط ومواصفات العقد .
- 4- أن تحمل التشوينات المورد العلامة التجارية الخاصة بالمصدر .
- 5- مراعاة طرق التشوين طبقاً للمطلوب بمستندات العقد .
- 6- أن يتم تقديم التشوينات المورد للموقع للمواد المعتمد عيناتها للتدقيق عليها أولاً بأول وأن يتم الاستخدام طبقاً للمطلوب بمستندات العقد .
- 7- أن يتم تقديم عينات من هذه المواد للمهندس المقيم للتدقيق عليها ونجاحها بالفحوصات طبقاً لما هو مطلوب في مستندات العقد تمهيداً للاعتماد النهائي .
- وعليه أقفل المحضر ووقع الحضور بالموافقة على ما ورد أعلاه ولا يعمل بهذا المحضر إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الثالثة .
- عن المؤسسة العامة للرعاية السكنية


عن المتعهد



المهندس
حسين دابشقي
المهندس المقيم






ممثل المتعهد
مهندس / حسن جرارة

صادر
عقد رقم 940/ع/م.ع.ر.س.ع/ 2002/2003
رقم: 576
تاريخ 17/9/2003

المحترم

الموضوع :- اعتماد مصادر مواد

المشروع :- إنشاء وإجرا وصيانة عدد (1) مدرسة ابتدائية

بنات + (1) مدرسة متوسطة بنين + (1) مدرسة

متوسطة بنات بصلاحية جابر العلي (1) + (1) مدرسة

متوسطة بنين بقطاع 2 بمشروع القرين الإسكاني

تعمد :- شركة الإنشاء والتصنيع المقاولي


عقد رقم :- م.ع.ر.س.ع/ع/ 940 — 2002 / 2003

بالإشارة إلى الموضوع أعلاه ، نوفق لكم طيه محضر اعتماد مصادر المواد رقم 23 بتاريخ


2004/11/1 والخاضع باعتماد المصدر السعودي عوازل لأعمال جازل الرطوبة بالعدد وذلك بعد اعتماد.

وتفضلوا بقبول فائق الاحترام


الهندس المقيم


2004/11/9
م.ع.ر.س.ع/ع/ 940
الهندس المقيم

السيد / ممثل المتعهد
السيد / ممثل الشركة
السيد / ممثل الشركة

السيد / ممثل الشركة

2004/11/9

المؤسسة العامة للرعاية السكنية
المنطقة الأولى



المهترم ..

السيد / ممثل المتعهد

تعبئة طيبة وبعد ..

الموضوع : اعتماد مصادر المواد لأعمال العزل
المشروع : إنشاء وإتجاز وصيانة عدد (1) مسجد محلي + سكن إمام ق 1
+ عدد (1) روضة أطفال + مدرسة ابتدائية بنين + مدرسة متوسطة بنين
+ مسجد محلي + سكن إمام ق 2 + عدد (1) روضة أطفال
+ مسجد محلي + سكن إمام ق 3 + عدد (1) مسجد محلي + سكن إمام ق 4
بمشروع : مدينة سعد العبد الله (جنوب الجھراء سابقاً)
عقد رقم : م . ع . ر . م / س / ع / 1045 / 2006 - 2007
تعهد : مؤسسة سعد البوصل للتجارة والمقاولات العامة

بالإشارة إلى الموضوع أعلاه ،،، وإلى كتابكم رقم (م.س.ب/747/2006) بتاريخ 2007/6/24 والذي تطلبون فيه استخدام عازل الرطوبة والبرايمر الخاص به من المصنر السعودي DESERT SHIELD عازل .

نفيدكم علماً بأنه لا مانع لدينا من استخدام المذكور أعلاه من أعمال العزل المائي للعقد عاليه .

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم

م. علي عشوي الغزوي

المرفقات :

كما بعالية

المؤسسة العامة للحماية السكنية

المطبعة الثالثة

عقد رقم (1048)

التاريخ : 2007/7/25

الإشارة : 2007/524

السيد / ممثل المتعهد

تحية طيبة وبعد ،،،

المحترم

الموضوع: اعتماد مصدر عازل الرطوبة

والبرايمر الخاص به لأعمال العقد

المشروع : إنشاء وإنجاز وصيانة عدد (1) مركز ضاحية

رئيسي + عدد (1) مركز صحي نموذج (3) + (1)

مخفر شرطة قيادي نموذج (2004) + (1) فرع

غار بالقطاع (1د) بضاحية مبارك الكبير

تعهد : مؤسسة جرية للتجارة العامة والمقاولات

عقد رقم : م.ع.ر.س / ع / 1048 - 2006 / 2007

بالإشارة إلى الموضوع أعلاه ... والى كتابكم رقم ج.م.ض.ق / 2007/549

بخصوص الموافقة على اعتماد المصدر السعودي عازل DESERT SHIELD 20200

للتصنيع وتوريد عوازل الرطوبة والبرايمر الخاص به لأعمال العقد أعلاه ، ونحيطكم علماً بالموافقة المبدئية على طلبكم .

وعليه يطلب منكم مخاطبتنا لطلب اعتماد المصدر المذكور أعلاه ، حتى يتسنى لنا اعداد

محضر بالاعتماد حيث تم دراسة الموضوع على ضوء القرار الوزاري الخاص

باعطاء الأولوية للمنتجات الوطنية .

وتفضلوا بقبول فائق الإحترام ،،،

المهندس المقيم
علي حسين حسين

المهندس
صالح الرشيد

محضر اعتماد مصادر مواد رقم (32)

التاريخ : 31 / 7 / 2007

المكان : مكتب المهندس المقيم

العقد : م.ع.ر.س/ع/ 1048 - 2006 / 2007

المتعهد : مؤسسة جرية للتجارة العامة والمقاولات.

المشروع : إنشاء وإتجاز وصيانة عدد (1) مركز ضاحية رئيسي + عدد (1) مركز صحي نموذج
(3) + (1) مخفر شرطة قيادي نموذج (2004) + (1) فرع غاز بالقطاع (د) بضاحية
مبارك الكبير.

الموضوع: اعتماد مصادر مواد لأعمال العازل المائي

الحضور

المهندس المقيم

عن المؤسسة العامة للرعاية السكنية :-
المهندس / صالح الرشيد

ممثل المتعهد

عن مؤسسة جرية للتجارة العامة والمقاولات :-
المهندس / محمد محمد ابراهيم

وقائع الاجتماع

اجتمع الحضور لمناقشة الموضوع أعلاه بناءً على كتاب ممثل المتعهد رقم ج.م.ض.ق/617/2007 بتاريخ 2007/7/28 الموجه للمهندس المقيم بخصوص طلبه الموافقة على اعتماد المصدر السعودي عوازل DESERT SHIELD 40200 لتصنيع وتوريد عزل الرطوبة والبرايمر الخاص به لأعمال العقد أعلاه (مرفق 1) .

وبعد مناقشة الموضوع على ضوء القرار الوزاري رقم (6) لسنة 1987 الصادر من وزارة التجارة والصناعة والقرارات المعدلة له بشأن دعم المنتجات الوطنية والمنتجات ذات المنشأ الوطني (مرفق 2) واستناداً إلى مذكرة إدارة ضبط الجودة رقم 767 بتاريخ 2007/7/23 (مرفق 3) والتي

المهندس المقيم
صالح الرشيد

محمد محمد ابراهيم

ممثل المتعهد
محمد محمد ابراهيم

ما ورد بمحضر اجتماع لجنة إجراءات إعطاء الأولوية للمنتجات الوطنية المنعقد بغرفة اجتماعات إدارة ضبط الجودة بتاريخ 2007/7/18 والمعتمد من السيد/ المدير العام بتاريخ 2007/7/21 بنفس الخصوص (مرفقات 4-7) فقد تم الاتفاق على ما يلي:-
أولاً: الموافقة المبدئية على اعتماد المصدر المذكور أعلاه وذلك حسب الجدول التالي :-


م	اسم المادة	رمز المنتج	اسم المنتج	بند المنشأ	اسم المصنع أو الوكيل أو الموزع المعتمد
1	عازل ملكي ورطوبة مع البرايمر	R.T.W2/9	DESERT SHIELD عوازل 40200	السعودية	شركة عوازل الكويت لمواد البناء


ثانياً: يجب مراعاة الشروط التالية :-

- 1 - أن يتم التصنيع والتوريد طبقاً لشروط ومواصفات العقد .
- 2 - أن يتم استخدام مصدر واحد فقط لهذه المادة حيث انه سيبقى اعتماد المصدر المحلي السادة / الشركة الأهلية للكيمياويات لتوريد عزل الرطوبة نوع طربال وذلك بموجب محضر اعتماد مصادر مواد رقم 3 بتاريخ 2006/9/4 والمعتمد بتاريخ 2006/9/6 - بند 17 (مرفق 8 - 12) .
- 3 - أن يتم تقديم عينات للمهندس المقيم لاعتمدها قبل التوريد للموقع .
- 4 - تقديم التشوينات الموردة للموقع أولاً بأول فور ورودها للموقع .
- 5 - مراعاة ظروف التخزين السليمة لحماية التشوينات من التلف وعدم تعرضها لأشعة الشمس المباشرة
- 6 - تقديم نشرة فنية توضح المواصفات العالمية المطبق لها المنتج مع كتالوج اصل .
- 7 - أن تحقق التشوينات ما هو مطلوب بمواصفات العقد وان تجتاز الفحوصات التي تجرى عليها .
وعلى ضوء الالتزام بتنفيذ الشروط المذكورة أعلاه وتحقيق المطلوب بالمواصفات التعاقدية سوف يتم النظر في الاعتماد النهائي للمصدر المذكور أعلاه .
وعلى ما ورد أعلاه أقفل المحضر ووقع الحضور بالموافقة على ما جاء فيه على ألا يعمل به إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الثالثة .

عن المؤسسة العامة للرعاية السكنية :-

عن المتعهد :-





محضر اعتماد مصادر مواد رقم (16)

التاريخ : 2007 / 07 / 24

المكان : مكتب المهندس المقيم

المشروع : إنشاء وإنجاز وصيانة عدد (1) مركز ضاحية فرعي ق (3) + (1) مدرسة ثانوية بنات ق (1) + (1) روضة أطفال + مدرسة ابتدائية بنين ق (2) + (1) مجموعة محلات ق (2) + (1) روضة أطفال ق (4) بمشروع ضاحية عبد الله المبارك الصباح .

العقد : م . ع . ر . س / ع / 1051 / 2006 / 2007

المتعهد : شركة غسان أحمد الخالد وشركاه .

الموضوع : اعتماد مصادر مواد لأعمال عازل الأسطح .

الحضور : عن المؤسسة العامة للرعاية السكنية :

المهندس المقيم

مهندس موقع

فنى المختبر

ممثل المتعهد

(1) المهندس / عبدالعزيز عبدالله الشايجي

(2) المهندس / هلال عبدالوهاب الهلال

(3) السيد / طلعت أحمد الجندي

عن المتعهد (شركة غسان أحمد الخالد وشركاه) :

المهندس / محمد حسين الباز

الوقائع :-

اجتمع الحضور لمناقشة ما جاء بكتاب المتعهد رقم : غ .أ.خ / 600 / 2007 بتاريخ 2007/07/22 الموجه إلى المهندس المقيم والخاص بطلبه اعتماد المصدر السعودي (عوازل) (DS40200) لتصنيع وتوريد لفات العزل المائي والبرايمر الخاص به لإستخدامه بالعقد أعلاه ، وذلك نظراً لحدوث حريق بمصنع الشركة الأهلية للكيمياويات والمخازن الخاصة بها وتوقف التوريد منها لمدة غير معلومة وإستناداً إلى دليل مصادر المواد المعتمدة بمشاريع المؤسسة العامة للرعاية السكنية ، فقد تم الاتفاق بين الحضور بالموافقة على الإعتماد المبدئي لتوريد المادة المذكورة بالجدول أدناه من المصدر المذكور أمامها :

م	المادة	اسم المنتج	رمز المنتج	المصنع أو الوكيل المعتمد	بلد المنشأ
1	عازل مائي ورطوبة مع البرايمر	عوازل DESERT SHIELD 40200	R.T.W2/9	شركة عوازل الكويت لمواد البناء	السعودية

وذلك بالشروط التالية :-

1- أن يتم التصنيع والتوريد طبقاً لشروط ومستندات العقد .

2- تقديم عينات من هذه المواد للمهندس المقيم للتدقيق عليها ونجاحها بالفحوصات طبقاً للمطلوب بمستندات العقد تمهيداً للإعتماد النهائي .

يتبع * (2)



(2)


- 3- أن يتم تقديم التوثيق للمورد للموقع المعتمد عيناتها للتدقيق عليها أولاً بأول وأن يتم الإستخدام طبقاً للمطلوب بمستندات العقد .
- 4- مراعاة طرق التشويين الصحيحة .
- 5- ان تحمل التوثيق المورد العلامة التجارية الخاصة بالمصدر موضحة بطريقة لا تمحي .
- 6- سيتم رفض أى كمية يتم توريدها للموقع غير محققة للمطلوب بمستندات العقد .
- 7- أن يتم الإلتزام بتعليمات الصانع أثناء التنفيذ .

أقل المحضر ووقع الحضور بالموافقة على ما جاء به أعلاه ولا يعتبر المحضر سارى المفعول إلا بعد إعتماده من السيد / رئيس مهندسي المنطقة الرابعة بالمؤسسة العامة للرعاية السكنية .

عن المؤسسة العامة للرعاية السكنية

عن المتعهد


06 محمد عبد العزيز
شركة غسان احمد الخالد
عقد رقم 02-ع-ر-س-1051/ع1-2006-2007

المؤسسة العامة للرعاية السكنية
المنطقة الرابعة

السيد / ممثل المتعهد
تحية طيبة وبعد ...

المستورم

شماره: ٢٠٠٧ / ٢٠٠٨ / ١٠٧٥ / ٥٠٢ / ٠٨
تاريخ: ٢٠٠٨ / ١٠ / ٢٧
المنطقة: ٤
الشارع: ٣٠٨ / ٤١٤١

الموضوع : أعمال عزل الأسطح لبيت الامام والمؤذن

مشروع: إنشاء وإنجاز وصيانة عدد (1) مركز ضاحية
فرعي + عدد (1) مخفر شرطة نموذج (2004- الأشغال) + عدد
(1) سكن إمام ومؤذن + عدد (1) مركز صحي + عدد (1)
فرع غاز بالقطعة (5) بمشروع مدينة سعد العبدالله الإسكاني
مقدرة: م.ع.ر.س / ع / 1075 / 2006 / 2007
تعمد: شركة إبراهيم الناصر الهاجري وأولاده

بالإشارة إلى الموضوع أعلاه ، والى كتبكم أرقام 08/502/1075 - بتاريخ 2008/2/20 بنفس
الخصوص ، نفيدكم بالموافقه على استخدام المصدر السعودي عوازل فى اعمال عزل لسطح لبيت الامام
والمؤذن لحين اعتماد المصدر المذكور .

وتفضلوا بقبول فائق الاحترام ،،،

الهندس القيم

محمد طالب جمال

بريد / ملف الصف

صفه ملفه امتحان للموار

أ. م. خالد

نتي لختبر . صوره للمقاول
للعلم وعمد اللازم شكراً

2008
02
27

المؤسسة العامة للحماية السكنية

المنطقة الأولى

معرض اجتماع رقم (11)

التاريخ : 2007/10/22
المكان : مكتب المهندس المقيم
المشروع : إنشاء وإنجاز وصيانة عدد (443) بيتاً والمباني العامة والخدمات الرئيسية وتنسيق الموقع بالقطعة رقم (8) بمنطقة سعد العبد الله
العقد : م.ع.ر.س/ع/1079 - 2007 / 2008
المتعهد : شركة غسان أحمد سعود الخالد وشركاه
الموضوع : طلب اعتماد مصادر توريد مواد لازمه للعقد .

الحضور

عن المؤسسة العامة للحماية السكنية

1- المهندس / حبيب محمد طاهر

عن المتعهد (شركة غسان أحمد الخالد)

1- المهندس / حسام طاهر مشهور

اجتمع الحضور لمناقشة ما جاء بكتاب المتعهد رقم (غ.أ.ك.ح - 2007/219) بتاريخ 2007/10/17 بنفس الخصوص .

وبعد المناقشة والدراسة تمت الموافقة المبدئية على اعتماد المصدر السعودي عوازل لتصنيع وتوريد عازل الرطوبة Desert shield 40200 (رمز R.T.W 2/9) مع البرايمر الخاص به لإستخدامه لأعمال عازل الرطوبة بالمشروع وذلك بعد إستيفاء قرار وزارة التجارة والصناعة رقم (9) لعام 1987 (مرفق صورة) بضرورة أن يكون فرق السعر بين المنتج الوطني و المنتج ذات المنشأ الوطني لا يقل عن 5 % وأن فرق السعر حسب عروض الأسعار المقدمه هو 10.67 % .
وذلك بالشروط الآتية :

- 1- أن يتم التوريد من مصدر واحد فقط للمشروع حيث سبق اعتماد المصدر المحلي الشركة الأهلية للكيمياويات كمصدر لتصنيع وتوريد عازل الرطوبة من نوع TURBAL .
- 2- أن يتم التصنيع و التوريد طبقاً للشروط و المواصفات التعاقدية .
- 3- تقديم عينات مصحوبه بكتالوجات أصلية للمهندس المقيم للتدقيق عليها وإجراء الفحوصات التعاقدية قبل التوريد .
- 4- تقديم النشرات الفنية وشهادات المنشأ و الكتالوجات الأصلية لمصادر المواد أعلاه تشمل المواصفات القياسية العالمية المطابق لها المنتج وطريقة الاختبار ونتائج الفحص .
- 5- لا يصرح باستخدام المواد إلا بعد إجراء الفحوصات التعاقدية وتحققها لمتطلبات العقد .
- 6- تشوين المواد حسب أصول التخزين وبطريقة يسهل التدقيق عليها .

١٠٠١٢٣

المؤسسة العامة للرعاية السكنية
المنطقة الأولى

محضر (11)

- 2 -


- 7- تقديم الوكلاء المحليين أو الموزعين المعتمدين بدولة الكويت للمواد المستوردة.
 - 8- تقديم نسخه من كل عقود التوريد للمواد المعتمدة أعلاه والتي ستستخدم في أعمال العقد وكذلك تقديم فواتير الشراء أو الاعتمادات البنكية لتوريد المواد مبينا عليها رقم العقد وأسم المشروع وموقعه.
 - 9- مراعاة القرار الوزاري المتعلق بحماية المنتجات المحليه وذات المنشأ الوطني على أن تكون الأولويه للمصادر المحليه .
 - 10- أن يتم استخدام المواد حسب شروط ومواصفات العقد وفي الاماكن المخصصة لها تعاقديا وحسب تعليمات وكتالوج الشركة المصنعة.
- وأفقل المحضر على ما جاء به أعلاه ، ويرفع إلى السيد/مساعد رئيس مهندسي المنطقة الأولى للاعتماد .

عن المؤسسة العامة للرعاية السكنية

عن التعهد

١٠٠١٢٤
س
١٠/١٠/٢٤

س
١٠/١٠/٢٤



المؤسسة العامة للرعاية السكنية
المنطقة الرابعة

مشروع مدينة صباح الأحمد
عقد 1176
صادر: (للمرجع)
الرقم:
التاريخ: 9/7 1432

المحترم

السيد / ممثل المتعهد

(شركة جلفار للمهندسة والمقاولات)

تحت طيبة وبعد ...

الموضوع : عازل الرطوبة للخزانات الأرضية

مشروع : إنشاء وإنجاز وصيانة الطرقات
ومواقف السيارات وشبكات خدمات البنية التحتية الرئيسية
للمحور الخدمي بمشروع مدينة صباح الأحمد
عقد رقم : م . ع . ر . س / ع / 1176 — 2012/2011

بالإشارة إلى الموضوع أعلاه ،،، والى كتابكم رقم: GECK/RE/296/12 بتاريخ
2012/9/2 بخصوص طلبكم الموافقة على استخدام عازل الرطوبة السعودي (عوازل) بخزانات المياه
الأرضية في (ZONE,5,8,9) بالعقد أعلاه .

نفيدكم بأنه لا مانع لدينا من استخدام عازل الرطوبة السعودي (عوازل) في أرضيات
الخزانات وغرف المضخات لحين صدور قرار لجنة مفاضلة الأسعار شريطة أن يكون عازل الرطوبة
مطابق لشروط ومستندات العقد وعلى أن تتحملوا كامل المسؤولية المترتبة على نتائج المفاضلة في
حال صدور قرار بذلك.

وتفضلوا بقبول فائق الإحترام ،،

المهندس المقيم الرئيسي

عبد العزيز عبدالله الشايعي

Mr. / M. / Ms. / Mrs. / Dr. / Prof. / Other	
Name	
Signature	✓
Appr. /	✓
Date	
Mr. / M. / Ms. / Mrs. / Dr. / Prof. / Other	
Name	
Signature	
Date	
Mr. / M. / Ms. / Mrs. / Dr. / Prof. / Other	
Name	
Signature	
Date	
Mr. / M. / Ms. / Mrs. / Dr. / Prof. / Other	
Name	
Signature	
Date	
Mr. / M. / Ms. / Mrs. / Dr. / Prof. / Other	
Name	
Signature	
Date	
Mr. / M. / Ms. / Mrs. / Dr. / Prof. / Other	
Name	
Signature	✓
Date	

المحترم

نسخة للسيد / رئيس مهندسي المنطقة الرابعة

المؤسسة العامة للرعاية السكنية
المنطقة الرابعة

مشروع مدينة صباح الأحمد
عقد 1176
صادر: ()
الرقم: ١٥
التاريخ: ٢٠١١ / ٩ / ٢٠

السيد / ممثل المتعهد

(شركة جلفار للهندسة والمقاولات)

تحية طيبة وبعد ...

Geckir Kuwait	Action	Inform
Head Office	CEO/OM	✓
Deputy PM		✓
Program Engr.		
Site Engr	Anwar	✓
Safety Engr		
Elec/Mech Engr.		
Foreman		
Qty Surveyor		✓
Land Surveyor		
Lab Technician		✓
Subcontractor		✓
Others		

الموضوع : اعتماد مقاول باطن لأعمال الطبقات العازلة

مشروع : إنشاء وإتجار وصيانة الطرقات
ومواقف السيارات وشبكات خدمات البنية التحتية الرئيسية
للمحور الخدمي بمشروع مدينة صباح الأحمد
عقد رقم : م . ع . ر . س . ع / 1176 / ج / 2011 / 2012

بالإشارة إلى الموضوع أعلاه ،،، والى كتابكم رقم: GECK/RE/236/12 بتاريخ
2012/7/22 بخصوص طلبكم الموافقة على اعتماد السادة / مؤسسة الطاقم الفني للتجارة العامة
والمقاولات لأعمال الطبقات العازلة للحرارة والرطوبة لأعمال العقد أعلاه .
نفيدكم بأنه لا مانع من الموافقة على اعتماد السادة / مؤسسة الطاقم الفني للتجارة العامة
والمقاولات كمقاول باطن لأعمال الطبقات العازلة للحرارة والرطوبة بالعقد أعلاه فقط وفي ضوء
جودة الأعمال المنفذة من قبله سوف ينظر باعتماده لباقي المشاريع وبالشروط التالية :-
1- تقديم كشف بالعمالة الفنية المتخصصة للأعمال المذكورة أعلاه والموجودة على كفاية
الشركة وإرفاق ما يثبت ذلك .
2- التنفيذ طبقاً لشروط ومواصفات العقد .

وتفضلوا بقبول فائق الإهتمام ،،

المهندس القيم الرئيسي

عبد العزيز عبد الله الشايعي

المحترم


- نسخة للسيد / رئيس مهندسي المنطقة الرابعة

شركة أبناء عبدالرحمن البشر
للتجارة العامة والمقاولات

مجموعة شركات أبناء عبدالرحمن البشر

الإشارة: 09/157/ن

التاريخ: 2007/9/23



المحترم

السيد / المهندس المقيم

تحية طيبة وبعد ،،،

الموضوع: اعتماد مصـالـر مـواد
المشروع: إنشاء وإنجاز وصيانة
عدد (209) بيتاً + المباني العامة +
الخدمات الرئيسية بمشروع مدينة
سعد العبدالله الإسـكـاني - قطعة (8)
عقد رقم م.ع.ر.س/ع/1080/2007-2008

بالإشارة إلى الموضوع أعلاه ،،، يرجى التكرم بالموافقة على اعتماد مصدر عازل
الرطوبة والبرايمر الخاص به لأستخدامه بالمشروع المذكور أعلاه ، وذلك نتيجة حدوث حريق
بمصنع الاهلية للكيمياويات وتوقف الإنتاج لمدة غير معلومة ، والمادة هي كمايلي :-

م	المادة	اسم المنتج	رمز المنتج	المصنع أو الوكيل المعتمد	بلد المنشأ
1	عازل مائي و رطوبة مع البرايمر الخاصة به	DESERT SHIELD 40200	R.T.W2/9	شركة عوازل للكريت لمواد البناء	السعودية

شاكرين لكم حسن تعاونكم معنا

وتفضلوا بقبول فائق الاحترام والتقدير ،،،


المحترم

الاخ / فني المختبر

يودى الساكوسا ترفقى الإنتاج
بمصنع الاهلية وفى حاله الساكوسا
يرجى تولى حضراتهما و لا تنسى
بشكر المنتج الجديد

ممثل المتعهد

م. بكر عطوان



9
7
مرفقات: اعتمادات سابقة

جارة عامة

قاولات إنشائية

قاولات كهربائية

قاولات زراعية

مال ميكانيكية

مال صحية

قاولات وصيانة تكييف

تأمين سيارات

الن حديدية

السيد / ممثل المتعهد (شركة أبناء عبدالرحمن البشر للتجارة العامة والمقاولات) **المحترم**
تحية طيبة وبعد ،،،

الموضوع: محضر الاجتماع رقم (11)

مشروع إنشاء وإنجاز وصيانة عدد (209) بيتا +
المباني العامة + الخدمات الرئيسية
بمشروع مدينة سعد العبد الله الإسكاني - قطعة / 8
عقد رقم : م.ع.ر.س/ع/1080 - 2008/2007
تعهد : شركة أبناء عبدالرحمن
البشر للتجارة العامة والمقاولات

بالإشارة إلى الموضوع أعلاه ، مرفق طيه صورة من محضر الاجتماع
رقم (11) والخاص باعتماد مصادر مواد لأعمال عازل الأسطح . للعقد أعلاه وذلك بعد
الاعتماد للعمل بموجبة .

وتفضلوا بقبول فائق الاحترام ،،،

~~المهندس المقيم~~
~~عبدالله بن عبدالعزيز الفوزان~~
نائب للمهندس المقيم

محضر اجتماع رقم (11)

احمد
11/15/07

التاريخ : 2007/9/ .

المكان : مكتب المهندس المقيم .

المشروع : مشروع إنشاء وإنجاز وصيانة عدد (209) بيتا + المباني العامة + الخدمات الرئيسية
بمشروع مدينة سعد العبد الله الإسكاني - قطعة / 8 .

العقد : م.ع.ر.س/ع / 1080 - 2007 / 2008 .

المتعهد : شركة أبناء عبد الرحمن البشر للتجارة العامة والمقاولات .

الموضوع : اعتماد مصادر مواد لأعمال عازل الاسطم .

الحضور :

عن المؤسسة العامة للرعاية السكنية :-

المهندس المقيم .

• المهندس / عبد المحسن علي البناي

فتى المختبر .

• السيد / محمد محمد عبد المنعم

عن المتعهد (شركة أبناء عبد الرحمن البشر للتجارة العامة والمقاولات) :-

ممثل المتعهد

• المهندس / بكر عطوان الطه

المرجع :-

❖ كتاب المتعهد رقم 09/157/ن بتاريخ 2007/9/23 .

وقائع الاجتماع :-

اجتمع الحضور لمناقشة ما جاء بكتاب ممثل المتعهد المذكور أعلاه إلى المهندس المقيم والخاص بطلبية اعتماد المصدر السعودي (عوازل) (D-S-40200) لتصنيع وتوريد لقات العزل المائي والبرايمر الخاص به لاستخدامه بالعقد أعلا ، وذلك نظرا لحدوث حريق بمصنع الشركة الأهلية للكيمائيات والمخازن الخاصة بها وتوقف التوريد منها لمدة غير معلومة واستنادا إلى دليل مصادر المواد المعتمدة بمشاريع المؤسسة العامة للرعاية السكنية فقد تم الاتفاق بين الحضور بالموافقة على الاعتماد المبدئي لتوريد المادة المذكورة بالجدول أدناه من المصدر المذكور أمامها وذلك بالشروط اللاحقة .

المؤسسة العامة للرعاية السكنية
المنطقة الرابعة

م	المادة	اسم المنتج	رمز المنتج	المصنع أو الوكيل المتعهد	بلد المنشأ
1	عازل مائي رطوبة مع البرايمر الخاصة به	DESERT SHIELD 40200	R.T.W 2/9	شركة عوازل الكويت	السعودية

1. أن تكون المواد الموردة مطابقة لشروط ومواصفات العقد .
2. أن يتم تقديم عينه للسيد/ المهندس المقيم لاعتمادها قبل التوريد لكل هذه المواد .
3. أن يتم استخدام هذه المواد حسب شروط ومواصفات العقد وفي الأماكن المخصصة تعاقديا وحسب تعليمات وكتالوج المنتج .
4. أن ترسل العينات اللازمة من هذه المواد لإجراء الفحص اللازم عليها قبل التوريد وأن تكون محققة للمطلوب تعاقديا .
5. يلتزم المتعهد بتقديم الكتالوجات الأصلية والنشرات الفنية للمواد المستخدمة وحيثما يطلب منه .
6. على المتعهد تقديم نسخة من كل عقود التوريد من المواد المعتمدة والتي ستستخدم في أعمال العقد وكذلك تقديم فواتير الشراء مبينا عليها رقم العقد واسم المشروع وموقعه.
7. أن يتم تشوين المواد بطريقة جيدة وحتى لا تتأثر من العوامل الجوية .

وعلى ما جاء أعلاه أقلل المحضر ووقع الحضور على أن لا يعمل بهذا المحضر إلا بعد اعتماده من السيد / رئيس مهندسي المنطقة الرابعة .

عن المؤسسة العامة للرعاية السكنية

المتعهد (شركة أبناء عبدالرحمن العشر ن.م.م.)

م. عبد الرحمن العشر

م. عبد الرحمن العشر

م. عبد الرحمن العشر

م. عبد الرحمن العشر

السيد / ممثل المتعهد (شركة أبناء عبدالرحمن البشر للتجارة العامة والمقاولات) المحترم
تحية طيبة وبعد ،،،

الموضوع : نتائج فحوصات معتمدة

مشروع إنشاء وإنجاز وصيانة عدد (209) بيتا +
المباني العامة + الخدمات الرئيسية
بمشروع مدينة سعد العبدالله الإسكاني - قطعة / 8
عقد رقم : م.ع.ر.س/ع/1080 - 2007/2008
تعهد : شركة أبناء عبدالرحمن
البشر للتجارة العامة والمقاولات

بالإشارة إلى الموضوع أعلاه ، نرفق لكم نتائج فحص عازل الرطوبة سماك 4 مم
(D S 40200) من المصدر السعودي عوازل وبلاط موزاييك قياس 25 × 25 × 2.5 سم
من المصدر الكويتي مصنع الكويت الكبير والواردة من المركز الحكومي للفحوصات
والمختبرات - وزارة الأشغال وذلك كما موضح بالجدول أدناه :-

رقم الفحص	رقم الشهادة	تاريخ الشهادة	البيان	قرار المؤسسة
1	2008/2586	2009/1/12	عازل الرطوبة سماك 4 مم	يعتمد
2	2008/2586 B(1/3)	2008/12/25	عازل الرطوبة سماك 4 مم	يعتمد
3	2008/2686	2009/1/18	بلاط موزاييك قياس 25 × 25 × 2.5 سم	يعتمد

والتي وردت بالاعتماد .


وتفضلوا بقبول فائق الاحترام ،،،

الهندس القيسم

م. عبد الرحمن البشر

المؤسسة العامة للرعاية السكنية

المنطقة الرابعة



المحترم

السيد / ممثل المتعهد

(شركة الإنشاء العقارية)

تحية طيبة وبعد ،،،

الموضوع : عازل الرطوبة بالسوق المركزي

مشروع : إنشاء وإنجاز وصيانة المباني العامة

بالضاحية (B) بمشروع مدينة صباح الأحمد السكنية

عقد رقم : م . ع . ر . س / ع / 1186 / 2012/2011

بالإشارة إلى الموضوع أعلاه ،،والى كتابكم رقم : ERESO/1186/107/2012 بتاريخ 2012/8/730 بخصوص طلبكم الموافقة على استخدام عازل الرطوبة السعودي (عوازل) بمبنى السوق المركزي وخزان المياه بالعقد أعلاه .

نفيدكم بأنه لا مانع لدينا من استخدام عازل الرطوبة السعودي (عوازل) وفي الأماكن المحددة بكتابكم المذكور أعلاه لحين ظهور قرار لجنة مفاضلة الأسعار شريطة أن يكون عازل الرطوبة مطابق لشروط ومستندات العقد وعلى أن تتحملوا كامل المسؤولية المترتبة على نتائج المفاضلة في حال صدور قرار بذلك.

وتفضلوا بقبول فائق الإحترام ،،،

المهندس المقيم الرئيسي

عبدالعزیز عبداللہ الشایحی

نسخة للسيد / رئيس مهندسي المنطقة الرابعة المحترم

* نائب مدير المشروع
* م. المواد
* الملف

٥٠٩٠٢٠١٢

التاريخ: 2012/08/16.

المرجع: 2012 / 89 / 1186 / ERESO

المحترم

السيد / المهندس القيم الرئيسي

تحية طيبة وبعد،،،

الموضوع: عازل رطوبة مع البرايمر

المشروع: إنشاء وإنجاز وصيانة المباني العامة بالضاحية (B)

بمشروع مدينة صباح الأحمد السكنية

عقد رقم: م.ع.ر.س/ع/1186 - 2011 / 2012

بالإشارة إلى الموضوع أعلاه، يرجى التكرم بتحديد موعد لإجراء المفاضلة

السعرية بين كل من المصادر التالية:-

1- المصدر المحلي - السادة / الشركة الأهلية للكيماويات لتصنيع و توريد عازل رطوبة

طوبال سماكة 4 ملم مع البرايمر.

2- المصدر السعودي عوازل " Desert Shield " 40200 الوكيل الحصري بدولة

الكويت - السادة / شركة خاجة للمواد الخصوصية.

شاكرين لكم حسن تعاونكم ،،،

وتفضلوا بقبول فائق الاحترام،،،،،

ممثل المتعهد

م. نبيل إبراهيم الهندى

م. نبيل إبراهيم الهندى

ERESCO

عقد رقم 1186 - 2011 / 2012

المؤسسة العامة للحماية السكنية

المطقة الثالثة

عقد رقم (1191)

التاريخ : 2012/12/3

الإشارة: 2012/52

المحترم

السيد/ ممثل المتعهد

تحية طيبة وبعد،،،

الموضوع: اعمال عازل الرطوبة

المشروع: إنشاء وإنجاز وصيانة خزانات مياه الري
بمدينة صـــــــــــــــــباح الأحـــــــــــــــــمد

تعهد: شركة ساي للتجارة العامة والمقاولات

عقد رقم: م.ع.ر.س / ع / 1191 - 2012/2013

بالإشارة إلى الموضوع أعلاه ،،، وإلى كتابكم رقم SAI/OD/1191/049/2012 بتاريخ

2012/11/25 بنفس الخصوص .

نفيدكم بأنه نتيجة لتوقف المصدر المحلي طريال (الشركة الأهلية للكمياويات) عن أنتاج البرايمر الخاص بعازل الرطوبه حيث أنه غير مطابق للمواصفات التعاقدية (MSTM-D41) ودفعاً للعمل بالمشروع فإنه لا مانع لدينا من الموافقة على طلبكم باستخدام عازل الرطوبة السعودي (DESERT SHIELD 40200) وذلك بعد اعتماد مقال الباطن لأعمال العزل بالعقد مع الالتزام بما ورد بمحضر اعتماد مصادر المواد رقم 4 والمعتمد بتاريخ 2012/11/11 بخصوص مطابقه للمواصفات التعاقدية وطريقة الاستخدام بالموقع.

وتفضلوا بقبول فائق الاحترام ،،،

المهندس المقيم

عائلي العبيدي

STATE OF KUWAIT

MINISTRY OF PUBLIC WORKS



دولة الكويت
وزارة الأشغال العامة

شهادة اعتماد

AWAZEL DS40200

اسم الشركة / المصنع :

شركة عوازل الكويت لمواد البناء.

العنوان :

ت : 25712223 - 24826677 فاكس : 25749228 - 24826801.

ص.ب : 42137 الشويخ - الرمز البريدي : 70652.

تاريخ الانتهاء

2015/8/18

تاريخ الإصدار

2013/8/19

9

وصف المواد المعتمدة :

- AWAZEL DESERT SHIELD 40200, " 4 mm thick , APP Modified Bituminous Membrane, reinforced with non woven polyster mat , Type II , Grade S ", produced by AWAZEL company – Saudi Arabia.

ملاحظات :

- ضرورة الالتزام بالمواصفات العامة للوزارة والمواصفات الخاصة لكل مشروع على حده والمتعلقة بهذا المنتج .
- يتم التقدم بهذا المنتج من خلال المقاولين المعتمدين لمشاريع وزارة الأشغال العامة التي يطلب فيها استخدام هذا المنتج شريطة أن تطابق مواصفات هذا المنتج المواصفات الخاصة لأي عقد من عقود وزارة الأشغال العامة كل على حده .
- هذا الاعتماد لا يعفي هذا المنتج من إجراء الفحوصات اللازمة عند التوريد لأي مشروع .
- تلتزم وزارة الأشغال العامة بتطبيق القرار الوزاري رقم (6) لعام 1987 والقرار المعدل له رقم (282) لعام 2000 والخاص بمنح الأولوية في المشتريات الحكومية للمنتجات الوطنية وذات المنشأ الوطني .
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه شريطة سريان تراخيص الشركة وعقد الوكالة .
- في حال تغير بلد المنشأ يعتبر هذا الاعتماد لاغياً .


ا وكيل وزارة الأشغال العامة

م. عواطف سليمان الغنيم

الموكول المسماح به

لشئون المركز الحكومي للفحوصات

وضبط الجودة والأبحاث





١٦٢ / ١٨
٢١١ / ٧١٢٥

شهادة اعتماد

AWAZEL DS40200

اسم الشركة / المصنع:

شركة عوازل الكويت لمواد البناء
العنوان

ص.ب: 42137 الشويخ - الرمز البريدي: 70652

تاريخ الإصدار

تاريخ الانتهاء

2013 / 7 / 6

2011 / 7 / 7

وصف المواد المعتمدة:

- AWAZEL DESERT SHIELD 40200, " 4 mm thick, APP Modified Bituminous Membrane, reinforced with non woven polyster mat, Type II, Grade S ", produced by AWAZEL company - Saudi Arabia .

ملاحظات

- ضرورة الالتزام بالمواصفات العامة للوزارة والمواصفات الخاصة لكل مشروع على حده والمتعلقة بهذا المنتج.
- يتم التقدم بهذا المنتج من خلال المقاولين المعتمدين للمشروع التابعة لوزارة الأشغال العامة التي يطلب منها استخدام هذا المنتج شريطة أن يطابق المواصفات العامة لوزارة الأشغال العامة والمواصفات الخاصة بالعقد.
- هذا الاعتماد لا يعني هذا المنتج من إجراء الفحوصات اللازمة عند التوريد لأي مشروع.
- تلتزم وزارة الأشغال العامة بتطبيق القرار الوزاري رقم (6) لعام 1987 والقرار الإداري المعدل له رقم (282) لعام 2000 والخاص بمنح الأولوية في المشتريات الحكومية للمنتجات الوطنية وذات المنشأ الوطني.
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه شريطة سريان تراخيص الشركة وعقد الوكالة، ويراعى التجديد في حينه.

أوكيل وزارة الأشغال العامة

م. عواطف سليمان الغنيم
الوكيل المساعد
لشؤون المركز الحكومي للفحوصات
وضبط الجودة والأبحاث





شهادة اعتماد

عازل الرطوبة

اسم الشركة / المصنع :

شركة عوازل الكويت لمواد البناء .

العنوان : ت : ٢٥٧١٢٢٢٣ _ فاكس : ٢٥٧٤٩٢٢٨

ص.ب : ٤٢١٣٧ الشويخ : ٧٠٦٥٢ الكويت

تاريخ الانتهاء

2011/5/9

تاريخ الإصدار

2009/5/10

وصف المواد المعتمدة :

Polymer modified bituminous membrane type Awazel Desert shield (40200) 4mm thick Heavy Duty Grade II .

ملاحظات :

- يتم التقدم بهذا المنتج من خلال المقاولين المعتمدين لمشاريع وزارة الأشغال العامة التي يطلب منها استخدام هذا المنتج شريطة أن يطابق هذا المنتج المواصفات العامة لوزارة الأشغال و المواصفات الخاصة لأي عقد من عقود وزارة الأشغال العامة كل على حده.
- هذا الاعتماد لا يعفي هذا المنتج من إجراء الفحوصات اللازمة عند التوريد لأي عقد من عقود وزارة الأشغال .
- ضرورة تقديم شهادة ضمان و نتائج فحوصات من مختبر معترف به مع كل شحنة يتم توريدها الى داخل دولة الكويت .
- تلتزم وزارة الأشغال العامة بتطبيق القرار الوزاري رقم (6) لعام 1987 والقرار الإداري المعدل له رقم (282) لعام 2000 والخاص بمنح الأولوية في المشتريات الحكومية للمنتجات الوطنية وذات المنشأ الوطني.
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه ويراعى التجديد في حينه.

اوكيل وزارة الأشغال العامة

م. عواطف الغنيم

الوكيل المساعد

لشؤون المركز الحكومي للفحوصات

وضبط الجودة والأبحاث





شهادة اعتماد

عازل رطوبة

اسم الشركة / المصنع :

شركة عازل الكويت .

العنوان : ت : 4826677 - فاكس : 4826801

لشويخ الصناعية - شارع الزينة - الكويت

تاريخ الإصدار

تاريخ الانتهاء

2008/5/21

2006/5/22

وصف المواد المعتمدة :

Polymer modified bituminous membranes Type DS-40200 4 mm thick Heavy duty Grade II .

ملاحظات :

- يتم التكميم بهذا المنتج (DS-40200) من خلال المقاولين المعتمدين لمشروع وزارة الأشغال العامة التي يتطلب فيها استخدام هذه المنتج شريطة أن تطابق هذه المنتجات المواصفات العامة لوزارة الأشغال العامة والمواصفات الخاصة بالعقد الذي يرغب في استخدام هذه المنتج .
- هذا الاعتماد لا يعفي هذا المنتج من إجراء الفحوصات اللازمة عند التوريد لأي عقد من عقود وزارة الأشغال العامة .
- ضرورة تقديم شهادة ضمان وتنتج فحوصات من مختبر معترف به مع كل شحنة يتم توريدها إلى داخل دولة الكويت .
- تلتزم وزارة الأشغال العامة بتطبيق القرار الوزاري رقم (6) لعام 1987 والقرار الإداري المعدل له رقم (282) لعام 2000 والخاص بمنح الأولوية في المشتريات الحكومية للمنتجات الوطنية وذات المنشأ الوطني .
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه ويراعى التجديد في حينه .

وكيل وزارة الأشغال العامة

المهندس / د. الوفاء الغنيمة



Ref. :

الإشارة: ١٨ - ١٥١ - ٧١ - ٢

Date:

التاريخ:

٢٨ مايو ٢٠٠٦

المحترمين

السادة / شركة عوازل الكويت

فلكس : 4826801

ت : 4826677

الشويخ الصناعية - شارع الزينة - الكويت


تحية طيبة وبعد ،،،،،

الموضوع : " اعتماد عازل الرطوبة

" (DS - 40200)

إشارة إلى كتابكم بدون رقم والمؤرخ في 2006/4/19 ، الخاص بالمنتج عازل الرطوبة (DS-40200) ، من إنتاج شركة صناعات العزل العربية السعودية (عوازل) والوكيل المحلي شركة عوازل الكويت ، نرفق لكم طيه شهادة الاعتماد الخاصة بكم والتي تحمل رقم (00274) .

وتفضلوا بقبول فائق الاحترام ،،،،،


أ وكيل وزارة الأشغال العامة



المنظمة الأشغال العامة




Ministry of Public Works - Roads Administration, Motorway and Bridges Department
 Contract RA/106 - Completion of First Ring Road - Jahra Gate Roundabout (Package 1)

Contract RA/106 R.E. OFFICE
RECEIVED
Date: 1 Nov 08
Ref: PB-MAS 309 R1

Mat. Ref. **MATERIAL APPROVAL SUBMITTAL**

Submitted by: AKTOR / COPRI JV
 To : RESIDENT ENGINEER PBI


10:00

Transmittal No. :MAS. 309 Rev. 01		Date: 09/11/2008	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Distribution</th> </tr> <tr> <th></th> <th>Act Info</th> </tr> </thead> <tbody> <tr> <td>RE</td> <td></td> </tr> <tr> <td>DRE</td> <td></td> </tr> <tr> <td>Hwy</td> <td></td> </tr> <tr> <td>Utilities</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> </tr> <tr> <td>Electric</td> <td></td> </tr> <tr> <td>Geotech</td> <td></td> </tr> <tr> <td>Material</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> </tr> <tr> <td>Struct.</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> </tr> <tr> <td>Office</td> <td></td> </tr> <tr> <td>OS</td> <td></td> </tr> <tr> <td>Survey</td> <td></td> </tr> <tr> <td>Issue</td> <td></td> </tr> <tr> <td>File No.</td> <td></td> </tr> </tbody> </table>	Distribution			Act Info	RE		DRE		Hwy		Utilities	<input checked="" type="checkbox"/>	Electric		Geotech		Material	<input checked="" type="checkbox"/>	Struct.	<input checked="" type="checkbox"/>	Office		OS		Survey		Issue		File No.	
Distribution																																	
	Act Info																																
RE																																	
DRE																																	
Hwy																																	
Utilities	<input checked="" type="checkbox"/>																																
Electric																																	
Geotech																																	
Material	<input checked="" type="checkbox"/>																																
Struct.	<input checked="" type="checkbox"/>																																
Office																																	
OS																																	
Survey																																	
Issue																																	
File No.																																	
Prev. Transmittal No. : 309		Cont. Dwg. Ref. :																															
Material Description:	1. Awazel Primer - D41 2. Awazel Desert Shield 40200-4mm Thick App Modified Bituminous Membrane to be Applied by Torch Bonding Method.																																
Manufacturer: AWAZEL Local agent : Awazel Kuwait Co		Country of Origin: Saudi Arabia																															
WE CONFIRM THAT THIS MATERIAL IS SUBMITTED IN ACCORDANCE WITH THE 'PRIORITY OF NATIONAL PRODUCTS' REQUIREMENTS OF ARTICLE 75 OF THE PARTICULAR CONDITIONS APPLICABLE TO THIS CONTRACT																																	
BOQ Reference: Dwg.SD-U-W-1, 2, 3, 4 Rev. 2 Approved by Parsons on 2/6/2008 and by M.E.W. on 31/3/2008		Spec. Reference: Dwg.SD-U-W-1, 2, 3, 4 Rev. 2 Approved by Parsons on 2/6/2008 and by M.E.W. on 31/3/2008																															
Test Report Ref. :		Enclosure: Attachment with M.A.S. 209 Rev.0																															
Signature : 		Position : For AKTOR/COPRI JV																															
Received by RE:																																	
Reviewed by the Resident Engineer's Office: Parsons Brinckerhoff International in association with Gulf Consult																																	
Status :	<input checked="" type="checkbox"/> Approved (A) <input type="checkbox"/> Approved As Noted (B) <input type="checkbox"/> Resubmitt (R) <input type="checkbox"/> Approval Not Required(N) <input type="checkbox"/> Rejected (State Reasons)(C)																																
Notes:																																	
Signed : RE/DRE 		Date: 16/11/2008																															
Received :  For AKTOR/COPRIJV		Date: 16/11/08																															

Copies : Project Engineer, File, Others _____



MINISTRY OF PUBLIC WORKS
NATIONAL ASSEMBLY BUILDINGS AND
THE INFORMATION CENTRE



CONTRACT NO : SPA/116
CONSULTANT : HOK Int. Ltd/Sief Eng.
CONTRACTOR : KUWAIT DYNAMICS CO. Ltd

SAMPLE TAG

TRNS NO : CivM-004	Rev: 0
SAMPLE NO: 001	Rev: 0
DATE:	30/11/2008

SAMPLE DESCRIPTION

Modified Bituminous membrane 4mm thick, 20x8cms 3 Samples

SPECIFICATION /BOQ REFERENCE

III-2/07110
cl. 2.1.

Material Engineer : *Ragab Sayed*

Project Manager *[Signature]*

Date : 1/12/08

Received by Consultant :

Signature : *[Signature]*

Date: 1/12/08

Consultant's Comments :

Approved

- | | |
|---|---|
| <input checked="" type="checkbox"/> A- Approved | <input type="checkbox"/> B- Approved as noted |
| <input type="checkbox"/> C- Not Approved | <input type="checkbox"/> D- For Information |
| <input type="checkbox"/> N- Not Reviewed | |

Resident Engineer *[Signature]*

DISTRIBUTION

- MPW PE RE CONTRACTOR



MINISTRY OF PUBLIC WORKS
NATIONAL ASSEMBLY BUILDINGS AND
THE INFORMATION CENTRE

HOK INTERNATIONAL LIMITED



السيف للإستشارات الهندسية
sief engineering consultants
PROFESSIONAL ENGINEERS / PLANNING / CONSTRUCTION MANAGEMENT

CONTRACT NO : SPA/116
CONSULTANT : HOK Int. Ltd/Sief Eng.
CONTRACTOR : KUWAIT DYNAMICS CO. Ltd

SITE TRANSMITTAL (MATERIALS)

TRNS No: CivM-004 Rev: 0
DIV/SEC : Div-7
Date : 30/11/2008

Consultant : Resident Engineer HoK/Sief

WE REQUEST APPROVAL OF THE FOLLOWING MATERIAL, GOODS/PRODUCTS /EQUIPMENT:

NO.	Dwg Spec or BOQ Ref	Item description	Submittal Code	Action Code	Returned by DD/MM/YY
	III-2/07110 <i>cl. 2.1</i>	1- Modified Bituminous Membrane, 4mm thick type DS40200	1	A	
		2- Awazal Primer D41	1		

Details of information . Literature , catalogue cuts and the like attached are :

Tests and Technical Data (M.D.) 3 Copies

SAMPLES

Enclose Submitted under separate cover Not applicable

Received	KDI
Issued	23-12-2008
Distr.	Action
H.O.	
P.M.	
P.E.	<input checked="" type="checkbox"/>
T.M.	<input checked="" type="checkbox"/>
Plan. E.	<input checked="" type="checkbox"/>
Coord. E.	<input checked="" type="checkbox"/>
Q.C.E.	<input checked="" type="checkbox"/>
Q.S.	
Arch. E.	
<i>M/S B & R Co. For N.B.</i>	
<i>Trans (2) F.C.</i>	
<i>23/12/08</i>	

N.B. We certify that above items have been reviewed in detail and are correct and in performance with the contract Documents unless noted below

Contractor's Rep.: *[Signature]*
6/11/2008

Received by Consultant: *[Signature]*

CC:MPW Project Engineer


Consultant's Remarks:

Approved, A"

Resident Engineer Signature: *[Signature]*
22/12/08

MPW.PE Signature: _____

Received by Contractor: *[Signature]*
23-12-2008



SUBMITTAL CODE: DEC 2008

ACTION CODE

- 1. Submitted for Approval
- 2. Submitted for information

A. Approved
 B. Approved as Noted

C. Not Approved

NOTE :A Separate Transmittal should be made for each material

DISTRIBUTION MPW PE RE CONTRACTOR

تعليمات مهندس الموقع رقم (244)

(وهي خاصة بتطبيق المواصفات وشروط العقد ولا يترتب عليها أية التزامات من قبل الوزارة)

رقم العقد : هـ م / 214 / 1
أسم المشروع: إنشاء وإنجاز وصيانته مدرسة ثانوية بنات في منطقة أبو حليفة ق (53)
أسم المتعهد : شركة الجواد للتجارة والمقاولات

الوقت: 12:00 ظهرا

التاريخ : 2010/6/22

السيد / مدير المشروع المحترم (مندوب المتعهد أو مهندس الموقع أومثله)

الموضوع: اعتماد مواد (WATER PROOFING)

بالإشارة إلي الموضوع أعلاه ، والى النموذج المقدم لاعتماد المواد رقم (100)
بتاريخ 2010/6/6 ، نعلمكم لآمانع لدينا من اعتماد المادة المذكوره AWAZEL
DS 40200 شريطه ما يلي :
1- نجاح الفحص المعمللي .
2- تقديم كفالة للعازل لمدة عشر سنوات حسب العقد .

المرفقات: عدد (1) نموذج اعتماد مواد

وتفضلوا بقبول فائق الاحترام

التاريخ : 2010/6/22
توقيع مهندس الموقع :

استلمت بتاريخ : 2010/6/22
توقيع مهندس المتعهد :

ملاحظة :

- يحدد المهندس مكان ونوع وأسباب رفض أو طلب إصلاح أو تعليمات أخرى بالنسبة للأعمال .
- يعطى المهندس بنود لكل نوع مختلف من الأعمال .
- يحدد المهندس الفترة اللازمة لإنهاء الأعمال المذكورة .
- يقدم مهندس الموقع تقريرا نصف شهري على نموذج رقم (ن م / 8 / 70) للإجراءات المتخذة بشأن هذه التعليمات .



STATE OF KUWAIT
 MINISTRY OF PUBLIC WORKS
 ROAD ENGINEERING SECTOR

PROJECT CONSULTANT'S:



CONTRACTOR



COMBINED GROUP CONTRACTING CO.
 (K. S. C. C.)
 TEL-22254545 FAX-24344610
 P.O. BOX 4819 SAFAT - 13048 KUWAIT

MATERIAL APPROVAL TRANSMITTAL

TRANSMITTAL SERIAL NO.: RAJ 184 -M.S. 0024

REVISION NO.: 0

REF. LETTER NO.: XXXX

DWG. REFERENCE: XXXX

DESCRIPTION OF MATERIAL

WATER PROOFING MEMBRANCE DS 40200

MANUFACTURER

AWAZEL KSA
 Local agent : KHAGA SPECIALITIES Co. Kuwait

COUNTRY OF ORIGIN

K. S. A

MPW Gen. Spec. 2004.Clause. 516 . 04.1

ENCLOSURE

- 2 Copies of Catalogue- previous approval From other projects, Samples

TEST REPORT FROM MPW LAB & UNIVERSITY

CONTRACTOR

SUBMITTED BY: Engr. Abdul-khaliq ahmad kamal (PM)

DATE: 13 / 11 / 2010

TIME :

SIGNATURE: *[Signature]*

RECEIVED BY:

DATE: / / 20

TIME: 13 NOV 2010

SIGNATURE: *[Signature]*

RECEIVED

(E) Accepted as Noted
 subject to full compliance with the specifications / manufacturer's instruction and following comments

- ACCEPTED
- ACCEPTED AS NOTED
- ACCEPTED AS NOTED/RESUBMIT
- REVISE AND RESUBMIT
- INCOMPLETE/RESUBMIT
- APPROVAL NOT REQUIRED

CONSULTANT

RE / Deputy RE: *[Signature]*

DATE: 13 / 12 / 2010

TIME :

SIGNATURE: *[Signature]*

CONTRACTOR

RECEIVED: *[Signature]*

DATE: 5 / 12 / 2010

TIME :

SIGNATURE: *[Signature]*

MINISTRY OF PUBLIC WORKS
SPECIAL PROJECTS ADMINISTRATION



W.P.
memorandum

MULTISTORY CAR PARKS@ MOH HOSPITALS and BRIDGES CONNECTING AL- SABAH HOSPITAL BUILDINGS

CONTRACT NO. : SPA/149MULTISTORY CAR PARKS@ MOH
HOSPITALS and BRIDGES CONNECTING
AL- SABAH HOSPITAL BUILDINGS

CONSULTANT : MINISTRY OF PUBLIC WORKS
CONTRACTOR : The Kuwait Company For Process Plant(KCPC)

SITE TRANSMITTAL
(MATERIALS)

TRNS No.: AR-09/ 42 Rev. : 0
DIV. : 07 Sec.'07130
DATE : 2/7/2009

WE REQUEST APPROVAL OF THE FOLLOWING MATERIAL/GOODS/PRODUCTS/EQUIPMENT :

Item No.	Dwg Spec or BOQ Ref	Item description	Submittal Code	Action Code	Returned by DDMM/YY
1	07130	Waterproofing Membran Shield Ds - 40200 Thick 4.0 mm. Manufacturer: Awazel Saudi Arabia Attachments: Manufacturing data & sample and previous approvals .	1	(B)	14/07/2009

Details of information, literature, catalogue cuts and the like attached are :


catalogue

SAMPLES

Enclose Submitted under separate cover Not applicable

N.B. We certify that above items have been reviewed in detail and are correct and in strict performance with the contract. Documents unless noted below

Contractor's Rep. :




Received by MPW Project Engineer : _____

Consultant's Remarks :

Approved as noted (B)

- Method statement for water proofing system to be submitted
- Manufacturer Recommendations to be followed
- waterproofing system to be performed by the approved applicator.
- Tests & warranty to be applied as Contract documents

MPW . PE Signature :



SUBMITTAL CODE :

- Submitted for Approval
- Submitted for information

ACTION CODE

- Approved
- Approved as Noted

Team leader Eng.

NOTE : A Separate Transmittal should be made for each material.

Project : JAHRA ROAD - Construction, Completion and Maintenance of Roads, Overpasses, Sewage, Storm Water Drainage and other Services. Contract - RA / 166



TRANSMISSION OF DOCUMENTS, SAMPLES ETC

TO : LBG / PAGE

Transmittal No. RA166/OT/ 1411

WE ARE SENDING HERE WITH/UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW. (DELETE AS NECESSARY)

Date : 19/04/2011 Rev. 0

ACTION :

Approved

A

Rejected D

Approved As Noted

B

Revised and Resubmit

C

SUBMITTED FOR

APPROVAL


1

YOUR INFORMATION

2

QTY	REF	ITEM NO	DESCRIPTION	TYPE	CODE	
					Submittal	Action
5	2011/RA166/AC/PO/OT/SM/MD/CT/ 25	1	Water Proofing Membrane (4 mm Awazel Desert Shield 40200)	OT	1	B

Jahra Road Project
RA 166
The Arab Contractors
Osman Ahmed Osman
To the Engineer &
Consultant
used Date: 19-4-11



Submitted by Contractor :- *Abby*
Signature & Date :-

Received By LBG /PAGE :-
Signature & Date

REMARKS

- * subject to materials compliance with specifications
- * Full adherence to the manufacturer's recommendations
- * Detailed method statement is to be submitted
- * installation involved personnel are to be experienced
- * To be used as shown in the drawings
- * Specify the location where this product is used

Correction and comments made relative to submittals during this review do not the Contractor from the compliance with the requirements of drawings and specifications. This check is only for review of general conformance with this design concept of the project and general quantities and dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Consultant
Project Director
Signature & Date

28/4/11

SC-SUBCONTRACTOR
RP- REPORT
SM - Sample
GT - Guarantess

SUBMITTER RECEIVED
MI - Manufacturer's Data
CT - Certificates
Re: 28 APR 2011
OT -
Jahra Road Project (RA166)


Received by Arab Contractor

Date / Time : _____



وزارة الأشغال العامة

Ministry of Public Works



Ref :

الإشارة : ٥٣٢٦ - ١٥١ - ٥ / ٢٠

Date :

٤ نوفمبر ٢٠١١

المحترمين

السادة / شركة الدار للهندسة والإنشاءات
ص.ب 2518 الصفاة - الرمز البريدي 3026 الكويت

تحية طيبة وبعد ،،،

الموضوع : العقد رقم ه.م.أ / 255

استكمال تصميم وإنشاء وإنجاز وصيانة

المركز الحكومي للفحوصات وضبط الجودة والأبحاث (تصميم - تنفيذ)

(اعتماد مقاول باطن لتوريد مواد عازل الرطوبة)



بالإشارة إلى الموضوع أعلاه ، وإلى كتابكم رقم 125/ص/2011 بتاريخ 2011/10/30. نحيطكم
علماً بأنه لا مانع لدينا من اعتماد السادة / شركة عوازل الكويت لمواد البناء كمقاول باطن لتوريد مواد عازل
الرطوبة ذات المنشأ الوطني (سعودي) في المشروع أعلاه شريطة الإلتزام بالمواصفات الفنية والشروط
التعاقدية.

هذا للعلم وعمل ما يلزم بهذا الخصوص.

وتفضلوا بقبول فائق الاحترام ،،،

الوكيل المساعد لشئون المشاريع الإنشائية

المهندس /
مسير /
مصلحة المشاريع الإنشائية



ص.ب : 8 الصفاة - 13001 الكويت - هاتف : 25385520 - فاكس : 25395532 - برقا : الأشغال - الكويت
P. O Box : 8 Safat - 13001 Kuwait - Tel : 2 5385520 - Fax : 25395532 - Cable : Works - Kuwait
www.mpw.gov.kw

cc.TL



وزارة الأشغال العامة

Ministry of Public Works



FILE

2011/9/12

REF :

الإشارة : ٢٠١١ - ١٥١ - ٥/٤

DATE :

التاريخ :

١٨ سبتمبر ٢٠١١

المحترمين

السادة / شركة الإنشاءات المتحدة (اسكو)

P.O. Box 1099 SAFAT- 13011 Kuwait Tel : 22422460 - Fax: 22404584

تحية طيبة وبعد ،،،

الموضوع/ العقد رقم هـ. م. خ / 35 .

إنشاء و إنجاز و صيانة مبنى المقر الرئيسي للهيئة العامة لشئون القصر


المبنى الرئيسي ومواقف السيارات

أعمال العازل المائي - استبدال منتج

بالإشارة إلى الموضوع أعلاه ، وإلى كتبكم أرقام ASCO/MPW/PAMA/054/2011 بتاريخ 2011/9/6 و ASCO/PACE/PAMA/059/2011 بتاريخ 2011/9/12 ، يرجى العلم باعتمادنا للمنتج المكافئ (عازل DS 40200) المصنع من قبل شركة صناعات العزل العربية شرط الالتزام بالآتي :-
1- اجتياز جميع الفحوصات المطلوبة وتقديم شهادات الضمان وفقاً للمواصفات الفنية للعقد .
2- تقديم المخططات الفنية وطريقة التنفيذ للدراسة والاعتماد قبل البدء بالتنفيذ .


وتفضلوا بقبول فائق الاحترام ،،،

الوكيل المساعد لقطاع المشاريع الإنشائية

المهندس / 
مدير إدارة التقييم
هندسة المشاريع الخاصة


المرفقات : كالمذكور أعلاه




٢٠١١

PAN ARAB CONSULTING ENGINEERS

HQ BUILDING FOR PUBLIC AUTHORITY FOR MINORS AFFAIRS (PAMA)



TRANSMITTAL		Transmittal No. : PAMA/043	
		Date : 06/9/2011	
To: Ministry of Public Works (MPW) Special Projects Administration Attn. : Eng. Eman Al Sharifi Project Engineer	TRANSMITTED FOR YOUR	CODE	
	ACTION		1
	INFORMATION		2
	REVIEW & COMMENTS		3
	USE AS REQUESTED		4
	USE & RETURN		5

We are sending herewith the following:


QTY	REF. NUMBER	DESCRIPTION	* TYPE	CODE
2	ASCO/MPW/PAMA/54/2011	Contractor's request for approval for waterproofing membrane (alternative material)	OT	1

* TYPE: DG - Drawings SM - Sample MN - Minutes
 SP - Specifications MD - Manufacturer's Data OT - Other

REMARKS:

Contractor proposed material "Awazel Desert Shield 40200" - manufactured by M/s Arabian Waterproofing Ind. Co.-KSA is technically accepted subject to:

1. Conduct testing of material as per Contract Specifications.
2. Submit method statement and shop drawings for review and approval.
3. Submit cost comparison with specified product.
4. All Guarantees/Warranties shall be submitted in full compliance with Contract Documents.

Copies to: _____ (with enclosures)	 R.E.'s Signature
------------------------------------	--

RECEIVED BY: _____ Date _____
 Addressee's Signature

Addressee: Please sign, date and return this transmittal form to PACE

P.O. Box 1031, 13011 Safat Kuwait - Tel. (965) 22669600, Email: pace@ncc.moc.kw

MINISTRY OF PUBLIC WORKS

KUWAIT NATIONAL LIBRARY

CONTRACT No. : SPA -115

SITE TRANSMITTAL (MATERIAL)

TAEP - KNL SITE OFFICE	
RECEIVED	
Date & Time	8/2/06 2:45 PM
Reference	69
Received By	<i>[Signature]</i>

TRANSMITTAL NO. : M-3 MAT.

REV. 1

Contractor : AL - HANI CONSTRUCTION & TRADING Co.

DATE : 08 February 2006

To : MINISTRY OF PUBLIC WORKS, P.E. ;

WE REQUEST THE APPROVAL OF THE FOLLOWING ENCLOSED MATERIAL

Item No.	Qty	SPEC. / B.Q.	Item Description	Submittal Code :	Action Code :
1	5	Spec. 07130	Sheet Membrane Waterproofing (Equivalent Type: Saudi Awazel DS40200)	1	B
2	5	Spec. 07130	Protection Board on Vertical Applications	1	B
3	5	Spec. 07130	Bituminous Primer D 41	1	B

Details of information, literature, catalogue cuts and the like attached are :

1. Catalogues and Approvals
2. WP Membrane Comparison Sheet
3. Copy of Art. 75 from the Contract Particular Conditions

Sample Enclosed Manufacturers Data Others:

N.B. We certify that above items are in strict compliance with contract documents unless mentioned otherwise.

CONTRACTOR'S REP: *[Signature]*

DATE: 8/2/06

RECEIVED BY MPW: _____

DATE: _____

MPW / Consultant's Remarks :

*Approved As Noted: Comply with Manufacturers Instructions
 Comply with Clauses 1.06 & 3.03 of Section 07130
 of Document M-2.
 Submit Guarantee of not less than 10 years.
 Apply 2 layer as per B.O.Q. on blinding bed*

Resident Engineer: *[Signature]*
21-02-06

Received by Contractor: _____

MPW / P.E.: _____

DATE: _____

SUBMITTAL CODE : 1. Submitted for Approval 2. Submitted for Information	ACTION CODE A. Approved B. Approved as Noted C. Not Approved D. For Information
--	--



SUBMITTAL FORM

CLIENT : MINISTRY OF PUBLIC WORKS, ROAD ADMINISTRATION DEPARTMENT , STATE OF KUWAIT	Submittal No : RA - 189-MT- 0012	
CONSULTANT : URS/Scott Wilson with DMSEC	Date : 11 October 2011	
CONTRACTOR : FIRST KUWAITI TRADING & CONTRACTING COMPANY	Revision : 0	
CONTRACT NO : RA/189	Submitted For	code*
PROJECT : Construction, Completion And Maintenance of Interchanges on Main Highway - 6th Ring Road Connecting to New Housing Area at West of Jaleeb Al Shuyoukh Area.	Approval	1
	Information	2
	others	3
	Bill: D	Page: 8

SUBJECT : MATERIAL FOR APPROVAL

To : Resident Engineer,
URS/Scott Wilsons with DMSEC

Action	code*
Approved	A
Approved As Noted	B
Not Approved	C
Resubmit	D
For Information	E

We are sending herewith the item listed below for your action please :

Item No.	Ref.sec'n & Clause	No. of copies	item Description / Vender / Supplier	Type***	code	
					Submittal*	Action**
1	D.3.E	3	Awazel DS 40200	MT	1	B
	D.5.d		App modified bituminous			
			Water proofing membrane			
			Manufacturer:			
			AWAZEL KSA			
			Local Agent:			
			Awazel Kuwait Co. LTD			
			Enclosed:			
			- Technical data sheet - Previous Approvals			

CONTRACT RA/189
Scott Wilson - DMSEC
R. E. Office
RECEIVED
Date 11/10/2011
11:43 PM

Project Manager
E. Abbas El-Banna

(Signature)
SIGNATURE

Copies	Submitted by	Received by
To	FIRST KUWAITI TRADING & CONTRACTING COMPANY.	

Notes :

* للمراجع من تصحيح المادة للاختبار والعدد 189 رقم

* عمل الاختبار والارزاق للمادة بـ 2011/10/11

نائب مدير
المشروع / محمد السيد عثمان
2011
10/13

* Codes to be entered by contractor (MT-003 Rev-0)

** Codes to be entered by Engineer / Consultant

*** Submittal Type
MT - Material, SD - Shop Drawing, SM - Sample, GT - Guarantee, TC Test Certificate, MDS Material Delivered to Site, MS - Method Statement, DC - Design Calculation / Notes
Sk - Sketches, MD - Manufacture's date CT - Certificates, TR - Test Reports OT - Others.



copy MW/HS

ALGHAMM SPECIALITIES CO. 07/23/2010					
GM	AGM	CNS	CTR	CD	A/C

ملحق رقم (1) للاطلاع رقم المرسوم 95/177 - 96 لاجل الخدمات الاستشارية
 بالمركز التقنية (الإدارة) على التحضير والتجهيزات الاستشارية لفرع كلية الشرطة الجديدة
 Agreement No. A/887/1795-96 - Consultancy Services for
 New Police College. No provision and typical Services of Police College
 Contractor: Kuwait Arab Contractors

**MINISTRY OF PUBLIC WORKS
 KUWAIT POLICE COLLEGE**

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

CONTRACTOR: **KUWAIT ARAB CONTRACTOR** CONTRACT #: **S.P.A 99**

TO: **RESIDENT ENGINEER - SOM / GULF CONSULT**

WE ARE SENDING HEREWITH THE FOLLOWING DOCUMENTS THAT COMPLY WITH THE CONTRACT DOCUMENTS

QTY	DRWS., SPEC. OR BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	*TYPE	CODE	
					Submitter	Action
	Doc-II-2	2.01	Membrane Water Proofing	MD,SM	1	B
	Div-7		Awaze I desert shield 40200	OT,CT		
	Sec.7130 & 7500		app modified blumen water proofing membrane (4mm Thick)			
	Part-2		with non- woven polyester Reinforcement			
			Manufacturer:- Arabian Water Proofing Ind. Co. (Awazel) KSA			
			Local Agent:- AWAZEL Kuwait Co.			
			to be used for roofing & foundations.			

COPIES TO: 15 FEB 2010

FOR CONTRACTOR - PROJECT MANAGER

Resident Engineer to enter Action Codes and Remarks, and return to the contractor

REMARKS:

See attached comments

Kuwait ARAB CONTRACTORS
 Project : K.P.C
 RECEIVED IN
 DATE - 06.03.10
 TIME : 11:25 AM
 NAME :
 SIGNATURE :

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the contract documents. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all dimensions, selecting fabrication processes and techniques of construction, co-ordinating his work with that of other trades, and performing the work in a safe and satisfactory manner.

COPIES TO: *M. Al-Jarrah* 6 MAR 2010

RE: SOM / Gulf Consult For Resident Engineer DATE:

*TYPE: SD - Shop drawings MD - Manufacturer's Data
 SM - Sample CT - Certificates
 ET - Excavation OT - Other

FROM :

Transmittal No.KPC-MT/ST/153

Rev.0

Dated 15th February, 2010

COMMENTS

- (1) Subject to full compliance with the Specifications/manufacturer's instruction and following comments.
- (2) Refer clause 2.01 item c and confirm that properties of the membrane fulfill the requirements/latest tests as per the specified standards.
- (3) Subject to the submission and compliance with the 10 years guarantee as specified.
- (4) Single source/associated compatible accessories to be as per clause 2.02/07130.
- (5) Approved adhesive to be applied as per clause 3.04.
- (6) Material to be tested in approved laboratory after deliver on site to comply the Specification Section 07130 clause 2.01C.
- (7) DS40200 is accepted and final approval subject to the test results (under item no.6).

المعامل الرئيسي: مؤسسة البنية التحتية العامة والتجارة والمقاولات
 مقاول العزل: روى محمد عبد المحسن الغرور بتاريخ العينة
 رقم الإشتداد: C-35
 مع فحص بدون فحص

المواصفات الخاصة
 1) Thickness = 4mm
 2) Unite weight = 4-kg/m²
 # Tensil strength N/Scm
 3) Longitudinal = 1000
 4) Transversal = 800
 # Catalogue is attached.
 # Previous appraisals attached.

المواصفات العامة حسب الكاتالوج المقدم
 2007/01/30 التاريخ
 المواصفات العينة

1- Sample Size 8x15cm
 4mm-thick
 DS 40200

التاريخ
 التاريخ
 اعتماد نهائي (مستور الأمانة)

التاريخ
 التاريخ
 التاريخ

التاريخ
 التاريخ
 التاريخ
 التاريخ

التاريخ
 التاريخ
 التاريخ
 التاريخ

نسخة لجنة المواد
 مرفق بها الكاتالوج والعينة
 نسخة الجاهز والموافق
 302 Page

التاريخ: ٢٠٠٩/١٢/٢١

رقم العقد: هم ٥٢/١

هندسة المشاريع الإنشائية

اسم العقد: إنشاء وإنجاز وصيانة مركز ضاحية مبارك الميدان

إدارة التنفيذ

المادة	المادة	مرفوض سابقا	جديد	إعادة تقديم	مرفوض سابقا
التوكيل	التوكيل	X	X		
مواصفات المادة حسب الكatalog المقدم					

رقم الاعتماد - CIV-5 مع الفحص بنون فحص

المهندس المشرف

لاداعيلع عرط لعوض

مرفق نسخة اعتمادات كتالوج المادة

4mm thick , APP modified bituminous membrane , reinforced with non woven polyester mat , 200 gm/m 2

Type DS 40200

Roll size 10 x 1 m

Normal unit weight (plain) 4 kg/m2

مهندس المتابعة: وهو المهندس الذي لا يمكنه من توقيع العقد

2٤/١٢/١٥٩ التاريخ

رئيس قسم الإشراف

لاداعيلع عرط لعوض

اعلاه

لاداعيلع عرط لعوض

المواصفات المعينة

4 mm thick (attached)

التاريخ

اعتماد نهائي (مدير الإدارة)

المهندس

لاداعيلع عرط لعوض

التاريخ

مستلام المهندس

٢٠٠٩/١٢/٢١

التاريخ

مستلام المقاول

٢٠٠٩/١٢/٢١

التاريخ

مستلام الملف

٢٠٠٩/١٢/٢١

التاريخ

مستلام لجنة المواد

٢٠٠٩/١٢/٢١

رقم بها الكatalog والمينة

التباين بين العقد والمادة المقدمة

لا يوجد

مفوض

Division 7 Thermal & Moisture protection

المواصفات العامة

الهيئة العامة للمشروعات الإنشائية
أبوظبي

رقم الطلب: 21
اسم المقدم: شركة مياه الشرب
اسم المقدم: شركة مياه الشرب

APPROVED	C NOT APPROVED
APP. AS NOTED	D. RESUBMITT
✓	water printing
رقم الإصدار: 1	رقم الإصدار: 1
رقم الإصدار: 1	رقم الإصدار: 1

المواصفات الخاصة	الرقم	التاريخ	رقم الإصدار: 1
------------------	-------	---------	----------------

SUBMITTAL
NAME OF MANUFACTURER - AWAZEL KUWAIT Co. LTD.

MATERIAL
 1. WATERPROOFING MEMBRANE - DS 40200
 2. PROTECTION BOARD - MS 80
 3. BITUMINOUS PRIMER (VAPOUR BARRIER) - FLEKKOTE
ATTACHMENTS
 1. TECHNICAL DATA SHEET (DS 40200, MS 30,40,80)
 2. SAMPLE (DS 40200, MS 60)
 3. COMPARISON SHEET BETWEEN AWAZEL DS40200 & PARALON NT4
 4. COMPARISON SHEET BETWEEN DS40200 & INDEX TESTUDO
 5. APPROVAL OF MATERIALS FROM MINISTRY OF PUBLIC WORKS FOR THE ONGOING PROJECTS.
 6. TECHNICAL DATA FOR FLEKKOTE BITUMINOUS PRIMER
 7. LETTER FOR NON-AVAILABILITY OF THE SPECIFIED PRODUCT IN LOCAL MARKET.

1. AR-805-A 5. AR-801-D 9. AR-808-S
 2. AR-806-A 6. AR-802-D 10. AR-007B-S
 3. AR-801-B 7. AR-802-E
 4. AR-801-C 8. AR-803-E

BLDG A - ITEM NO. 7.117.2
 BLDG B - ITEM NO. 7.117.2
 BLDG C - ITEM NO. 7.117.2
 BLDG D - ITEM NO. 7.117.2
 BLDG E - ITEM NO. 7.117.2

GUARD ROOM & WAITING ROOM - ITEM NO. 7.117.2
 TRANSFORMER ROOM & PUMP ROOM - ITEM NO. 7.117.2

الملاحظات
 المواصفات الخاصة

التاريخ: 15/11/2009
 التوقيع: [Signature]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]


التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]

التاريخ: [Blank]
 التوقيع: [Blank]



Handwritten signature and date: 15/11/2009



رقم العقد : 248 / م - هـ
 رقم العقد : 248 / م - هـ
 (مدني) بتاريخ: 26/12/2010 (CIV-07 - REV.01) والرقم (248 / م - هـ)

وزارة الأشغال - قسمه المشاريع الأدميه - إدارة التقية الشؤون الرئيسي مقاول الجاهل رقم الإحصاء مهتمين مواد المقاول : 3 ، بين 300 م		وزارة الأشغال - قسمه المشاريع الأدميه - إدارة التقية الشؤون الرئيسي مقاول الجاهل رقم الإحصاء مهتمين مواد المقاول : 3 ، بين 300 م	
C	NOT APPROVED	مادة مطبقة	رقم العقد : 248 / م - هـ
D	RESUBMITTED	مادة جديدة	قسم التقية : نظام الجاهل وصيف مبنى منطقة مبارك الكبير لتطبيقية
ف	تم الاستعداد للإحصاء	المساحة	ملاحظات
SECTION 07130-2.02/A, B - SHEET WATERPROOFING Waterproofing Membrane: Flame bonded membrane of specified layers, 4(+L0.2) mm thick each, composed of asphalt or bitumen modified with thermoplastic resins and reinforced with non-woven polyester fabric		مواصفات المادة حسب الكatalog المقدم Awazel Desert Shield 40200 4 mm Thick , APP Modified Bituminous Membrane. Reinforced with Non Woven Polyester mat , Complies with the Requirements of ASTM D622 , DEAc MOATAC, CGSB 37,GP-56M & DIN 52133	
المخططات : S-01 , S-07 , S-08 , S-10 , S-44 & A075 & L04 , L05 , L07			
ATTACHMENTS: Catalogue copies of previous approvals Material Safety Data Sheet Approvals Certificates Product Test Certificates 2 Sample Pieces			
جداول الكميات Sheet Waterproofing III-47-1 / 7.2,7.3,7.4,7.5,7.6,&7.8			
مواصفات العينة 2 Sample Piece Size 8 x 20 cm x 4 mm Thick			
المواصفات العامة: Division 07 Thermal Moisture Protection Page 302-304			
التاريخ : تاريخ تسليم الاثرية : التاريخ : تاريخ التسليم : 2011/12/26			
التاريخ : تاريخ التسليم : التاريخ : تاريخ التسليم :			

17/01/2011 التاريخ

(CIV-05-REV. 00)

وزج اصمك راد و قسوم

A) APPROVED	C NOT APPROVED	حالة معلقة
B APP. AS NOTED	D RESUBMITT	حالة معلقة
* WATER PROOFING MEMBRANE & PRIMER		
* AWAZEL ARABIA WATERPROOFING CO. KSA		

مواصفات المادة حسب التفويض والرقم
 مواصفات المادة حسب التفويض والرقم
 مواصفات المادة حسب التفويض والرقم
 مواصفات المادة حسب التفويض والرقم
 مواصفات المادة حسب التفويض والرقم

SECTION 07130 SHEET WATERPROOFING

* WATER PROOFING MEMBRANE DS 40200 4MM THICK

* AWAZEL PRIMER D-41

* ATTACHMENT : TESTS AND TECHNICAL DATA SHEET OF MATERIALS

وصف المشروع :-
 وصفاً عاماً للمشروع

رقم العقد : 17/01/2011

DRG. NO. (S01) : GENERAL NOTES & TYPICAL DETAILS
 DRG. NO. (S07) : FOUNDATION SECTION (SHEET NO. 1)

وصف المشروع :-
 وصفاً عاماً للمشروع

BOQ (DIVISION 7) 7.1 PAG

التاريخ	التاريخ
التاريخ	التاريخ
التاريخ	التاريخ
التاريخ	التاريخ
التاريخ	التاريخ
التاريخ	التاريخ

ATTACHMENT: COMPARISON SHEET
 WATER PROOFING MEMBRANE



موقع الوحدة الموردة
 مواصفات المادة حسب التفويض والرقم




2012/2/25 (تمت الموافقة) بطارية (MT-CV-ST-06 REV-00) رقم المادة: 2571

A. APPROVED B. NOT APPROVED		C. NOT APPROVED D. RESUBMIT	
اسم المنتج: MT-CV-ST-06 REV-00 رقم المنتج: 2571		اسم العميل: رقم العميل: تاريخ العميل:	
اسم المنتج: ARABIAN WATERPROOFING IND. CO. رقم المنتج: تاريخ المنتج:		اسم العميل: رقم العميل: تاريخ العميل:	
المواصفات الفنية: SECTION 07110 (SHEET MEMBRANE WATERPROOFING) PAGE NO.: III-2107.110/4 - PART 2.1.A. WATERPROOFING(MEMBRANE)		المواصفات الفنية: AWAZEL DESERT SHIELD 40200	
A. Waterproofing Membrane: 4(+0.2) mm thick composed of APP modified thermoplastic bitumen membrane for roof works and reinforced with 200g/m ² non woven polyester fabric.			
Physical Properties: 1. Thickness (EN 1949-1): 4mm +0.2 2. Reinforcement : 200g/m ² non-woven spunbound polyester. 3. Water-tightness (EN 1928) : 50 kpa. 4. Shear Resistance EN 12317-1 : 500/500N/50mm 5. Maximum Tensile Force : 800/700N/50mm after ageing (EN 12311-1) 6. Elongation after ageing : 50/50% After ageing (EN 12311-1) 7. Resistance to Tearing : 150/150N nail shank - EN 12310-1 8. Dimension Stability EN 11071 : 0.5/0.5% 9. UV ageing (EN 1297) : Should pass the test.			
المواصفات الفنية: ATTACHMENT : 3 NOS. ORIGINAL QUALITY SAMPLE OF DS 40200 MEMBRANES POLYMER MODIFIED, POLYESTER CARBON...			
المواصفات الفنية: 1. Tensile Strength : Require 800/700N/50MM 2. Tear Resistance : Require 150/150N 3. Elongation At Break : Require 50/50% 4. Shear Resistance : Require 500/500N/50mm 5. Dimension Stability : Require 0.5/0.5% 6. Water-tightness : Require 50 kpa.			

Approved As Noted
 See attached sheet
 2012/03/27



تمت الموافقة
 2012/2/25
 م. ع. م.



45

REF :
DATE :

الإشارة: ٤١٧ - ١٥١ - ٤١٥٥
التاريخ: ٢٠ أكتوبر ٢٠١٣

المحترمين

السادة / شركة المجموعة المشتركة للمقاولات
ص.ب: 4819 الصفاة 13049 الكويت
ت: 24344686 فاكس: 22254545

تحية طيبة وبعد ،،،


المشروع : ه ط / 212 إنشاء وإنجاز وصيانة الطرق وتقاطعات على الجزء
الأوسط من طريق الجهراء

الموضوع : اعتماد مواد

بالإشارة إلى الموضوع أعلاه ، وإلى كتاب السادة/ أورينتال كونسلتانت انترناشونال بالمشاركة مع السادة/
دار الدولية للاستشارات الهندسية رقم (OC/ADC-RA/212-136) المؤرخ في 2013/10/01 (مرفق نسخة) ،
وإلى طلبات الإحالة (MATERIAL APPROVAL TRANSMITTAL) أرقام (RA/212-MS.0033) و
(RA/212-MS.0034) و (RA/212-MS.0035) و (RA/212-MS.0036) المؤرخة في 2013/09/18 (مرفق
نسخة) ورقم (RA/212-MS.009) المؤرخ في 2013/09/28 (مرفق نسخة) بشأن اعتماد المواد التالي ذكرها
بالجدول أدناه :

م	وصف المادة	المصدر/ بلد الصنع	المورد
1	Rubberized/Liquid Bitumen Emulsion (Spec tite DP 60)	الإمارات	شركة البحر ويردويل للمواد الخصوصية
2	Polysulphide Joint sealant (Spec Seal 625)	الإمارات	شركة البحر ويردويل للمواد الخصوصية
3	Water Stops (Spec tite PVC Water stop)	الإمارات	شركة البحر ويردويل للمواد الخصوصية
4	GEOTEXTILE ALYAF A231	السعودية	شركة البحر ويردويل للمواد الخصوصية
5	Water Proofing Membrane (AWAZEL DS40200)	شركة عوازل السعودية	شركة عوازل الكويت لمواد البناء

(2/1)



REF :
DATE :

الإشارة:
التاريخ:

نحيطكم علماً بأنه لا مانع لدينا من اعتماد المواد المذكورة أعلاه شريطة الإلتزام بما يلي :

1. الإلتزام بالموصفات الفنية والمتطلبات التعاقدية .
2. إجراء الفحوصات اللازمة والدورية عند التوريد .
3. سريان صلاحية شهادات الاعتماد طوال فترة التوريد والإلتزام بالملاحظات الواردة بها .

وتفضلوا بقبول فائق الاحترام ،،،

الوكيل المساعد لقطاع الطرق

م/ احمد سليمان محمد الحصان
الوكيل المساعد لقطاع هندسة الطرق





STATE OF KUWAIT
MINISTRY OF DEFENCE
MILITARY ENGINEERING PROJECTS

دولة الكويت
وزارة الدفاع
هندسة المنشآت العسكرية

Ref. 2742014332 : الإشارة
Date : 2004/10/11 : التاريخ

المحترمين

السادة / شركة أدكو للتجارة والمقاولات

تحية طيبة وبعد ،،،

الموضوع : اعتماد منتجات شركة العوازل السعودية

بالإشارة إلى الموضوع أعلاه ، وإلى كتابكم رقم (ا/8524/2004) بتاريخ 2004/9/12 (مرفق صورة) ، وبخصوص اعتماد المنتجات المذكورة من عزل الرطوبة ولود شركة العوازل السعودية نوع :

1. لانت العزل المائي منتج عوازل DS40 ، سمك 4 ملم ، بيثومين معدل APP تصليح بوليمتر 180 جم/م² .

2. لانت العزل المائي منتج عوازل DS40200 ، سمك 4 ملم ، بيثومين معدل APP تصليح بوليمتر 200 جم/م² .

يرجى العلم بأنه وبعد قيام جهازنا الفني بمراقبة ضبط الجودة بسحب العينات من مخزون شركة أدكو للتجارة والمقاولات بمنطقة الشويخ الصناعية ، وعمل الفحوصات اللازمة بمراقبة المختبرات ، حيث تبين أن النتائج مطابقة المواصفات القياسية (مرفق النتائج) -
علما بأن هذه الموافقة لا تعفي المنتجات المذكورة أعلاه من سحب المواد وإجراء الفحوصات اللازمة مع ضرورة الإلتزام بمواصفات وشروط العقد وذلك عند إعماله بمشاريع وزارة الدفاع .

مع أطيب التمنيات ،،،


وكيل وزارة

وكيل وزارة الدفاع
هندسة المنشآت العسكرية



STATE OF KUWAIT
MINISTRY OF DEFENCE
MILITARY ENGINEERING PROJECTS

دولة الكويت
وزارة الدفاع
هندسة المنشآت العسكرية



رقم المشروع: _____ اسم المشروع: مطرفة بعمق القوة البحرية - البحراء تاريخ تقديم المبيعات: 22 / 12 / 2006
 رقم العقد: 1242804 اسم العميل: شركة الاندلس للهندسة والبناء والتجارة تاريخ اصدار المبيعات: 2006
 اسم المادة المطلوب اعتمادها WATER PROOFING MEMBRANE عدد مرات التقديم: 01 توقيع ممثل العميل: _____

الوصف	الكميات	الخطوات	جداول الكميات	وصف المبيعات القديمة	رقم
MANF: AWAZEL CO. LTD.	A-11, 12	HQ	11-4 / 7-1	AWAZEL	1
SAUDI ARABIA	A-07	OP	DIV. 7	D.S. 40200	
ATTACH: SAMPLE AND	A-11	TH			
TECHNICAL DATA.					

ملاحظات اعضاء اللجنة: معاينة

المهندس المشرف: محمد بن علي

الاسم: _____

التوقيع: _____

امضاء اللجنة

ملاحظات رئيس اللجنة: _____

مراتب المنطقة: مركز المنطقة

رئيس اللجنة: _____

مدير المنطقة: _____

التوقيع: _____

1- يحرر هذا العقد النموذج من اصل وثلاث نسخ من قبل المهندس المشرف ولا يلقى أي من النصوص العقد التعاقد بالاداء.
 2- للمهندس المحل في أي وقت من الأوقات أن يطلب من المقدم أي عينه من المواد المتكاملة حتى ولو سبق اعتمادها.
 نموذج رقم 25 - 73000

2006 / 12 / 22

ملاحظات اعضاء اللجنة: معاينة

المهندس المشرف: محمد بن علي

الاسم: _____

التوقيع: _____

امضاء اللجنة

ملاحظات رئيس اللجنة: _____

مراتب المنطقة: مركز المنطقة

رئيس اللجنة: _____

مدير المنطقة: _____

التوقيع: _____



State of Kuwait
Ministry of Awqaf and Islamic Affairs
Sector of Mosques
Department of Farwaniva

دولة الكويت
وزارة الأوقاف والشئون الإسلامية
قطاع المساجد
إدارة مساجد محافظة الفروانية

التاريخ: ١٤٢٦/١٢/٤ هـ الموافق: ٢٠٠٦/١/٤ م الرقم أ.ق.م ف.ا / ٥ / ٢٠٠٦ م

المعتمدين

السادة/ شركة غانم عبد الله العثمان

السلام عليكم ورحمة الله وبركاته...

الموضوع: عقد رقم ٦١-٥٠٥-٢٠٠٦/٢

إنشاء وإنجاز وصيانة مركز تدريب الدعاة بالرقعي

أعمال عازل السرداب

بالإشارة إلى للموضوع أعلاه، نود إحاطتكم علماً بأنه قد تم اعتماد شركة غنام والصناعات للتجارة والمقاولات لتوريد وتنفيذ أعمال العازل لسرداب المبنى وذلك بحسب ما جاء بعرض سعرهم بحيث يكون:

- ١- العزل الخارجي من طبقتين طريال نوع عوازل Ds40200 . مصدر سعودي.
 - ٢- العزل الداخلي للسرداب من مواد هايدي ذو الأساس الأسمنتي. مصدر ألماني.
 - ٣- ألواح حماية لجدران السرداب نوع عوازل Ms60 . مصدر سعودي.
- وعليه يطلب إليكم التعاقد مع الشركة المذكورة أعلاه بخصوص هذه الأعمال. مع التأكيد على التقيد بطريقة ومراحل العمل، والأسعار الواردة. في عرض السعر المرفق وذلك شريطة أن يتم التنفيذ من قبل شركة غنام والصناعات للتجارة والمقاولات. وأن تكون المواد المستخدمة منتجة حديثاً، والالتزام بتعليمات الجهة الصانعة فيما يخص طريقة العمل.
- مع حفظ حق الوزارة في إجراء أي فحوصات تراها على المواد المستعملة في أعمال العازل.

وتفضلوا بقبول فائق الاحترام،،،

مدير إدارة

مساجد محافظة الفروانية



التاريخ: 22 من جمادى الأولى 1427 هـ الموافق 18 يونيو 2006 رقمياً: ف.د.م.ح. / 2006/

السيد الفاضل / مدير إدارة الشؤون الهندسية
المعتمد

السلام عليكم ورحمة الله وبركاته...

الموضوع: عقد رقم 2004/90-2005 (مؤسسة حربية)

صالة مساجد محافظة حولي

اعتماد عازل رطوبة

Jawad AL-Saffar Est.
Specialities and W.P.

تهديكم إدارة مساجد محافظة حولي أطيب تحياتها لكم متمنية لكم دوام التوفيق
والسداد، وبالإشارة إلى الموضوع أعلاه، يرجى التكرم بالإيعاز لمن يلزم نحو دراسة اعتماد
عازل الرطوبة للمسلح بطبقة بولستر والمغلفي بالحبيبات المعدنية سمك 4 مم نوع (عوزال)
طبقاً للبند رقم (11/15) بجدول أسعار العقد المذكور.
وكذلك دراسة اعتماد عازل رطوبة أملس للمسلح بطبقة بولستر سمك 4 مم نوع (عوزال)
طبقاً للبند رقم (10/15) بجدول أسعار العقد المذكور.

وتنظروا بقبول فائق الاحترام والتقدير،،،

مدير إدارة

مساجد محافظة حولي

المهندس
محمد عبد الله
مدير إدارة مساجد محافظة حولي

استقبلت لأمير المؤمنين

موسى بن جواد السفار

البرقيات:-

2006/6/10

- 1- طبقات نظيفة
- 2- مادة اعتماد
- 3- أنواع طب اعتماد
- 4- عبة من الماء الجيد
- 5- عبة من شغل الأمان



State of Kuwait
Ministry of Awqaf and Islamic Affairs
Sector of Mosques

دولة الكويت
وزارة الأوقاف والشئون الإسلامية
قطاع المساجد
إدارة مساجد محافظة الفروانية

Department of Farwaniya

التاريخ: ١٤٢٦/١٢/٤ هـ الموافق: ٢٠٠٦/١/٤ م الرقم أقي م ف/ ٥ / ٢٠٠٦ م

المحترمين

السادة/ شركة قائم عبد الله العثمان

السلام عليكم ورحمة الله وبركاته...

الموضوع: عقد رقم ٦١-٢٠٠٥-٢٠٠٦

إنشاء وإنجاز وصيانة مركز تدريب الدعاة بالرقعي

أعمال عازل السرداب

بالإشارة إلى الموضوع أعلاه، نود إباطتكم علماً بأنه قد تم اعتماد شركة غنام والصنائع للتجارة والمقاولات لتوريد وتنفيذ أعمال العازل لسرداب المبنى وذلك بصب ما جاء بعرض سعرهم بحيث يكون:

- ١- العزل الخارجي من طبقتين طربال نوع عوازل Ds40200 . مصدر سعودي.
 - ٢- العزل الداخلي للسرداب من مواد هايدري ذو الأساس الأسمنتي. مصدر ألماني.
 - ٣- ألواح حماية لجدران السرداب نوع عوازل Ms60 . مصدر سعودي.
- وعليه يطلب إليكم التعاقد مع الشركة المذكورة أعلاه بخصوص هذه الأعمال. مع التأكيد على التنفيذ بطريقة ومرحل العمل، والأسعار الواردة. في عرض السعر المرفق وذلك شريطة أن يتم التنفيذ من قبل شركة غنام والصنائع للتجارة والمقاولات. وأن تكون المواد المستخدمة منتجة حديثاً، والالتزام بتعليمات الجهة الصانعة فيما يخص طريقة العمل.
- مع حفظ حق الوزارة في إجراء أي فحوصات تراها على المواد المستعملة في أعمال العازل.

وتفضلوا بقبول فائق الاحترام،،،

مدير إدارة

مساجد محافظة الفروانية

مدير إدارة
مساجد محافظة الفروانية



التاريخ: 22 من جمادى الأولى 1427 هـ الموافق 18 يونيو 2006 رقمها: خ.د.م.ج. / 2006/

السيد الفاضل / مدير إدارة الشؤون الهندسية
المعتمد

السلام عليكم ورحمة الله وبركاته...

الموضوع: عقد رقم 2004/90-2005 (مؤسسة حوية)

صالة مساجد محافظة حولي

اعتماد عازل رطوبة

Jawad AL-Saffar Est.
Specialities and W.P.

تهديك إدارة مساجد محافظة حولي أطيب تحياتها لكم متمنية لكم دوام التوفيق
والسداد، وبالإشارة إلى الموضوع أعلاه ، يرجى التكرم بالإيمار لمن يلزم نحو دراسة اعتماد
عازل الرطوبة المسلح بطبقة بولستر والمغلي بالحبيبات المعدنية سمك 4 مم نوع (عوزال)
طبقاً للبند رقم (11/15) بجدول أسعار العقد المذكور.
و كذلك دراسة اعتماد عازل رطوبة أملس المسلح بطبقة بولستر سمك 4 مم نوع (عوزال)
طبقاً للبند رقم (10/15) بجدول أسعار العقد المذكور .

وتنظروا بقبول فائق الاحترام والتقدير،،،

مدير إدارة

مساجد محافظة حولي

المهندس
محمد عبد المصطفى
مدير إدارة شؤون
الهندسة في محافظة حولي

استقبلت لامل المرتبات

موسى عبد الصمد

المرققت:-

٢٠٠٦/٦/٢٥

- 1- طبقات التربة
- 2- طبقات الأساس
- 3- انواع طبقات الأساس
- 4- عمق منسوب المياه
- 5- عمق منسوب المياه

International Hospital Complex
 Package No. 6 (Internal Finishing Works)
SITE TRANSMITTAL
 of Shop Drawings, Samples, etc.



PROJECT : **International Hospital Complex**
 CONTRACTOR : **cmbc**
 TO : **Gulf Consult**
 PACKAGE NO. : **6 (Vol.2)**


TRANSMITTAL NO. **IHC/BP6/MD/0035**
 REV. NO. **0**
 DATE **09.05.2009**

WE ARE SENDING HERewith DOCUMENTS/ SAMPLES LISTED BELOW.

QTY	DRW., SPEC. OR BOQ REF	ITEM NO.	DESCRIPTION	TYPE +	SUBMITTAL CODE *	ACTION CODE **
	Section 07100		Waterproofing for all the wet areas			
3	WaterProofing Membrane	1	Awazel Desert Shield 40200	MD	1	B
1	BOQ III-4/7-1, Item No. A	2	Awazel Desert Shield 40200	SM	1	A
3		3	Awazel Primer D41	MD	1	B
3		4	Al Hamara Kuwait Co. W.L.L	MD	1	B
Supplier : Al Hamara Kuwait Co. W.L.L						

PM : M/s UMS [SR. Vice President-Project Management]
 Consultant : M/s GC
 UNS / GC to enter ACTION CODE and REMARKS

CONTRACTOR :
 DATE : **09.05.2009**



Remarks :

- Approved As Noted*
- ① Arabian water proofing Ind. Co. is approved as a manufacturer for water proofing primer (D-41) and bituminous membrane (DESERT SHIELD 40200) which supply by Al Hamra Kuwait Co. W.L.L.
 - ② Submit factory backed sample for the approved primer (D-41)
 - ③ Submit separately Method statement for water proofing system Application for our review and approval and submit detailed shop drawings.
 - ④ Submit full system layers sketch for our review and approval.
 - ⑤ The above approval subject to full compliance with manufacturer instructions for Application, Material storage and subject to fully comply with contract documents.
- Initials *Kardar* Date **12/5/09**

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

For M/s (UMS / GC)

CC:

PM : M/s UMS [Sr. Vice President-Project Management]
 Consultant : M/s GC

DATE : **12-5-09**

TYPE:	SD: Shop Drawings	* SUBMITTAL CODE:	CODE	ACTION
SM:	Samples	1: Submitted for Approval	A	Approved
GT:	Guarantee	2: Submitted for your Information	B	Approved as Noted
MD:	Manufacturers data		B+R	Approved as Noted & Resubmit
CT:	Certificate		C	Not Approved
OT:	Other		D	For Information

3. Waterproofing for all the wet areas

التاريخ: 2012/11/22

اشارة: م.د.ص.م. 52/م

السادة / مجموعة هامي سلانت - مقاول المشروع المحترمين

عناية السيد: ممثل المتعهد المحترم

تحية طيبة وبعد

المشروع / إنشاء وإنجاز وصيانة مبنى المركز الصحي الجديد بالروضة ق 4

الموضوع: مواد عازلة للرطوبة (جداول مقارنه).

الاشارة الى الموضوع اعلاه. والى كتابكم رقم ه.س/ 2012/4417 تاريخ 2012/11/13.

نبلغكم بما يلي:

أولاً: لا مانع لدينا من اعتماد المادتين التاليتين:

1. مادة أغشية البيتومين المسلح بالبوليسترين من ماركة عوازل ((Awazel DS40200)) لأعمال العزل بالمشروع.

2. مادة ((Roof seal)) لأعمال دهان البيتومين.

وذلك طبقاً للشروط العاليه:

1. يتم أخذ عينات من المادتين المذكورتين أعلاه للفحص في المختبرات المعتمده لدينا لتأكيد تطابقها مع مواصفات المواد الموصوفه. وذلك قبل الإستخدام.

2. لا يتم المباشره بالإستخدام حتى تزويدنا بالكتالوجات من الشركات المنتجه لهاتين المادتين. توضح طريقه تنفيذهما. طبقاً للماده (6) من الملاحظات على أعمال الطبقات العازله للماء و الرطوبه للأسطح. الوارده في المواصفات الفنيه للمشروع ((أعمال مدنيه و معماريه)).

ثانياً: يطلب منكم تزويدنا بمستندات وعينات مادة الألمنيوم العاكس للدراسه و الإعتماد بالسرعه الكليه.

شاكرين حسن تعاونكم

وتفضلوا بقبول فائق التقدير والاحترام

دار المشاريع للاستشارات الهندسية

المهندس المقيم

م. عدنان الاحمد
11-012

المهندس المقيم
عدنان الاحمد

PI PROJECTS
HOUSE
دار المشاريع للاستشارات الهندسية

22 NOV 2012

المرسل اليهم: - المقاول: الاصل

- المالك: صورة للعلم

Hawalli - Al-Othman Street - Palaza Complex - 6th floor

Tel: 226 43 800 - Fax: 226 43 900 - P.O.Box: 133 Al-Shaab code 36062 - www.projects.com.kw



Material Submittal Form



مشروع انشاء وانجاز وصيانة مركز الفنيطيس الصحي

CONTRACTOR: Burhan intlco.

TRANSMITTAL No. : MOH2-MTS-GN-002

TO: PMI

PROJECT ID: 1010PM50-FN


ATTENTION: Engr.WALEED SELEEM

DATE: 26/7/2012

SUBMITTAL No. <u>2</u>	REVISION: <u>000</u>
SUBMITTAL TITLE : <u>Water Proofing membrane</u>	

We are sending Herewith Under separate cover The drawings/documents listed below:

Item No.	Dwgs, Specs, BOQ Ref	Description	Type	Copies	Eng. Rep Action
1	Div 7	Water proofing membrane Awazil (desert shield 40200) (data sheet & samples)	DS40200	2	



SUPPLIER/MANUFACTURER: Awazel

We certify that the materials submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR:



RECEIVED:

26/7/2012

ENGINEER'S REP REVIEW COMMENTS:

Approved As Noted (B)

1- submit Method statement
2- Follow strictly manufacturer's instruction

Waleed Seleem 30/7/2012



Corrections or comments made relative to submittals during this review do not relieve the Contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the Contract Documents. The Contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction; coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

PROJECT MANAGER:

DATE:

RECEIVED

26 JUL 2012



Materials Submittal

Mowasat Medical Plaza Building at Salmiya

TO : Gulf Consult (1 Original + One Copy)
 CC : KMPC/MPC (1 Copy)

DATE : 14/02/05

A: Approved
 B: Approved As Noted
 C: Not Approved
 D: Information Noted

CONTRACTOR : Bahar Int'l Construction Co.

Submittal No. :	<u>MPC-07110/01</u>	Revision.:	<u>1</u>
Submittal Title :	<u>4 mm thick Bituminous Waterproofing Membrane</u>		
Source :	<u>Manufacturer - Awazel Co. Ltd. Riyadh, Saudi Arabia</u>		
Supplier :	<u>Al Bahar & Bardawil, Kuwait</u>		
Location of use :	<u>Below Raft & over retaining wall</u>		

Mowasat Medical Plaza Phase III
 RECEIVED
 FEB 2005
 3:30

Item No.	Dwg, Specs, BOQ Ref.	Description	Type	Copies	Action
					MD Manufacturer's Data CT Certificate TT Tests GT Guarantee CAT Catalog PD Pre-qualification document
<u>1</u>	<u>07110</u>	<u>4mm thick - Bituminous Waterproofing Membrane - Type DS40200 Manufacturer - Awazel Co. Ltd. Riyadh, Saudi Arabia</u>	<u>SM & MD</u>	<u>3</u>	<u>A</u>
		<u>Note: The approved Material as per Tr. # MPC-07110 Rev. 0 is not available in the market.</u>			

We certify that the materials submitted here-with have been reviewed and are in compliance with the contract drawings and specifications and approved as per the above stated

Contractor's Representative
[Signature]
 Date: 14/02/05

Received:
[Signature]
 Date:

Review comments:
Please make sure that the material is (quantity) available locally

Gulf Consult R.E. [Signature] KMPC Superintendent
 Date: 15/2/05

AL-BAHAR & BARDAWIL
 MD - GM - BLD - IND - CTG - AC
 Received by
[Signature]
 Date: 17 FEB 2005

Distribution: KMPC Site offices Projects Gulf Consult Contractor

ACTION BY: _____ DATE: _____

E-Electrical
 H-HVAC
 P-Plumbing
 C-Civil

رقم القيد : 205/ص 2005

التاريخ : 2005/1/6

للمهندس

السادة / شركة إبراهيم الناصر المعماري وشركاه

الاحترام

عناية السيد المهندس / مسئول التصميم

تحية طيبة وبعد ..

الموضوع : مشروع إنشاء وتجديد وصيانة مستشفى الرعاية الصحية


بالإشارة إلى الموضوع أعلاه ، وبإني كلكم رقم م ر/ 251/2004 بتاريخ 2005/1/6
لأمنع من استخدام قسرين حوازل 4mm (DS 40200) إنتاج سعودي وتعلمكم بان يتم
التركيب باستخدام صالة مهرة حسب شروط الشركة المصنعة والمواصفات العالمية وسوف يتم
صل القوصمات اللازمة قبل وأثناء وبعد التركيب الحزل لا يجوز الأسطح .

تكون لكم حسن تعاونكم معنا

وتفضلوا بقبول فائق الاحترام

مكتب الشاهين للاستشارات الهندسية

المهندس القيم



مهندس استشاري

محمد يونس الشاهين المهندس

نسخة اصلية

**INTERNATIONAL HOSPITAL COMPLEX - PACKAGE 5
SITE TRANSMITTAL
of Shop Drawings, Samples, etc.**

PROJECT : International Hospital Complex TRANSMITTAL NO. 63 REV. 0
 CONTRACTOR : Kuwait Dynamics Limited Co.
 TO : Consultant Resident Engineer

WE ARE SENDING HEREWITH / UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS/
 SAMPLES LISTED BELOW. (Delete as necessary)

ITEM NO.	DRW. SPEC. OR BOQ. REF	DESCRIPTION	TYPE +	SUBMITTAL CODE *	ACTION CODE **
1	Sec.7551	D41 Awazel Primer, Bituminous Primer, Manufacturer: Awazel (KSA)			
		Manufacturer: Awazel (KSA)	MD	1	B
2	7551	Desert Shield, DS40200, 4mm thick, Bituminous Membrane, 200gram/2 Polys.	SM	1	B
3		Manufacturer: Awazel (KSA)	MD	1	B

CONTRACTOR : *28 JUN 2007* DATE : 28/6/2007
 RECEIVED BY : **GULF CONSULT** DATE :
 CC : UMS [Vice President-Project Management] *To: RH for action*
28.6.07
 Consultant to enter ACTION CODE and REMARKS


Consultant Remarks :
 * APPROVAL SUBJECT TO SUBMIT GUARANTEE-CERTIFICATE AS REQUIRED PER CONTRACT.

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Consultant Resident Engineer DATE : 28.7.07
 RECEIVED BY CONTRACTOR : *[Signature]* DATE : 28/7/07

CC : UMS [Vice President-Project Management]

+ TYPE: SD: Shop Drawings	* SUBMITTAL CODE:	** ACTION CODE:
SM: Sample	1: Submitted for Approval	A: Approved
GT: Guarantee	2: Submitted for your Information	B: Approved as Noted
MD: Manufacturer's Data	3:	C: Not Approved
CT: Certificates		D: For Information
OT: Others		


 28 JUL 2007
RECEIVED
 INTERNATIONAL HOSPITAL COMPLEX
 PACKAGE 5

2 - Trans
 List transmitted as per

AL MAIDAN HOSPITAL & MULTI STOREY CAR PARK - PACKAGE 11
SITE TRANSMITTAL
of Shop Drawings, Samples, etc.

PROJECT : Al Maidaan Hosp. & Multi Storey Car Park
CONTRACTOR : Almadiah Contracting & Trading Co.
TO : The Resident Engineer
Gulf Consult

Transmittal No. MH-CPEP11/MDACT-010 Rev.0

WE ARE SENDING HERewith / UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW. (Delete as necessary)

ITEM NO.	DRW, SPEC. OR BOQ REF	DESCRIPTION	TYPE +	SUBMITTAL CODE "	ACTION CODE "
1.	Spec. Section 07105	Waterproofing membrane DS 40200 - from M/s. AWAZEL	MD	1	A

CONTRACTOR : Al Maidaan Hospital & Multi Storey Car Park
 DATE: 27 May/06

RECEIVED BY : 27 MAY 2006
 DATE: 27-5-06

CC : (JMS VICE PRESIDENT - PROJECT MANAGEMENT)
 To: MR For action

GULF CONSULT RECEIVED

Consultant Remarks :

Approved

Initials _____ Date _____

Corrections or comments made relative to submittal during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and controlling all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Consultant Resident Engineer _____ DATE: 6.6.06

RECEIVED BY CONTRACTOR : _____ DATE: 6-6-06

CC : (JMS VICE PRESIDENT - PROJECT MANAGEMENT)

* TYPE 00: Shop Drawings SM: Sample GT: Guarantee MD: Manufacturer's Data CT: Certificate OT: others	* SUBMITTAL CODE 1: Submitted for Approval 2: Submitted for your information 3:	RECEIVED ACTC DATE: 06 JUN 2006 TO: ENGR. Bahar & M... My Desk	ACTION CODE : A: Approved B: Approved as noted C: Not Approved D: For Information
QS: _____ M.D.: N.H.		_____ _____	

مشروع نادي بالانتنوم الصحي بالمهيويلة

المالك : الشركة الثلاثية للتجارة العامة والمقاولات
 الاستشاري : دار النوبوس للاستشارات الهندسية
 المقاول الرئيسي : شركة تسونامي للتجارة العامة والمقاولات

طلب اعتماد مواد

نوع الطلب : إتش.إم.إي
 رقم الطلب : 4
 رقم القسم : 7550
 التاريخ : 20/12/2008
 النسخة : 0

إلى المكتب الاستشاري : المهندس العجم ، دار النوبوس للاستشارات الهندسية
 تقدم لكم طلب الاعتماد للمواد المتكورة أدناه

م	وصف العينة	المصدر	النتيجة	تاريخ إعادة الطلب
1	عازل رطوبة للأسطح AWAZEL Desert Shield 40200 (D.S 40200)	شركة صناعات العزل العربية (السعودية)		

الملاحظات

المواصفات الفنية

الاعتمادات السابقة

نتائج الاختبارات والفحوصات السابقة

استلام الاستشاري : أ. م. م. م.
 تاريخ الاستلام : 20/12/08
 الوقت : 4:15 P.M

مدير المشروع :

مرفوض

إعادة تقديم

مستند ملاحظات

مستند

تعليمات الاستشاري

لورينج سيدنيكيا د كنيو حياك ٢٤
 اتيان ومطبات المنتج

المهندس المختص :


تاريخ الاستلام : 20/12/08
 الوقت : ٩:١٥

استلام المقاول : ع. م. م.

A مستند
 B مستند بملاحظات
 C إعادة تقديم
 D مرفوض



State of Kuwait
Ministry of Electricity & Water



دولة الكويت
وزارة الكهرباء والماء

الإشارة :

التاريخ : 17-10-2011

الموافق :

KA/ZC/SUBC/L-00134

M/s. Al-Ghanim International General Trading
& Contracting Co. W.L.L.,
P.O. Box 2118, Safat,
13022 - Kuwait.

Fax: 24847197 / 24822490

Attn. Mr. Fadi Haddad - Vice President - Construction

AL GHANIM INTERNATIONAL GEN. TRAD. & CONT. CO.														R.R.		
AZ-ZOUR SOUTH CCGT-2 PROJECT																
Sec	VF	PD	PM	APM	CAN	M&P CIV	M&P EST	M&P CIV	Str	Str	Str	Str	Str	Str	Str	Str
A																
C																
Sec	PLG Mgr	Cont. Est.	Cont. Cont.	Accs	State Mgr	Exp. Mgr	Log. Mgr	Adm.	HSE	ALS	TAC	TRC	TRC	TRC	TRC	TRC
A																
C																
Dist:										Date: 17/10/11						

Dear Sir,

Design & Build and O & M for the Conversion of the Second Stage
Az-Zour South Gas Turbines to Combined Cycle Plant CCGT-2
(Contract No. MEW/C/4236-2010/2011)

Sub: Request for Material Approval - Awazel Products

This has reference to your letter no. AK/ZC/SUBC/L-000215 dated 09.10.2011 on the captioned subject enclosed with material data sheets for Awazel Products.

No.	Material Description	Manufacturer/supplier
1.	AWAZEL Primer - D41	Arabian Waterproofing Ind.Co. KSA.
2.	AWAZEL Membrane Shield 60	
3.	AWAZEL Desert Shield 40200 (4mm Thick)	

We have reviewed the enclosed document and material data sheets and have no objection to approve your proposed materials to be used for Water Proofing in the above project, provided that contractor shall abide with the clause 2.10 of the contract document regarding priority to the National Products.


Material shall conform to contract specification clause 5C.10 and shall be used as per manufacturer's recommendation. Contractor shall submit detailed method statement for the waterproofing works.

This is for your information and necessary action.

Yours faithfully,

UNDER SECRETARY
MINISTRY OF ELECTRICITY AND WATER

المهندس / إياد علي الفلاح
الوكيل المساعد للخدمات الفنية
والمشاكل الرئيسية



دولة الكويت
وزارة الكهرباء والماء

الإشارة : CEWP-1710-2012

التاريخ : 6-6-2012

الموافق :

M/s. G.S. Engineering & Construction Corporation
C/O M/s Rank General Trading & Contracting Co.
P.O Box No: 2416 Safat- 13025 Fax No: 25458392

Contract No: MEW/MC/4333 - 2011/2012
Construction and Maintenance of Azzour WDC - II

Sub: Approval of material for Water proofing Membrane
manufactured by M/s. AWAZEL KUWAIT CO. LTD.

Dear Sirs,


With reference to your letter no. 091790L - GH/ MH-084 , dated 24/4/2012 on the above mentioned subject, we would like to inform you that we have no objection to approve the above water proofing material

- (1) DS 40200 - 4 mm thick water proofing membrane and
- (2) MS 60 - 6 mm thick protection board
- (3) D-41 (Surfaces Preparation)

manufactured by M/s. AWAZEL KUWAIT CO. LTD, subject to the condition that material sample and latest test certificate to be submitted for review and approval before using the material at site.

With thanks and regards,

Chief Engineer
for Water Networks & Water Works Projects
Water Project Department
Ministry Of Electricity & Water



GS Engineering & Construction Corp.

Rasha Tower, 7th Floor, Flat No.704, Building No.8, Street No.2, Area No. 11
Madaan Hawalli, Arabian Gulf Street, The State of Kuwait
Tel : +965-2562-9124, Fax : +965-2562-9129, E-mail : psw@gsconst.co.kr

Mr Charles El-Khoury
Sr. Projects Manager
Site Office
Amana United General Trading & Contracting Co.
Azzour WDCII Project
Kuwait

Date: 09 June 2012
Ref. : 091790-L-GL/SU-081
Page: 1 of 1

Subject: Subcontract No. GS/Azzour/SC-002
Approval of Material for Water Proofing Works

Dear Sir,


With regard to your submittal Ref. O-07100-001-A, you are informed that the below water proofing material are approved by MEW,

- (1) DS 40200 – 4 mm thick water proofing membrane
- (2) MS 60 – 6mm thick protection board
- (3) D-41 (Surfaced Preparation)

The approval is subject to the condition that material sampling test should be done and the result should be submitted for review and approval before using the material at the site. For your reference, please find attached MEW letter Ref. CEWP-1710-2012


Yours sincerely

Sangwon Park
Sang-Won Park
Project /Site Manager
Azzour WDC II Project




Attachment: Copy of MEW letter

1 set



cc: Mr. George Naffah / General Manager of Kuwait Office



الجمهورية العربية السورية
50th Anniversary of the Issuance of the Constitution of the State of Kuwait
1962 - 2012



دولة الكويت
وزارة الكهرباء والماء

الإشارة: 707 / 2012 / C.F.W.P.

التاريخ: 13-3-2012
الموافق:

M/s ABB/AHMADIAH CONSORTIUM
P.O BOX 4275, SAFAT- 13043 KUWAIT, Fax No.22277900

Your Reference
PSP/P4

Number
O-01300-01273

Date:
24.01.2012

Reference: Contract No.MEW/MC/4181-2010/2011
Construction and Maintenance of Mina Abdullah WDC-II

Subject: Waterproofing System – Membrane Awazel DS40200

Dear ABB/AHMADIAH CONSORTIUM,

With reference to the above mentioned subject, please be informed that the document has been reviewed and our response is as shown in the attached submittal review.

Action Code No.1: Approved

This is for your information & necessary action.

Regards,

[Handwritten signature]

Chief Engineer
For Water Networks & Water Works Projects



A	WDC II-MINA ABDULLAH	Action	Info
	DMD		
	Project Manager		
	Contract Manager		
	Technical Manager		
	Const. Manager		
	MEP Coordinator		
	QA/QC Engineer		
	Procurement Officer		
	Quantity Surveyor		
	ABB		
	<i>[Handwritten initials]</i>		
Date: 14 MAR 2012			



NJS CONSULTANTS CO., LTD.



AL DOWAILAH ENGINEERING CONSULTANTS &
CONSTRUCTION MANAGERS


SUBMITTAL REVIEW

	Date: 29.02.2012	Document No: NJS/AD- ABB/ACTC-C0178
To: ABB/Ahmadiyah	Employer: MEW	
Attention: Hermann Hoffmann	Project Name: Construction & Maintenance of Mina Abdullah WDC II	
Reference:	Reference No.: O-01300-01273 Date: 24.01.2012	
Submittal No.	ACT/MEW/ABB/1246/10 0	

Subject Submittal has been reviewed and review action is as shown below:

Description	Doc./Dwg No.	Action Codes			
		Approved	Approved as Noted	Disapproved	Noted
		1	2	3	4
Waterproofing System – Membrane Awazel DS40200		X			

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the contract Documents. This Check is only for review of general conformance with the Design concept of the project and general compliance with the information given in the project Documentation. The contractor is responsible for design of the process and for any errors or omission of all submittals. The contractor is responsible for design and construction of the water works including confirmation and correlation of all quantities and dimensions; drawings, calculations and schedules (including those from subcontractors and suppliers); selecting fabrication process and techniques of construction; coordinating this work with that of other trades, and performing his work in a safe and satisfactory manner


Yoshiaki Hidaka
Resident Engineer




NJS CONSULTANTS CO., LTD.



AL DOWAILAH ENGINEERING
CONSULTANTS & CONSTRUCTION MANAGERS


**Construction And Maintenance of
Mina Abdullah WDC II**

Submittal No		ACT/MEW/ABB/1246/10 0				
Description	Waterproofing System – Membrane Awazel DS40200		Date	24.01.2012	No of Pages	
Reviewed/ Checked by	Senior Civil Engineer	MAGATATETSUN 	Reference			
Action Codes	1. Approved	2. Approved as Noted	3. Disapproved	4. Noted		
	X					

Com.No	Doc./Page	NJS/AL DOWAILAH Comment



Consortium
 ABB AG Division Power Generation
 Ahmadiyah Contracting & Trading Co.
 Construction and Maintenance of
 Mina Abdullah WDC II



Consortium ABB / Ahmadiyah
 Kallstadter Str. 1, D-68309 Mannheim

MEW
 Chief Engineer
 For Water Networks & Water Works Projects
 Ministry of Electricity & Water
 P.O Box 12
 Kuwait City
 Kuwait

Your ref.	Our Dept. Dictated by PSP/P4 Herrmann Hoffmann	Our Reference	Number O-01300-01273	Date 24-01-2012
-----------	--	---------------	-------------------------	--------------------

MEW Contract No: MEW/MC/4181 - 2010/2011
Construction & Maintenance of Mina Abdullah WDC II
Waterproofing System - Membrane Awazel DS40200

Dear Sir,

Please find enclosed herewith two (2) copies from M/s. Al-Bahar & Bardawil letter ref: ZM/0212/0112 dated 17 January 2012, related to the waterproofing system; Test of Membrane and Technical data sheet, which is self explanatory.

Please find the following documents for your kind review and approval at the earliest.

With best regards

For ABB/Ahmadiyah Consortium

Herrmann Hoffmann, Project Director

Document No.	Title	Action	Response Date
ACT/MEW/ABB/1246/10 0	Waterproofing System - Membrane Awazel DS40200	For Approval	23-02-2012

This document is electronically distributed to: Standard-MEW User/MEW/MinaAbdullah

...

 Received
 25/01/12

RECEIVED
 25 JAN 2012



ABB AG
 Kallstadter Str. 1
 68309 Mannheim
 GERMANY

MEW
 WATER PROJECT SECTOR
 CHIEF ENGINEER NETWORK & WATER WORKS PROJECTS
 AZZOUR NORTH WATER DISTRIBUTION SCHEM

No.: 599
 Date: 25/01/12

Design Department For Networks & Water Works Projects
 Water Works Projects Department
 Consultant

For Information For Necessary Action
 For Audit For Follow-up
 Refer to me For Study and Recommendation
 For File For Reply
 Urgent Very Urgent


ADDRESSEE  (SIGNATURE)	SENDER  (SIGNATURE)
---	--

1	water proof membrane for ROOF	14/1/06			
	D. S. 40200				
	AWAZGL				

REV.	DESCRIPTION	DATE	PREPARED	CHECKED	APPROVED
------	-------------	------	----------	---------	----------

SUBMITTAL RECORD

Client :



MINISTRY OF ENERGY
(ELECTRICITY & WATER)
STATE OF KUWAIT

Contractor :



AL-AHLEIA SWITCHGEAR COMPANY K.S.C.C.
KUWAIT

Contract No. :

ME/EW/3242-2005/2006
FOR SUPPLY & INSTALLATION OF 2 NOS. 132/11KV SUB-STATION
AT KHIRAN PEARL "A" & KHIRAN PEARL "B"

Contractor's Drg. No.	Rev. 0
-----------------------	--------

Title :

Kuwait Fire Department



الإدارة العامة للإطفاء

Date : _____

Ref No : _____

التاريخ : 17 / 10 / 2012
الرقم : 17 / 17 - 17

السادة / دار سلمان الشلاحي للإستشارات الهندسية
تحية طيبة وبعد،،
المحترمين،،

عقد رقم (37 / 2011 / 2012) إتفاقية الإشراف على مشروع

إنشاء وإنجاز وإضافة وصيانة دور بقطاع الوقاية

فرع محافظة الأحمدى بمركز إطفاء الفحيحيل

الموضوع : اعتماد نوع الطربال عازل الرطوبة (ممبرين)

بالإشارة إلى الموضوع أعلاه وإلى كتابكم رقم (2012/79) بتاريخ 2012/12/4 (مرفق نسخة) ، نفيدكم بأنه لا مانع لدينا من اعتماد عينة التريال السعودي (AWAZEL DESERT SHIELD 40200) سمك 4مم كعازل للرطوبة لعزل الأسقف والحمامات حسب شروط ومواصفات العقد.

وتفضلوا بقبول فائق الإحترام ،،

مراقب المشاريع والصيانة

مهندس إطفاء مهتم
محمد الأحمد العنزي
مراقب المشاريع والصيانة

بإدارة الإطفاء
17 / 10 / 2012

مراقبة المشاريع والصيانة (قسم التنفيذ)

17 / 10 / 2012



الهيئة العامة للبيئة
ENVIRONMENT PUBLIC AUTHORITY
دولة الكويت - State of Kuwait

التاريخ: ٢٠٠٧/٥/١٤
الرقم: ٤٦٧/أ

السادة شركة المجموعة الأولية للتجارة العامة والمقاولات المحترمين
تحية طيبة وبعد ،،،

الموضوع: اعتماد عينات عازل الرطوبة (طربال)
للعقد: رقم هـ ع ب / ٥ / ٢٠٠٧
صيانة مبنى من دورين مع إعادة تأهيل مخزن المواد الكيميائية
في مركز الشويخ الصناعية

بالإشارة إلى الموضوع أعلاه، وإلى كتابكم رقم م أ / ٤٦٧ بتاريخ ٢٠٠٨/٩/١٤
نحيطكم علماً بأنه لا مانع لدينا من اعتماد عازل الرطوبة (طربال) بمواصفات
(D.S 40 200) واردة شركة عوازل الكويت.

وتفضلوا بقبول فائق الاحترام،،،

مدير إدارة الشؤون الهندسية

**PUBLIC AUTHORITY FOR APPLIED EDUCATION & TRAINING (PAAET)
SHUWAIKH NEW CAMPUS PROJECTS**

Transmittal No.: AESSB/SM/0586
Rev. 00
Date: 6-Jun-11

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

Contractor: Real Estate Construction & Fabrication Co.
Contract: Construction & Maintenance of AESS Buildings
Contract No.: PA/AFA/72-2008/2009



AESSB

1. SUBMITTED FOR APPROVAL	CODE 1
YOUR INFORMATION	2
	3
2. ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED.	C
	D

To: A/E (JQEC)

WE ARE SENDING HERewith DOCUMENTS THAT COMPLIES WITH THE CONTRACT DOCUMENTS

SPEC. or BOQ. REF.	DRAWING NO.	QTY	ITEM SQ No.	DESCRIPTION	*TYPE	CODE	
						Submittal ¹	Action ²
Sec. 07110		1+3		Sample For	(SM)	(1)	B
				Water proofing - DS Membrane			
				M/s. AWAZEL DS 40200			
				Attachments:			
				Samples			
				Location:			
				Contractor: RECAFCO			
				Sub Cont: M/s. Jassim Al Nisf			
				Related Submittal : AESSB/MD/0307			



For: (RECAFCO: Eng. Faisal Abdullah Saud Al-A. Razzaq, Project Manager), Date: 06-06-2011

COPIES
PAAET (The Engineer)
CM (TP)
A/E (JQEC)

A/E to enter Action Codes and Remarks, and return to Contractor

REMARKS:

JAYLO

(B) Approved As Noted

- Test sample and submit Test Certificate.
- Comply with Manufacturer's instructions and recommendations of installation, storage and handling.

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

For: A/E (JQEC) Date: 12/6/2011

COPIES
PAAET (The Engineer)
CM (TP)
A/E (JQEC)

1. Submittal Code to be entered by Contractor Submittal Type: SD = Shop Drawing; SM = Samples; MS = Method Statement; MD - Manufacturer Data
2. Action Code to be entered by A/E MU = Mock-up; SC = Supplier/Sub-contractor; OT = Others (OT = TT, CT, GT, WT)



PROJECTS DEPARTMENT

CONSTRUCTION OF NEW OFFICE BUILDING AT MAA REFINERY
CONTRACT No.: CA/PD/3676

TR. No.: KNPC/KDL/PTFBP-T-0061

DATE: 08 JUL 2008

DOCUMENT TRANSMITTAL

To: **M/s. Kuwait Dynamics Ltd. for Contracting.**
 Attn: **Engr. Hesham Ahmed Mohammed Hassan**
Project Manager

Cc:

KNPC comments on the following document(s) as listed below are hereby transmitted for your information/ action:

Total Number of pages including the cover sheet: (01)

Ref.: KDL/KNPC/PTFBP-T-057

Dated: 23rd June 2008

Received: 26th June 2008

Document ID	Rev. No.	Description / Title	Appr. Stat.
-	-	WATER PROOFING FOR ROOFING SYSTEM	A1*

Legend : A1 – Approved, A2 – Approved with comments, A3 – Not approved,
 R1 – Reviewed – no comments, R2 – Reviewed with comments

Remarks:

NOTE: * MEMBRANE: AWAZEL – DS 40200 (4 MM).**
PRIMER: AWAZEL D41
PROTECTION BOARD: AWAZEL MEMBRANE SHIELD (MS60)
FOAMIX
GEO FABRIX

Note: Any review, comments, agreement or approval by the Company shall in no way relieve the Contractor from its obligations to fulfill all the requirements of the Contract or affect the Company's guarantee rights.

SM/nvm
 CC: File / Site office

SENT BY:

ABDULLAH N. AL-AJMI
PROJECT TASK FORCE LEADER – BP



KUWIAT NATIONAL PETROLEUM COMPANY (K.S.C.)

PROJECTS DEPARTMENT

CONSTRUCTION GROUP

REQUEST FOR APPROVAL OF MATERIAL (Civil/Mech/Elect/Inst)

Contract No. : CB/PD/1123		REF. NO. : RAM 63-09	DATED : 07-09-09
Contractor's Name : Ahmadiah Contracting Company			
CONTRACT TITLE : Revamp of Effluent Treatment Facility			
1 Area :	BUILDINGS MAA, MAB & SHU		
2 Relevant Section & Page of Contract Document :	WD-063-02-3p-0b1		
3 Item of Work :	WATER PROOFING MEMBRANES		
4 Material Item to be approved :	D.S. MEMBRANES (HIGH PERFORMANCE POLYMER MODIFIED BITUMINOUS MEMBRANES REINFORCED WITH NON WOVEN POLYESTER MAT)		
5 Brand & Model Name proposed for approval :	P.O. BOX 2933, RIYADH SAUDI ARABIA		
6 Deviation to Specification :			
Attachment 1 : Manufacturers Data Sheet	<input checked="" type="checkbox"/>		
Attachment 2 : Material Specification	<input checked="" type="checkbox"/>		
Attachment 3 : Sample	<input type="checkbox"/>		
Attachment 4 : Test Certificate	<input type="checkbox"/>		
Attachment 5 : Manufacturers Catalogue	<input checked="" type="checkbox"/>		
Compliance with Specification		Supplier VEC Approved	
Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/> Not Categorized in VEC List <input checked="" type="checkbox"/>
Prepared by : <i>[Signature]</i>		Contractor Representative : <i>[Signature]</i>	
Date : 07/09/09		Date : 08/09/09	
KNPC ACTION :		Rejected <input type="checkbox"/>	
Approved <input checked="" type="checkbox"/>			
By <i>B. H. J. Josem</i>			
Date 16/09/09			
Distribution			
KNPC	Contractor	Others	



شركة نفط الكويت (ش.م.ك.)
KUWAIT OIL COMPANY (K.S.C.)
 شركة نفط الكويت
 A Subsidiary of Kuwait Petroleum Corporation



REQUEST FOR APPROVAL OF MATERIAL (RAM)

Project : New Booster Station BS-171 at West Kuwait

KOC Contract No. : 45283

KOC Project No. : EF/171B

Document No.: SPC-000-AZ-E-94462	Rev No.: A	Date: 31/03/2012															
1. Item Description : 1 - <u>DS 40200</u> water proofing membrane 2 - <u>D-41</u> Primer for water proofing membrane To be used for water proofing works for roofs of buildings		<input checked="" type="checkbox"/> A. Approved <input type="checkbox"/> B. Approved with deviation <input type="checkbox"/> C. Not Approved <input type="checkbox"/> D. Incomplete Approved by: <i>[Signature]</i> Date: 25/4/12															
2. Discipline : <table style="width: 100%; border: none;"> <tr> <td><input type="checkbox"/> Mechanical</td> <td><input type="checkbox"/> Fire Fighting</td> <td><input type="checkbox"/> Painting</td> </tr> <tr> <td><input type="checkbox"/> Piping</td> <td><input type="checkbox"/> Structural</td> <td><input type="checkbox"/> Catalyst / Chemical</td> </tr> <tr> <td><input type="checkbox"/> Electrical</td> <td><input checked="" type="checkbox"/> Civil</td> <td><input type="checkbox"/> Others</td> </tr> <tr> <td><input type="checkbox"/> Instrument</td> <td><input type="checkbox"/> Architectural</td> <td></td> </tr> <tr> <td><input type="checkbox"/> Tank</td> <td><input type="checkbox"/> Insulation</td> <td></td> </tr> </table>			<input type="checkbox"/> Mechanical	<input type="checkbox"/> Fire Fighting	<input type="checkbox"/> Painting	<input type="checkbox"/> Piping	<input type="checkbox"/> Structural	<input type="checkbox"/> Catalyst / Chemical	<input type="checkbox"/> Electrical	<input checked="" type="checkbox"/> Civil	<input type="checkbox"/> Others	<input type="checkbox"/> Instrument	<input type="checkbox"/> Architectural		<input type="checkbox"/> Tank	<input type="checkbox"/> Insulation	
<input type="checkbox"/> Mechanical	<input type="checkbox"/> Fire Fighting	<input type="checkbox"/> Painting															
<input type="checkbox"/> Piping	<input type="checkbox"/> Structural	<input type="checkbox"/> Catalyst / Chemical															
<input type="checkbox"/> Electrical	<input checked="" type="checkbox"/> Civil	<input type="checkbox"/> Others															
<input type="checkbox"/> Instrument	<input type="checkbox"/> Architectural																
<input type="checkbox"/> Tank	<input type="checkbox"/> Insulation																
3. Vendor : Arabian Waterproofing Ind. Co. (AWAZEL)		Location : Saudi Arabia															
4. Manufacturer / Arabian Waterproofing Ind. Co. (AWAZEL)		Origin : Saudi Arabia															
5. Conformance to Specification : <input checked="" type="checkbox"/> Yes <input type="checkbox"/> Yes, but with deviation approved by the Contractor																	
6. Attachments :																	
Material Specification	<input checked="" type="checkbox"/>																
Vendor / Manufacturer's Profile / Catalog / Data Sheet	<input checked="" type="checkbox"/>																
Material Test Certificates	<input type="checkbox"/>																
Sample	<input type="checkbox"/>																
Others	<input checked="" type="checkbox"/>	Previous KOC approval															
Subcontractor : Company Name : Kharafi National Requested By : Anbalagan.S Date : 31-Mar-12		Contractor : Saipem Requested By : <i>[Signature]</i> Date : <i>[Signature]</i>															
KOC : <input type="checkbox"/> Approved <input type="checkbox"/> Rejected By : Date :		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3">Saipem S.p.A.</th> </tr> <tr> <th>DOCUMENT STATUS</th> <th>SIGNED</th> <th>DATE</th> </tr> </thead> <tbody> <tr> <td>Approved</td> <td><i>[Signature]</i></td> <td><i>[Signature]</i></td> </tr> <tr> <td>Not Approved</td> <td></td> <td></td> </tr> <tr> <td>Received for information</td> <td></td> <td></td> </tr> </tbody> </table>	Saipem S.p.A.			DOCUMENT STATUS	SIGNED	DATE	Approved	<i>[Signature]</i>	<i>[Signature]</i>	Not Approved			Received for information		
Saipem S.p.A.																	
DOCUMENT STATUS	SIGNED	DATE															
Approved	<i>[Signature]</i>	<i>[Signature]</i>															
Not Approved																	
Received for information																	

Handwritten notes:
 Top
 VV
 Credit

Handwritten notes:
 11/11
 (RC)



**KUWAIT NATIONAL PETROLEUM COMPANY
PROJECTS DEPARTMENT**

**CONTRACT NO.: CB/PD/1123
REVAMP OF EFFLUENT TREATMENT FACILITIES AT MAB, MAA & SHU REFINERIES**

TR. NO.: KNPC/ACT/RET/MAB-T-09-952

DATE: 16/09/09

DOCUMENT TRANSMITTAL

To: M/s. Ahmadiyah Contg. & Trdg. Co.
Kuwait.

Attn: Mr. Samir W. Karam
Project Manager

Fax: 23287592

cc:

KNPC comments on the following document(s) as listed below are hereby transmitted for your information / action:

Total Number of pages including the cover sheet : (02)

Ref: ACT/KNPC/RET/HO-T-09-1022 **Dated:** 07/09/09 **Recd. Date:** 10/09/09

Document ID	Rev. No.	Description / Title	Appr. Stat.
RAM -063		Request for approval of Material (RAM) Water Proofing Membranes Dimpled Membranes (High Performance Polymer Modified Bituminous Membranes Reinforcement with non woven Polyester mat)	A1

Legend : A1-Approved, A2-Approved with comments, A 3-Not approved, R1-Reviewed-no comments, R-2 : Reviewed with comments


Remarks: Refer attachment for the details

Note: Any review, comments, agreement or approval by the Company shall in no way relieve the Contractor from its obligations to fulfill all the requirements of the Contract or affect the Company's guarantee rights.

cc: File / Site office


SENT BY:

KHALED AL-BULOUSHI
Team Leader - Construction Gr. II - PD



Salim
Al-mad
Muhammad

James





FAKEB

12050504/KP/K/01214

Ref: PM/NK/12050504/21819/13

Date: 11 NOV 2013

M/s. Petrofac International Ltd.
Fax # 22281409

Attention: Mr. Jitender Goel, Project Manager

Contract No. 12050504

New Distribution Network for North Kuwait ESPs

Subject: Request for Approval of Material (RAM)

This has reference to your transmittal No. 12050504/CK/T/01408 dated 27th Oct. 2013 regarding the above subject, please be advised that we have reviewed your submittal and our comments are as follow:

Sr. No.	Document No.	Title	Review Comments
1	JI-2015-1856/7/8/9-0000-CON-GEN-082 Rev. A	RAM - Rock Wool RB Slab / Board Insulation (Stone / Mineral Wool Board)	Reviewed No Comments
2	JI-2015-1856/7/8/9-0000-CON-GEN-083 Rev. A	RAM - 1. AWAZEL DS 40200 (Bituminous Membrane / 4.0 MM THK) 2. AWAZEL Primer D41 (Asphaltic Primer)	Reviewed No Comments

The above Review / Comments by the Company shall in no way relieve the Contractor from his obligation to fulfill all the requirements of the Contract. Should any further requirements be detected in compliance to the Contract, the Contractor is obliged to fulfill the same and at no additional cost and / or time impact to the Company

This is for your information necessary action.

Yours faithfully,
FOR KUWAIT OIL COMPANY (K.SIC)

ABDUL LATIF AL-RABAH
Team Leader PM (NK)

Handwritten notes and initials:
I
I
I
OC I
A
Pno



AHMAD AL-JABER OIL & GAS EXHIBITION PROJECT

Transmittal No. 12050346 -MK-T-00 111 /MD-ST-000 24

Rev. A

CONTRACTOR: **MOHAMMED ABDULMOHSIN AL-KHARAFI & SONS**

Date: 30-10-2012

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

SUBMITTED FOR	CODE
APPROVAL	1
YOUR INFORMATION	2
	3

CONTRACT NO.: 12050346

Project: KOC- EF / 1703

ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
	D

TO: PM

WE ARE SENDING HEREWITH / DOCUMENTS LISTED BELOW. (DELETE AS NECESSARY)

QTY	DRWS., SPEC. OR BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	*TYPE	CODE	
					Submittal	Action
1 Original	VOL.II-P.III BUILD.-CIV- STRUC. SEC.3300 2.04-F	1	Bituminous Sheet Waterproofing: from Baher & Bardaweel as a Supplier	MD	1	
5-Copies		A	Protection board -MS 60 material data & sample			A
1- BDF -CD		B	Waterproofing - DS40200 material data & sample			B
		C	Primer - D41 material data			B
			sample tages included			



Mohammed Abdulmohsin Al-Kharafi & SONS W.L.L.
Contract.No.12050346 (K.O.C)

Copies To

PM

CONTRACTOR

ENG.Gamal Saad

COMPANY (KOC)

FOR CONTRACTOR -PM

PM to enter Action Codes and Remarks, and return to Contractor **APPROVED AS NOTED**

REMARKS:

- * Samples to be sent to laboratory for testing
- * Manufacturing recommendation for applying to be respect
- * This material to be used for basement
- * No extra time or cost to project.

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Copies To

PM

CONTRACTOR

COMPANY (KOC)

DISCIPLINE ENG.:

PM

DATE

DATE:

05-11-12

5/11/12

1 Code to be entered by Contractor

2 Code to be entered by PM

+ TYPE: SD - Shop drawings MD - Manufacturer's Data
SM - Sample CT - Certificates
GT - Guarantee OT - Other

Received by Contractor:

Date:

Signature:

	Company	شركة نفط الكويت (ش.م.ك.) KUWAIT OIL COMPANY (K.S.C.) إحدى شركات مؤسسة البترول الكويتية A Subsidiary of Kuwait Petroleum Corporation	JOB	UN
				22028
Project No.: EF 1769	Project Title : INSTALLATION OF NEW COMPRESSORS AT GC-07, 08 AND 21		QC CODE	
Contract No: 42906	Record/Report Title: REQUEST FOR APPROVAL OF MATERIAL (RAM)		REPORT No. RAM/CIV/047 Rev. A	
DOCUMENT No.:	Rev No.:	Date:	27/10/2011	

1. Item Description :
 1. Water Proofing Membrane (AWAZEL DS40200) Waterproofing Works
 2. PRIMER (AWAZEL PRIMER D 41) Waterproofing Works

2. Location :
 VSD BUILDING GC-07, GC-08 & GC-21

3. Discipline

<input type="checkbox"/> Mechanical	<input type="checkbox"/> Fire Fighting	<input type="checkbox"/> Painting
<input type="checkbox"/> Piping	<input type="checkbox"/> Structural	<input type="checkbox"/> Catalyst Chemical
<input type="checkbox"/> Electrical	<input checked="" type="checkbox"/> Civil	<input type="checkbox"/> Others
<input type="checkbox"/> Instrument	<input type="checkbox"/> Architectural	<input type="checkbox"/> Insulation
<input type="checkbox"/> Tank		

KUWAIT OIL COMPANY

A. Approved
B. Approved
C. Rejected - Resubmit
D. Information Missing

Reviewed as Noted -
Incorporate and Resubmit

Approved by the Contractor to fulfill all the conditions of the Contract.

By: O.R. Date: 3/11/11

4. Vendor : AWAZEL KUWAIT CO. LTD.

5. Whether Vendor Approved by Company : Yes No

6. Manufacture / Brand : AWAZEL KUWAIT CO. LTD. Origin : KUWAIT

7. Conformance to Specification : Yes No Yes, but with deviation approved by the Contractor

8. Attachments :

Material Specification	<input checked="" type="checkbox"/>
Vendor / Manufacturer's Profile / Catalog / Data Sheet	<input checked="" type="checkbox"/>
Material Test Certificates	<input checked="" type="checkbox"/>
Sample	<input checked="" type="checkbox"/>
Others	<input checked="" type="checkbox"/>

Attached sample
 Previous Approval

RECEIVED

20 NOV 2011

MBTC Cont. Div

Lower tier Sub-contractor Company Name : MBTC Requested By : R. PRABU Date : 27/10/2011	Subcontractor Company Name : hulf spic Requested By : J. KATHIRESAN Date : 27/10/11	Contractor Company Name : Saipem S.p.A. Requested By : Date : 27/10/2011 New Compressors at GC-7, 8 & 21 Project Field Quality Manager Radhakrishnan Kartha
---	---	---

COMPANY : Approved Rejected

By : _____ Date : _____

By : _____ Date : _____



TRANSMITTAL of DOCUMENT REVIEW NOTICE (DRN)

CONTRACT NUMBER 44017	CONTRACT TITLE Integrated Security System for all KOC Facilities	KOC PROJECT EF1700
KOC DRN TRANSMITTAL NUMBER 44017/KC/IT/01088	CONTRACTOR TRANSMITTAL 44017/CK/IT/01143	DATE ISSUED 3-Jan-11
TX / DRN ISSUE DATE 16 JAN 2011	SUBJECT Request for Material Approval - Water Proofing Membrane (Ahlia Chemical- Kuwait) and (Awazel-KSA)	DATE RECEIVED 3-Jan-11
		REPLY BY DATE 14 days after receipt
To: Samsung SDS Co. Ltd 707 -19 Yeoksam- 2 Dong Gangnam Gu Seoul, Korea, 135-918 Fax: +82 2 3429 3983 Att: Mr. Gwanghee Ahn Project Manager	From: Khalaf N. Hamada Team Leader Major Projects V Kuwait Oil Company K.S.C. PO Box 9758 Ahmadi 61008 Kuwait	RECEIVED:

In response to the referenced transmittal, the documents have been given the review status indicated below


- Status Key**
- A Approved / Reviewed
 - B Approved / Reviewed as noted. Incorporate and resubmit.
 - C Not approved / Rejected as noted - Revise and resubmit.
 - D Information Reviewed

Seq	Document No	Rev	Title	Status	Comments	Doc. Attached
	44017/CK/IT/01143					
1	44017-00000-V-RMA-00035	A	REQUEST FOR MATERIAL APPROVAL (RMA) - WATER PROOFING MEMBRANE (AHLIA CHEMICAL INDUSTRIES, KUWAIT)	A		X
2	44017-00000-V-RMA-00036	A	REQUEST FOR MATERIAL APPROVAL (RMA) - WATER PROOFING MEMBRANE (AWAZEL, KSA)	A		X

The Document Review Notice Comments are attached hereto. Please proceed as per contract requirements. If indicated, a response is required before the Reply by Date.

[Signature]
Khalaf N. Hamada
 Team Leader, Major Projects V

16 JAN 2011
 4:00 am
 Document Transmitted





KUWAIT OIL COMPANY (K.S.C)
A Subsidiary of Kuwait Petroleum Corporation



REQUEST FOR APPROVAL OF MATERIAL (RAM)

PROJECT: NEW AHMADI HOSPITAL & RESIDENTIAL BUILDINGS

KOC Contract No: 46671

Transmittal No. : 46571-S-K-T-00072

Document No: 46571-MDS-2PR-2002	Revision No: B	Date: 15-Mar-2011												
1 Item Description: BITUMINOUS SHEET WATERPROOFING SPECIFICATION REFERENCE : 07130 a) AWAZEL PRIMER - D 41 b) AWAZEL WATERPROOFING MEMBRANE - DS40200 c) AWAZEL PROTECTION BOARD - MS 60														
2 Discipline: <input type="checkbox"/> Mechanical <input type="checkbox"/> Fire Fighting <input type="checkbox"/> Painting <input type="checkbox"/> Piping <input type="checkbox"/> Structural <input type="checkbox"/> Catalyst/Chemical <input type="checkbox"/> Electrical <input type="checkbox"/> Civil <input type="checkbox"/> Others <input type="checkbox"/> Instrument <input checked="" type="checkbox"/> Architectural <input type="checkbox"/> Tank <input type="checkbox"/> Insulation														
3 Vendor: M/s. Al-Bahar & Bardawil		Location: Kuwait												
4 Manufacturer / Brand: M/s. Arabian Waterproofing Ind. Co., (AWAZEL)		Origin: Saudi Arabia												
5 Conformance to Specification: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Yes, but with deviation approved by the Contractor														
6 Attachments: Material Specification <input type="checkbox"/> Vendor/Manufacturer's Profile/Catalog/Data Sheet <input type="checkbox"/> Material Test Certificates <input type="checkbox"/> Sample <input type="checkbox"/> Others <input checked="" type="checkbox"/>		<div style="text-align: right; border-bottom: 1px solid black; margin-bottom: 5px;"> KUWAIT OIL COMPANY (K.S.C) (P) </div> <table style="width:100%; border-collapse: collapse;"> <tr> <td style="width:33%;"><input checked="" type="checkbox"/> A Approved/Reviewed</td> <td style="width:33%;"><input type="checkbox"/> B Approved/Reviewed - as Noted Incorporate and Resubmit</td> <td style="width:33%;"><input type="checkbox"/> C Not Approved/Rejected as Noted Revise and Resubmit</td> </tr> <tr> <td><input type="checkbox"/> D Information Reviewed</td> <td colspan="2"> <small>Approval by the Company related to the Work shall in no way relieve the Contractor from its obligation to fulfil all the requirements of the Contract.</small> </td> </tr> <tr> <td style="border-top: 1px solid black; border-bottom: 1px solid black;"> <small>Signature</small> </td> <td style="border-top: 1px solid black; border-bottom: 1px solid black;"> CIVIL <small>Dept.</small> </td> <td style="border-top: 1px solid black; border-bottom: 1px solid black;"> MAR 27, 2011 <small>Date</small> </td> </tr> <tr> <td colspan="3"><small>77N No.</small></td> </tr> </table>	<input checked="" type="checkbox"/> A Approved/Reviewed	<input type="checkbox"/> B Approved/Reviewed - as Noted Incorporate and Resubmit	<input type="checkbox"/> C Not Approved/Rejected as Noted Revise and Resubmit	<input type="checkbox"/> D Information Reviewed	<small>Approval by the Company related to the Work shall in no way relieve the Contractor from its obligation to fulfil all the requirements of the Contract.</small>		 <small>Signature</small>	CIVIL <small>Dept.</small>	MAR 27, 2011 <small>Date</small>	<small>77N No.</small>		
<input checked="" type="checkbox"/> A Approved/Reviewed	<input type="checkbox"/> B Approved/Reviewed - as Noted Incorporate and Resubmit	<input type="checkbox"/> C Not Approved/Rejected as Noted Revise and Resubmit												
<input type="checkbox"/> D Information Reviewed	<small>Approval by the Company related to the Work shall in no way relieve the Contractor from its obligation to fulfil all the requirements of the Contract.</small>													
 <small>Signature</small>	CIVIL <small>Dept.</small>	MAR 27, 2011 <small>Date</small>												
<small>77N No.</small>														
Subcontractor: Company Name: Requested By: Date:	Contractor: Sayed Hamid Behbehani & Sons Co. Requested By: Date: 15-Mar-2011													
KOC: <input type="checkbox"/> Approved <input type="checkbox"/> Approved as Noted-Resubmit <input type="checkbox"/> Rejected														
By:	By:													
Date:	Date:													

46571-S-K-T-00072

AL-BAHAR & BARDAWIL
P&CEO BLD IND CTG AC
 12 JUL 2011
 ACTION BY: DATE:



Anniversary
Kuwait Oil Company
 subsidiary of KPC

To:
SAYED HAMID BEHBEHANI & SONS CO.
 P. O. Box 3065, Safat 13031,
 Kuwait.

Date: **28 MAR 2011**
 Transmittal No: **48571-KS-T-00068**
 Contract No.: **48571**
 Project Name: **New Ahmadi Hospital and Residential Buildings**

Attn: **Eng. WALID K. BARAKAT**
 Project Manager

SUBJECT: RAM : BITUMINOUS SHEET WATERPROOFING

Document Number	Rev.	Doc. Status	Contractor Trans. Ref.	Contractor Received Date	Description
MDS-2PR-2002	B	A	48571-S-K-T-00072	17-Mar-11	RAM : BITUMINOUS SHEET WATER PROOFING - AWAZEL PRIMER D41/MEMBRANE DS40200 & PROTECTION BOARD - MS 80 - AL-BAHAR & BARDAWIL

Doc Status Legend:

A	Approved/Reviewed	C	Not Approved/Rejected - As noted. Revise and Resubmit
B	Approved/Reviewed - As noted. Incorporate and Resubmit	D	Information Reviewed

For KUWAIT OIL COMPANY

[Signature]
KEVAN ABRAHAMS
 Superintendent Representative

ACTION		APPROVE	REVIEW	INFO
NAME	ACTION	APPROVE	REVIEW	INFO
ENG.				
CIVIL				
ELEC.				
MECH.				
SITE MNG.				
COORD.				
PLAN.				
QA/QC				
HSE				
ARCH.	X	Y		
QS				
MEDICAL				
FURN.				
STRUC.				
CONT.	X	X		

RECEIVED
 28 MAR 2011
 7:45 AM
 NEW AHMADI HOSPITAL
 SHCC



عافة على تأسيس
 شركة نفط الكويت Anniversary
 1934 - 2009 Kuwait Oil Company
 subsidiary of KPC

To:
SAYED HAMID BEHBEHANI & SONS CO.
 P. O. Box 3065, Safat 13031,
 Kuwait.

Date: 24 FEB 2011
Transmittal No: 46571-KS-T-00021
Contract No.: 46571
Project Name: New Ahmadi Hospital and Residential Buildings


Attn: Eng. WALID K. BARAKAT
 Project Manager

SUBJECT: RAM : BITUMINOUS SHEET WATERPROOFING - AWAZEL PRIMER-D41/MEMBRANE DS40200/PROTECTION BOARD MS-60


Document Number	Rev.	Doc. Status	Contractor Trans. Ref.	Contractor Received Date	Description
MDS-2PR-2002	A	B	46571-S-K-T-00024	16-Feb-11	RAM : BITUMINOUS SHEET WATER PROOFING - AWAZEL PRIMER D41/MEMBRANE DS0200 & PROTECTION BOARD - MS 60

Doc Status Legend:
 A Approved/Reviewed
 B Approved/Reviewed - As noted. Incorporate and Resubmit
 C Not Approved/Rejected - As noted. Revise and Resubmit
 D Information Reviewed

For KUWAIT OIL COMPANY


KEVAN ABRAHAMS
 Superintendent Representative

NEW AHMADI HOSPITAL PROJECT				
NAME	ACTION			
	ACTION	ADVISE	RECORDS	INFO
ENG.				
CIVIL				
ELEC.				
MECH.				
SITE MNG.				
CO-ORD.				
PLAN.				
QA / QC				
HSE				
ARCH.				
QS				
MEDICAL				
FURN.				
STRUC.				
CONT.				
MAT	X		X	

RECEIVED

 24 FEB 2011
 11:30am
 NEW AHMADI HOSPITAL
 SHCC



بيت البناء الكويتي
Kuwait Building House



OSAMA BUKHAMBEN DESIGN
دار أسامة وبنين للهندسة والعمارة



المشروع : مجمع القوق سعد الجهاد الصباح المالك : الهيئة العامة للسياحة والرياضة الإستشاري : دار أسامة وبنين للاستشارات الهندسية المقاول : شركة بيت البناء الكويتي للشهرة العامة والمقاولات	طلب تفكيك مواد رقم الطلب : 6 المرجع : SIHC - KBH-6 التاريخ : 3/7/2011
--	--

إلى الإستشاري : طلب مراقبة عظم المراد التالية / الملح / المنتجات / المعدات

رقم البند	وصف للمعدات أو مرجع جدول المواصفات	وصف البند	النوع	عدد التمتع	كود التقييم	كود العمل
1	ST-02 Detail 1,5	مهم حائل رطوبة لزوم عزل ارضيات و حوائط السرداب من شركة عوازل الكويت (DS40200)	سعرى	3 SM/MD/CAT	1	
2		دهان اسمن (primer D41) من شركة عوازل الكويت	سعرى	3 MD/CAT	2	
3		الراج حملة 8 مم لزوم حملة حلال حوائط السرداب (MS60) من شركة عوازل الكويت		3 SM/MD/CAT	3	

لتفاصيل المعلومات والمرفقات :

المقاول : <u>محمد جبار</u> التاريخ : <u>5/11/15</u>	الإستشاري : التاريخ :
مقبول <input type="checkbox"/>	غير مقبول <input type="checkbox"/>
ويشهد أنه تم مراجعة البند المذكورة أعلاه بالتفصيل وهي مطابقة للشروط المرجوة.	
الإستشاري : التاريخ :	المقاول : التاريخ :

- ملاحظات الإستشاري :
1. MATERIAL IS APPROVED SUBJECT TO COMPLIANCE WITH SPECIFICATION THE INSTRUCTION AND MANUFACTURER'S PERMITS/STATEMENT
 2. SUBMIT SHOP DRAWING SHOWING EXTENT OF WATER PROOFING APPLICATION AND PROTECTIVE SHEET.
 3. SUBMIT WRITTEN STATEMENT IN PREPARATION & APPLICATION OF MAT
 4. SUBMIT 10 YEARS GUARANTEE AS PER SPECS. PERFORMANCE.

المقاول : <u>محمد جبار</u> التاريخ : <u>5/11/15</u>	الإستشاري : التاريخ :
مرفقة بملاحظات (B)	عدم المرفقة (C)
مرفقة (A)	لمستندات (D)

**PUBLIC AUTHORITY FOR APPLIED EDUCATION & TRAINING (PAAET)
SHUWAIKH NEW CAMPUS PROJECTS**

Transmittal No.: NI/SM/0211
Rev. 01
Date: 31-08-2010

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

Contractor: Real Estate Construction & Fabrication Co
Contract: Nursing Institute
Contract No.: PA/AFA/112-2008/2009

NI


1. SUBMITTED FOR	CODE
APPROVAL	1
YOUR INFORMATION	2
	3

To: A/E (DAH) - SITE OFFICE

2. ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
	D

WE ARE SENDING HERewith DOCUMENTS THAT COMPLIES WITH THE CONTRACT DOCUMENTS

SPEC. or BOQ. REF.	DRAWING NO.	QTY	ITEM SQ No.	DESCRIPTION	*TYPE	CODE	
						Submittal ¹	Action ²
07110		1+3	1	Approval of Waterproofing Membrane for Raft & Retaining Walls "D.S. 40200"	(SM)	(1)	B
Caluse: 2.02 B							
Enclosed as Follows:						14 SEP 2010	
Sample of D.S. 40200						RECAFCO, NI-PAAET SITE	
Location: Main Building						Position	
Contractor: RECAFCO						Action	
Subcontractor: M/s. Jassem Al-Nisf Co.						Info	
Related Submittal :						File	
RFAS # 003 Dated 03-07-2010						H.O.	
						C.M.	
						P.M.	
						P.E.	
						CO.Eng	
						PL.Eng.	
						S.O.	
						QA/QC	
						Q.S.	
						S.E.	
						Foreman	
						S.K.	
						SEC.	
						S/C.	
						Sign:	
						Date:	



COPIES	
PAAET (The Engineer)	<input checked="" type="checkbox"/>
CM(TP)	<input checked="" type="checkbox"/>
A/E (DAH)	<input type="checkbox"/>

(RECAFCO: Eng. Mohamed Abdul Kareem, Project Manager) Date: 31-08-2010

A/E to enter Action Codes and Remarks, and return to Contractor

REMARKS:

Approved As Noted

- 1 - The material to be tested after delivery to site and this approval is subject to compliance with manufacturer data.
- 2 - Waterproofing membrane must be installed according to manufacturer requirements.
- 3 - The waterproofing membrane shall not exceed the allowable time for exposure to natural elements.

Handwritten signature and date: 09/9/2010


Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

For: A/E (DAH) *[Signature]* Date: 09.09.2010

Submittal Code to be entered by Contractor: _____ Submittal Type: _____

Action Code to be entered by A/E: _____

SD = Shop Drawing, SM = Samples, MS = Method Statement, MF = Manufacturer Data, MU = Mock-up, SC = Supplier/Sub-contractor, OT = Others (ITT, CT, GT, WT)



COPIES	
PAAET (The Engineer)	<input checked="" type="checkbox"/>
CM(TP)	<input checked="" type="checkbox"/>
A/E (DAH)	<input type="checkbox"/>

**PUBLIC AUTHORITY FOR APPLIED EDUCATION & TRAINING (PAAET)
SHUWAIKH NEW CAMPUS PROJECTS**

Transmittal No.: CHS/MD/0276
 Rev. 00
 Date: 03-11-2010

1. SUBMITTED FOR APPROVAL	CODE 1
YOUR INFORMATION	2
	3
2. ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
	D

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

Contractor: Real Estate Construction & Fabrication Co
 Contract: Extension of College of Health Sciences - Girls
 Contract No.: PA/AFA/113-2008/2009

CHS

To: A/E (ZCE) - SITE OFFICE

WE ARE SENDING HEREWITH DOCUMENTS THAT COMPLIES WITH THE CONTRACT DOCUMENTS

SPEC. or BOQ. REF.	DRAWING NO.	QTY	ITEM SQ No.	DESCRIPTION	*TYPE	CODE	
						Submittal ¹	Action ²
III - 2		1 + 3		Approval of Water Proofing Membrane	(MD)	1	B
07110				4 mm thick 200 grams polyester			
Clause - 2.01				(Supplier : M/s Awazel Industries, K.S.A.)			
				Encl: As Above			
				Location: BUILDING			
				Contractor: RECAFCO			
				Sub-Contractor : Jassem A. Yusuf Al-Nisf & Co.			
				Related Submittal :			

RECAFCO, CHS			
Position	Action	Info	File
H.O.			
C.M.			
P.M.			
P.E.			
Arch. Eng.			
Str. Eng.			
P.L.A. Eng.			
S.O.			
QA/QC			
IS			
SE			
Foreman			
S.A.O			
SBC			
S/S			
Sign:		Date:	

For: RECAFCO (Eng. Azzam Al-Far, Project Manager) Date: 03-11-2010

COPIES
 PAAET (The Engineer)
 CM (TP)
 A/E (ZCE)


A/E to enter Action Codes and Remarks, and return to Contractor

REMARKS:

Approved as Noted :-

The 4mm thick water proofing membrane type 'DS 40200' from Awazel Co. Ltd. Of KSA is only accepted, subject to laying two layer as per the manufacturer's standard and compliance with the contract documents.

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades and performing his work in a satisfactory manner.




For: A/E (ZCE) Date: 14.11.10

Submittal Code to be entered by Contractor Submittal Type: SD = Shop Drawing; SM = Samples; MS = Method Statement; MD = Method of Data
 Action Code to be entered by A/E MU = Mock-up; SC = Supplier/Sub-contractor; OT = Others (OT = TT, CT, GT, WT)

PUBLIC AUTHORITY FOR APPLIED EDUCATION & TRAINING (PAAET)
 13 NOV 2010 Shuwaikh Campus Project
REQUEST FOR ALTERNATIVE OR SUBSTITUTION

TO: PAAET (The Engineer) CC: CM (TP) A/E (Dowailah)

Contractor: Combined Group Contracting Co.
 Contract: Construction & Maintenance of Labs and Workshops for Second Extension of the College of Technology
 Contract No: PA/AFA/114-2008/2009
 Request No: RFAS/0003
 Date: 01.11.2010



This submittal will not be reviewed unless the Contractor complies with the minimum submittal requirements of Document III-2, Section 01632, Clause 1.03-A-4b (comparison sheets), Clause 1.03-A-4c (product data), Clause 1.03-A-4d (cost comparison) & Clause 1.03-A-4g (contractor's waiver).

PROPOSED ALTERNATIVE OR SUBSTITUTION:

PRODUCT METHOD OF FABRICATION METHOD OF INSTALLATION

Specified Product: Dermabit 4250 / Paralon NT-4 / Testudo 16.
 Proposed Product: DS40200
 Spec. Section #: 07130 & 0755 Page # III-2/07130-3 & III-2/07550-3-4 Article # 2.01
 Specified Manufacturer: Dermabit Waterproofing Ind., KSA/Imper Italy/Index Construction System & Products
 Proposed Manufacturer: Arabian Waterproofing Ind. Co.,
 Brief Product Description: DS40200 Waterproofing Membrane.

REASON FOR PROPOSED ALTERNATIVE OR SUBSTITUTION:
 The specified product is not available.

COST AND TIME SAVINGS

COST No Yes Amount (KD) (Deduction) KD 350,000
 (Kuwaiti Dinars Ten Thousand Three Hundred & Fifty Only)
 TIME No Yes Days

ACTION	ACTED	DATE	REMARKS
PROJ. ENG.			
SITE ENR.			
CDR. ENG.			
ARCH. ENG.			
EST. ENR.			
QA/QC			
AL-ESSA			
MHARABI			
ALICB			
GULF			
ETA			

THE CONTRACTOR CERTIFIES AND UNDERTAKES THAT:

- Same warranty will be furnished for proposed alternative or substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable is available.
- Cost data as stated above is complete. Claims for additional costs or time related to accepted alternative or substitution which may subsequently become apparent are to be waived. Other costs to other disciplines and/or contractors shall be borne by the Contractor.
- Proposed alternative or substitution does not affect dimensions and functional clearances.
- The cost for all changes to design, including architectural or engineering design, detailing, and construction cost including authorities approvals, caused by the requested alternative or substitution shall be fully the responsibility of the contractor at no cost to the employer.
- Coordination, installation, and changes in the Work as necessary for accepted alternative or substitution will be complete in all respects.

THE CONTRACTOR FURTHER ACKNOWLEDGES THAT APPROVAL FOR ALTERNATIVE/SUBSTITUTION DOES NOT WAIVE HIS OBLIGATIONS TO THE EMPLOYER AS DETAILED IN DOC. III-2 SECTION 01632

For Combined Group Cont. Co.
 Eng. Malek Miski - Project Manager
 Received by PAAET

DATE/TIME _____
 DATE/TIME _____

REVIEW AND ACTION BY THE ENGINEER

Approved Not Approved Approved as Noted Incomplete Data Resubmit
 Request received too late Other


Refer to attached comments.
 ADDITIONAL COMMENTS:

PAAET(The Engineer):
 DATE/TIME: 10/11/2010

THE APPROVAL OF ANY ALTERNATIVE OR SUBSTITUTE PRODUCT/METHOD SHALL BE SOLELY AT THE DISCRETION OF THE ENGINEER AND SUCH APPROVAL SHALL IN NO WAY RELIEVE THE CONTRACTOR OF ANY OF HIS LIABILITIES AND OBLIGATIONS UNDER THE CONTRACT. THIS APPROVAL DOES NOT ENTAIL ANY ADDITIONAL COST OR TIME

cc: CM (TP) #REFI

**PUBLIC AUTHORITY FOR APPLIED EDUCATION & TRAINING (PAAET)
SHUWAIKH NEW CAMPUS PROJECTS**



TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

Contractor: Real Estate Construction & Fabrication Co
Contract: Nursing Institute
Contract No.: PA/ AFA / 112 - 2008 / 2009

Transmittal No.: NI/MD/03/
Rev. 00
Date: 19/08/2010

1. SUBMITTED FOR	COD
APPROVAL	1
YOUR INFORMATION	2
	3
2. ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
	D

To: A/E (DAH) - SITE OFFICE

WE ARE SENDING HERewith DOCUMENTS THAT COMPLIES WITH THE CONTRACT DOCUMENTS

SPEC. or BOQ. REF.	DRAWING NO.	QTY	ITEM SQ. No.	DESCRIPTION	*TYPE	CODE	
						Submittal	Action
III/2		1+3	1	Awazel Desert shield 40200	(MD)	(1)	
07110				(4 mm thick waterproofing membrane type			23 AUG 2010
				DS40200 from Awazel Arabian Waterproofing Co. KSA.)			
				(Enclosed: Catalogue)			
				Location: BUILDING & LANDSCAPING			
				Contractor: RECAFCO			
				Related Submittal : RFAS # 003, Rev-01 Dated 10/02/2010.)			

RECAFCO, NI-PAAET SITE			
Position	Action	Info	Pitt
H.O.			
C.M.			
P.M.			
P.E.			
CO. Eng.			
PL. Eng.			
S.O.			
QA/QC			
Q.S.			
S.E.			
Foremen			
S.K.			
SEC.			
CM(TP)			
A/E (DAH)			

For: RECAFCO (Eng. Mohamed Abdul Kareem, Project Manager) Date: 19/08/2010

A/E to enter Action Codes and Remarks, and return to Contractor

REMARKS:

Approved As Noted

- AWAZEL DESERT SHIELD 40200, 4mm thick, is accepted subject to laying the two membrane layers in opposite directions and to full compliance with all related contract documents.
- Comply with manufacturer requirements for preparation and installation.
- The approval is subject to randomly selected samples from materials delivered at site and for the results to meet minimum specification and manufacturer requirements.
- Submit method statement, samples and shop drawings for review and approval.

Alc 22/08/2010

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

For: The Engineer	Date: 22.08.2010	COPIES
1. Submittal Code to be entered by Contractor	Submittal Type: SD = Shop Drawing; SM = Samples; MS = Method Statement; MD = Manufacturer Data	PAAET (The Engineer) <input checked="" type="checkbox"/>
2. Action Code to be entered by A/E	NU = Mock-up; SC = Supplier/Sub-contractor; OT = Others (OT = TT, CT, GT, WT)	CM (TP) <input checked="" type="checkbox"/>
		A/E (DAH) <input type="checkbox"/>

19.8.2010
11:00AM

PUBLIC AUTHORITY FOR APPLIED EDUCATION & TRAINING (PAAET)
Shuwaikh New Campus Projects
REQUEST FOR ALTERNATIVE OR SUBSTITUTION


TO: PAAET (THE ENGINEER) CC: CM (TP) A/E (Dar Al-Dabbous)

Contract: Extension of Telecommunication & Navigation Institute Request No. 10 Rev.01
 Contract No.: PA/AFA/22-2005/2006 Date: 16/10/2007
 Contractor: Al Hamra Kuwait Co.

This submittal will not be reviewed unless the Contractor complies with the minimum submittal requirements of Document III-2, Section 01631, Clause 1.03-A-3b (comparison sheets), Clause 1.03-A-3c (product data), Clause 1.03-A-3f (cost comparison) & Clause 1.03-A-3g (contractor's waiver).

PROPOSED ALTERNATIVE OR SUBSTITUTION:
 PRODUCT METHOD OF FABRICATION METHOD OF INSTALLATION
 Specified Product Bituminous Waterproofing Membrane
 Proposed Product Bituplus P4200
 Spec. Section # III-2/07550 Page # 4 Article # 2.01/A1
 Specified Manufacturer DWI - Dermabut Waterproofing Industries (SA) & Calotex Corp. (USA)
 Proposed Manufacturer Awazel Co. Ltd. (Saudi Arabia)
 Brief Product Description Plastomeric Waterproofing Membrane

REASON FOR PROPOSED ALTERNATIVE OR SUBSTITUTION
The proposed product fulfill the contract requirements.



COST No Yes
 TIME No Yes
 Amount (KD) (Deduction) _____
 Days _____

THE CONTRACTOR CERTIFIES AND UNDERTAKES THAT:

- * Same warranty will be furnished for proposed alternative or substitution as for specified product.
- * Same maintenance service and source of replacement parts, as applicable is available.
- * Cost data as stated above is complete. Claims for additional costs or time related to accepted alternative or substitution which may subsequently become apparent are to be waived. Other costs to other disciplines and/or contractors shall be borne by the Contractor.
- * Proposed alternative or substitution does not affect dimensions and functional clearances.
- * The cost for all changes to design, including architectural or engineering design, detailing, and construction cost including authorities approvals, caused by the requested alternative or substitution shall be fully the responsibility of the contractor at no cost to the employer.
- * Coordination, installation, and changes in the Work as necessary for accepted alternative or substitution will be complete in all respects.

THE CONTRACTOR FURTHER ACKNOWLEDGES THAT APPROVAL FOR ALTERNATIVE/SUBSTITUTION DOES NOT WAIVE OBLIGATIONS TO THE EMPLOYER AS DETAILED IN DOC. III-2 SECTION 01631

Project Manager Al Hamra Kuwait Co. [Signature] DATE/TIME 16/10/2007
 Received by A/E (Dar Al-Dabbous) _____ DATE/TIME _____

REVIEW AND ACTION BY THE ENGINEER
 Approved Not Approved Approved as Noted Complete Data Resubmit
 Request received too late Other _____

ADDITIONAL COMMENTS:
Refer to attached comments.
 PAAET (The Engineer): [Signature] DATE/TIME 24/10/2007

THE APPROVAL OF ANY ALTERNATIVE OR SUBSTITUTE PRODUCT/METHOD SHALL BE SOLELY AT THE DISCRETION OF THE ENGINEER AND SUCH APPROVAL SHALL IN NO WAY RELIEVE THE CONTRACTOR OF ANY OF HIS LIABILITIES AND OBLIGATIONS UNDER THE CONTRACT. THIS APPROVAL DOES NOT ENTAIL ANY ADDITIONAL COST OR TIME
 cc: CM (TP) A/E (Dar Al-Dabbous)


Received by Al Hamra: _____ DATE/TIME _____
 GCMO
 C7CMO
 27/10/07

PAAET – New Campus Projects

Comments on Al-Hamra Kuwait Co. Request for Alternative or Substitution # 10 Rev. 1 Dated 16 October 2007

1. Proposed product Awazel DS40200 manufactured by Awazel Co. Ltd. – Saudi Arabia is approved subject to full compliance with all related contract documents.
2. Application shall be done as per manufacturer's recommendation.
3. Provide cost substantiation in accordance with Appendix D.

PROJECT: NBK - RECORD CENTER	CONSULTANT : Al Farooqi Engineering Consultants Bureau	REF.: MS
EMPLOYER: National Bank of Kuwait	CONTRACTOR : Al-Bahar & Bardawil Specialities Co.	Sch. Ref: Date : 30.06.2009



SUBMITTAL FOR APPROVAL OF MATERIALS

1. MATERIAL DESCRIPTION (one item only on this form) :

4mm thick Bituminous Waterproofing Membrane (DS40200)

Area of Application : Basement Tanking and Roofing

Drawing Ref. :

B.O.Q. Ref. No. :

Specification Ref. : 07110-07550

Standards :

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. MANUFACTURER/SUPPLIER :

Company Name : Arabian Waterproofing Ind. Co. (AWAZEL)

Address : Saudi Arabia

Local Agent : Awazel Kuwait Co.

3. DELIVERY :

Country of Origin : Saudi Arabia

Availability

Locally Manufactured

Overseas

Delivery : Ex-works/ Total Duration [] []

Estimated Time of Arrival on Site [] []

Program : Date Material Required on Site [] []

Latest Date for Order [] []

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by: **B&B**

Signature: 

Received by :

Date: ---/---/---

4. CONSULTANT'S REPRESENTATIVE'S COMMENTS :

1- 4mm thick Bituminous waterproofing Membrane (DS40200) shall be applied strictly in accordance with manufacturer's recommendations.

2- submit Bituminous primer for approval

Signature:  Date: 8/7/9

Received by : Date :

- Approved
- Approved As Noted
- Revise and Resubmit
- Rejected
- Sample Required
- Tests Required
- Additional Information Required
- Manufacturer's Guarantee Required

Ref: OHA/BKME/CMBC/08/2005

Date: 30th April 2005

**Construction Management & Building Company (CMBC)
Kuwait.**

**Attn: Mr. Jaber Mustafa Nour
Projects Director**

**Project: BKME - South Sarra Branch - Package 1
Subject: Water Proofing Works sub-contractor approval**


Dear Mr. Jaberr

Reference to the above subject and further to your letter ref. cmbc/547 E/2005 dated 20.04.2005; we would like to inform you of the following:

1. M/s Gannam & Al Sayegh Trading & Contracting Co. is approved as water proofing works sub contractor subject to submit recent valid Ministry of Trading and Industry registrations.
2. The water proofing membrane (DS - 40200) as manufactured by AWAZEL is approved subject to follow the manufacturer's application instructions.
3. The protection board (membrane shield MS 60) as manufactured by AWAZEL is approved subjected to follow the manufacturer's application instructions.
4. The primer (AWAZEL primer D41) as manufactured by AWAZEL is approved subjected to follow the manufacturer's application instructions

This is for your information and action

Best Regards,



**Engr. Khalid Najjar
Resident Engineer**

**CC Mr. Khalid Shady
BKME**

CENTRAL BANK OF KUWAIT - SHUWAIKH BUILDING

CONTRACTOR: SAYED HAMID BEHBEHANI & SONS Co.
TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

Transmittal No: 459 Rev. 0
Date: 30-Jun-05
SUBMITTED FOR CODE
APPROVAL 1
YOUR INFORMATION 2
3

RE: CONTRACT
Central Bank of Kuwait - Shuwaikh Building

TO: RE/GC CC: PM/KUCM

ACTION
APPROVED A
APPROVED AS NOTED B
NOT APPROVED C
FOR INFORMATION D

WE ARE SENDING HEREWITH / UNDER SEPARATE DOCUMENTS LISTED BELOW.

QTY	DRWS., SPEC. or BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	(+) TYPE	CODE
				Submittal *	Action
	Specs 07105		BITUMINOUS WATERPROOFING MEMBRANE		
3		1	AWAZEL-DS40200	MD	1 A
1		2	AWAZEL-DS40200	SM	1 A

ATTN: ENG MASSALI

COPIES

Acting Project Manager: Basil Yasin *Basil*
For Sayed Hamid Behbehani & Sons Co.

Engineer's Rep. to enter Action Codes and Remarks:

REMARKS: *Approved*

- Discussed with Mr. Yohannas K. HAS, GC.*
- Approved in the light of SHBC & MS. H. Ghannim Specifications letter no. 024/813/235/05 dated 30.6.05 & H-Ghanim Jedd dated 30.6.05 attached to it.*
- All specifications for Application & Submittals as per contract applicable.*

AS
6/7/05

Manager

4/7/05
DATE

RESIDENT ENGINEER / GULF CONSULT

KUCM PROJECT MANAGER

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design cover of the project and general compliance with the instructions given in the contract documents. The contractor is responsible for confirming and controlling all quantities and dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

COPIES

FOR OWNER'S REF.
(+) TYPE: SD Shop Drawings
SM - Sample
CM - Certificate
All As Held

CBK - SHUWAIKH
04 JUL 2005
11:29 am
SHBC

DATE:
30/6/05

Code to be entered by contractor
Code to be entered by Engineer's Rep

MD Manufacturer's Data
CT Certificate
DI Other

DATE RECEIVED : 01/06/10
 DATE RETURNED : 01/06/10
 APPROVAL CODE : B.J.L.
 SIGNATURE :

NO ADDITIONAL
TIME OR COST

ahli united bank



Submittal Form

Project : AUB (Ayoun Branch)
 TO : OHA Engineering Consultant

CONTRACTOR : High Slant Group. DATE : 1/6/2010

A. Approved
 B. Approved As Noted
 C. Not Approved
 D. For Information
 E. Resubmit

Submittal No. :	12		Revision.:			
Submittal Title :	1					
Type:	SM Sample	GT Guarantee	OT other			
	CT Certificates	TT Test	MS Method Statemet	MD Manufacturer's Data		
Item No.	Dwgs. Specs BOQ Ref	Description	prov	Type	Copies	Action
		Jassem A. Yusuf AL-Nisf Co." Waterproofing "				
		1- Primer Prime Guard form AL Ahalia Chemicals.				(C)
		2-Waterproofing membrane 4 mm thick 200gram polyster from M/S Awazel Industris K.S.A		Sample		(B)
		3- Protection Bord (MS60)from M/S A wazel Industris K.S.A		Sample		(B)
		4 -Elastorooform M/S CMCI		Catalog		(C)
		5- Xypex		Catalog		(C)
		6- Waterstop		Sample		(C)

We certify that the material submitted here with have been reviewed and are in conformance with the contract material and specification s except as otherwise stated

Contractor : Date: 1/6/2010
 Received by OHA : Date:

Review comments:
 * Approved for waterproofing membrane 4mm and protection board 6mm Made in KSA
 * Submit other materials from as per Bahar and Bardawil
 * Refer to our letter for approving the subcontractor

OHA Discipline Eng. Date: 1-6-2010
 Resident Engineer : Date: 1-6-2010

AUB Discipline Date: 01/06/10
 S.Manager TFD Date:
 Received by Contractor Date:



Alternative Materials
Submittal



SALMIYA PARK PROJECT

TO : PROJACS
CC : SALMIYA GROUP; GULF CONSULT

PACKAGE NO. : 2 - STRUCTURAL WORKS DATE : 16-Feb-2009

CONTRACTOR : WARA CONSTRUCTION Co.


A: Approved
B: Approved As Noted
C: Not Approved
D: Information Noted

Submittal No. :	BP2/07/GN/MT/ALT/002	Revision.:	00
Submittal Title :	Waterproofing Membrane Sheet	Alternative	Substitute
Source :	Saudi Arabia	AWAZEL DS40200	
Supplier :	Awazel Kuwait Co. LTD		
Location of use :	All Buildings - Foundation (Water proofing works)		

Item No.	Dwgs, Specs, BOQ Ref.	Description	Type	Copies	Action
1	Document III-2	AWAZEL DS40200	CAT	5	
	Division-7	Waterproofing Membrane			"B"
	Section 07130				
2		AWAZEL DS40200	SM	3	
3		Technical / cost Comparison Sheets	OT	5	

* If the submitted material is an "ALTERNATIVE" or "SUBSTITUTE" material, then a "Specification & Comparison Sheet" shall be submitted along with the material submittal form.
* We certify that the materials submitted here with have been reviewed and are in conformance with the project drawings, specification, contract as otherwise stated.

Contractor's Representative: Mohamed Adel
Date: 16-Feb-2009



Review comments: "B" - APPROVED AS NOTED


Submit cost comparison sheet showing total cost saving associated with this submittal within 02 days of receipt in order to issue a negative variation.

..project engineer
- Sub-contractor (AWR)

SALMIYA PARK	
Copy to:	
PM	<input checked="" type="checkbox"/> Material Eng.
CM	<input type="checkbox"/> Site Eng.
Coord.	<input type="checkbox"/> Planner
S.Site	<input type="checkbox"/> Stores
QS	<input type="checkbox"/> Doc. Controller
BP-PM	<input checked="" type="checkbox"/>

Employer's Representative

PROJACS Project Manager
Date: 18/02/09



Received by: SALMIYA PARK
Date: 18, 2, 2009
3-10 PM

Date: 18 Feb 2009

Cinema Leisure Complex - Jahra




Materials Submittal

TO : OHA Engineering Consultant

cc :

CONTRACTOR : Kuwait Dynamics Limited for contracting Co.

DATE : 14-01-09

Submittal No. :	2	Revision.:	0
Submittal Title :	WATER PROOFING MATERIALS		
Item No.	Divgs. Spots B90 Ref.	Description	Type Codes
SM Sample MD Manufacturer's Data CT Certificate TT Tests GT Guarantee CAT Catalog OT Others			Action
	DIV.7	Manuf.:AWAZEL	
		AWAZEL PRIMER D41 (CAT +MD)	(B) (C) (S)
		AWAZEL MEMBRANE DS 40200 (CAT +MD +SM)	
		AWAZEL MEMBRANE SHIELD MS6 (CAT +MD +SM) MS6	
		ATTACHED: * COPARISON SHEET.	
		* PREVIUOS APPROVALS.	
We certify that the materials submitted here with have been reviewed and are in conformance with the contract drawings and specification s except as otherwise stated			
Contractor's Representative		Received:	
			
Date: 14-01-09		Date:	
Review comments: (B) Approved As Noted			
1) Manufacturer: Awazel is approved.			
2) Follow strictly manufacturer's Application instructions & recommendations.			
3) All site & Laboratory tests should be passed successfully.			
4) Submit 10 Years manufacturer's Warranty.			
5) submit 10 Years Guarantee effective from the substantial Completion of the project against Leaks & any other defects occurring in membrane water proofing works.			
6) Comply Fully with contract documents requirements			
			
Resident Engineer		OWNER	
Date: 15-1-2009		Date:	Received by Contractor:
			Date: 15-01-09

Distribution:

File

Other:

AL-BAHAR & BARDAWIL
P&CEG BLD IND CTG AC
25 DEC 2011
KUWAIT UNITED DEVELOPMENT
DATE:

ATTN : ENG. ZIAD

SITE TRANSMITTAL OF SHOP DRAWING, SAMPLES ETC.

Doc. Ref. No.	KUD/QMS/CMF-01
Revision No.	00
Page No.	

Project	Homaizi Group Offices - BP 2	Transmittal No.	TR/MA/001	Rev. No.	0
Project Manager	Kuwait United Development			Date	18.12.11
Supervision Consultant	Dar Saleh Al-Qalaf Engineering Consultants				
Contractor	NASA Construction General Trading & Contracting Co				
To	The Construction Manager				

WE ARE SENDING HERewith / UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW. (Delete as necessary)

Sr. No.	Drawing / Document Description	Drawing/ Document Reference	Type	**Submittal Code	***Action Code
1	Water proofing membrane D.S.40200 (Data Sheet)		MD	1	B
			SM		

Contractor PM		Date	19/12/2011	Received By		Date	20 DEC 2011
---------------	---	------	------------	-------------	--	------	-------------

Consultant to enter ACTION CODE and REMARKS

Received: 11:30am

Consultant's/ Project Director's Remarks : **APPROVED AS NOTED.**

REFER TO OUR LETTER

REF: LTR/08007/CS/KUD-005/SR DATED 22/12/2011




IN REPLY TO (NASA) CONTRACTOR LETTER

REF: NASA/IKFA/KUD-005/2011 DATED 18/12/2011

COPY OF OUR LETTER ATTACHED HERewith

RECEIVED
27 DEC 2011
 HOMAIZI GROUP OFFICER PROJ. SEC

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for performing and completing all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Resident Engineer		Date	22/12/2011
KUD Project Director	 (cm)	Date	22/12/2011
Received By Contractor		Date	24 DEC 2011

ACTION CODE and REMARKS


* Type	** Submittal Code	*** Action Code
SD Shop Drawing	1 Submitted for Approval	A Approved
SM Sample	2 Submitted for your information	B Approved As Noted
GT Guarantee		C Not Approved
MD Manufacturer's Data		D For Information
CT Certificates		
OT Others		

Distribution List

	Contractor	KUD Project Director	Consultant R.E.	Others
Original	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Copy Cc	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>



المعهد : شركة المنير العربي



الإستشاري : دار صالح للتقانات الإستشارية الهندسية



المقر : الرياض - حي النخيل - الرياض

SITE TRANSMITTAL of Shop Drawings, Materials, etc.


TRANSMITTAL NO: MT/DIV07/001

REV: 0001

PROJECT	REFERENCE	OWNER	CONTRACTOR

WE ARE SENDING HEREWITH / UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW.

ITEM NO.	DRW. SPEC. OR BOQ. REF	GENERAL DESCRIPTION AND REVISION DETAILS	TYPE +	COPIES	ACTION CODE *
	111-2) 07110/3 2.01.b	water proofing membrano Awazel Desert shield 40200 4 mm thick manufactured by arabian water proofing ind .co.saudi arabia sample & M.Dalready submitted in previous transmittal Rev(0)	MD&SM& OT	3	B



We certify that the items submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR: الشيخ طارق بن الشهابي
ENG. TARIQ A. AL-SHENHARY
 DATE: 20/11/2011

Received by SQC
 Date: _____

SQCS REMARKS:

① The material submitted is accepted from the technical point of view based on the comparison sheet attached to the submitted & new specs.


② Action (B) Al-Shehary
20-11-2011

Corrections or comments made relative to submittals during the review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

SQC RESIDENT ENGINEER: [Signature]
 DATE: 28/11/2011

RECEIVED BY CONTRACTOR:
 DATE: _____

* TYPE: SD: Shop Drawings SM: Sample GT: Guarantee MD: Manufacturer's Data CT: Certificates OT: Others	المهندس الإستشاري محمد طلعت محمد المهندس القيم دار صالح الإستشارات الهندسية مشروع نادي الجوهري بالرياض	* Action CODE A: Approved A: Approved as Noted C: Not Approved D: Further Information Required
---	---	--



PROJECT: Al-Salam Mall - Al-Salmiya
Block No.(19),Plot NO. (1A+1B)



المشروع: مجمع السلام للتجاري - المنطقة القطيفة
رقم 19 للقطعة رقم 1A+1B

Submittal No. **MT-CIVIL/001** رقم المرسلة Rev. **2** إصدار رقم: **2011/9/27** التاريخ
 TO: **KUWAIT ENGINEERING BUREAU** دار الكويت للهندسة
 CC: _____
 CONTRACTO: **SADEEM ALKUWAIT Gen. Trad. & Cont. Co.** شركة سعدم الكويت للتجارة العامة والمقاولات

A: Approved
 B: Approved As Noted
 BR: Approved As Noted & Re-Submit
 C: Not Approved
 D: For Information

SM Sample MD Manufacturer's Data CT Certificate TT Tests GT Guarantee CAT Catalog OT Others

Div . 07	Completion of Water proofing materials Documents				
Sec.07105	1-Resistance of material to Chemicals at under ground water material By Arabian Water proofing Industries (JASSEM A.YUSUF AL-NISF & CO) Later Ref : 2011/02/05 dated 27/09/2011				(B)

We certify that the materials submitted here with have been reviewed and are in conformance with the contract drawings and specification & except as otherwise stated
 نقر بأن المواد المقدمة أعلاه قد تم مراجعتها والتأكد من أنها مطابقة لمخططات ومستندات ومواصفات عقد المقاولات، عندما ما هو غير ذلك متصوص عليه

Contractor's Representative: [Signature] ممثل المقاول
 Date: 0.11/9/11 التاريخ
 Received: _____
 Date: _____ التاريخ

Review comments: ملاحظات
 معتمد على ملاحظات (B)
 إجراء اختيار المواد التي تتجسد في
 تعزيزها بنسبة من مواصفات الجوده للمنع ان هناك لتوريد للتوريد

OWNER: _____
 Resident Engineer: [Signature] المهندس المقيم
 Date: 3-10-2011 التاريخ
 Received by: [Signature] Contract: **SADEEM AL-KUWAIT**

Distribution: التوزيع المالك الاستشاري الملف

Date	Page	Act.	Info.	Sign	Date
1	Deputy PM				
2	Coordinator				
3	Planning Eng.				
4	ARL Eng.				
5	Site Eng.				
6	Yusef Al Ghan.				
7	Planning Cont.				
8	Mirco				
9	Abra Al Mut.				

تأريخ
 + جاسم ليمان
 11/9/11

SAMPLE TAG



TRANSMITTAL NO : 01 REV 0 DATE : 11/09/2011

CONTRACT NO :

CONTRACTOR : Sadeem Al-kuwait

SAMPLE DESCRIPTION :
Awazel Waterproofing Membrane DS40200

SPECIFICATION / CPM REFERENCE :
Div : 07 - Sec : 07105

CONTRACTOR'S SIGNATURE :   شركة سديم الكويت
للتجارة العامة والمقاولات ذ.م.م
Tel.: 1825825 - Fax : 22252649

TO BE FILLED

BY CONTRACTOR

Project: AL-Salam Mall				
SADEEM AL-KUWAIT				
Sr.	Post.	Act.	Info.	Sign/Date
1	Deputy P.M			
2	Coordinator			
3	Planning Eng.			
4	Arch. Eng.			
5	Site Eng.			
6	Yusef Al-Ghan.			
7	Planning Cont.			
8	Miroc			
9	Abra Al-Had.			
10	SAKALO			
11	File			

A

B


BR


Approved

TO BE FILLED

BY RE

CLIENT / RE SIGNATURE

Date : 
3-10-2011





الائتلاف الوطني للعقارات
National Union of Real Estate Co.
شركة التقيين المتحدة العقارية

التاريخ: ٢٣ - مارس - 2011
إشرفنا: م.ش / ن.هـ / 669/2011/296

المحترمين،،،،
المحترم،،،،

السادة / شركة المدير الكويتي
المهندس / محمود ريشة
(مدير المشروع)

تحية طيبة وبعد،،،

المشروع: إنشاء وتجيز وصيانة معرض السيارات المستعملة - الشويخ - قسيمة رقم (150)
ملك السادة / بيت التمويل الكويتي

الموضوع: نتائج إختبارات مواد عزل الرطوبة

بالإشارة إلى الموضوع أعلاه ، وبناء على كتاب الإستشاري إشارة (م.د.ن.ن/150/227/2011) (مرفق)

نحيطكم علما أنه لا ملاح لدينا من اعتماد مادة عوازل كمصدر أول لأعمال عزل الرطوبة بالمشروع .

هذا لتعلم وإتخاذ اللازم،،،

وتفضلوا بقبول فائق الاحترام،،،

ممثل المالك

م / محمد طه

البريد الإلكتروني: info@nur.com.kw
- صورة: م / هشام القايح - شركة التمويل العقارية
- م / عيسى تويج - دار الكويت للاستشارات العقارية

SUBMITTAL FOR APPROVAL OF MATERIALS

SUB NO: 48 MT

Date: 25/01/2011

1. MATERIAL DESCRIPTION (one Item only on this form)

Awazel desert shield 40200 (Awazel Ds40200)

Awazel primer - D 41

Area of Application: _____

Drawing Ref. : _____

B.O.Q.Ref.NO. : _____

Specification Ref. : _____

Standards: _____

Attach all relevant technical literature marked to identify relevant description, current Test Certificates as appropriate.

2. MANUFACTURER/ SUPPLIER:

Company Name **AWAZEL KUWAIT CO. LTD**

Address _____

local Agent _____

Country of Origin : _____

Availability


Locally Manufactured

Delivery

Ex-works/ Total Duration _____
Estimated Time of Arrival on Site _____

Program

Date Material Required on Site _____
Latest date for Order _____



We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specification except as otherwise stated. Also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

SubContractor Manager Signature : _____

Received by : _____

Date : 25/01/2011

Contractor Manager

Signature : _____

Received by : _____

Date :/...../.....

4. CONSULTANT'S REPRESENTATIVE'S COMMENTS :

Awazel DS Membrane 40200
are approved subject to use
Awazel primer as manufactured
by Awazel main instructions
(primer D-41)

Approved

Approved As Noted
revise and Resubmit

Rejected

Sample Required

Tests Required

Additional Information Required

Manufacture's Guarantee Required



Signature: _____

Date: _____

Received by: _____

Date: _____

Approval shall not relieve contractor of his liabilities under the contract or constitute authorization of any change to contract documents

Owner:  EMKE GROUP	PROJECT:  LULU HYPERMARKET DAJEEJ - KUWAIT	Consultant Bureau: دار الفاروقى للاستشارات الهندسية AL-FAROOQI Engineering Consultants Bureau كويت - صفا - شارع أبو بكر الصديق - برج الفاروقى - مبنى 100 - طابق 10 - صفا - الكويت P.O. Box: 115588 - Safat - Kuwait info@al-farooqi.com
---	--	--

SUBMITTAL FOR APPROVAL OF MATERIALS

CONSULTANT Al Farooqi Engineering Consultant Bureau	Date 3 0 0 6 2 0 1 0
CONTRACTOR AL Hamara Co. W.L.L	Ref LULU 2010 001

1. MATERIAL DESCRIPTION (one item only on this form) :
Awazel Water Proofing DS 40200 4mm Thk

Area of Application :

Drawing Ref. :	B.O.Q. Ref. No. :
Specification Ref. :	Standards :

M.D Certificates Tests Mock Up Sample Method of Statement Report

2. MANUFACTURER/SUPPLIER :

Company Name : _____

Address : _____

Local Agent : _____

3. DELIVERY :

Country of Origin : _____

Availability

<input type="checkbox"/> Locally Manufactured	<input checked="" type="checkbox"/> Over Seas
---	---



C . Program :

Ex-works/ Total Duration	[]	[]
Estimated Time of Arrival on Site	[]	[]
Date Material Required on Site	[]	[]
Latest Date for Order	[]	[]

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

<p><i>APPROVED as a source</i></p> <p><i>submit method of statement</i></p> <p><i>Mock up should be done before execution</i></p> <p><i>coordinate with all other trades</i></p> <p><i>comply with all contract documents</i></p>	<input type="checkbox"/> Approved
	<input checked="" type="checkbox"/> Approved As Noted
	<input type="checkbox"/> Revise & Resubmit
	<input type="checkbox"/> Rejected
	<input type="checkbox"/> Sample Required
	<input type="checkbox"/> Tests Required
<input type="checkbox"/> Additional Information Required	
<input type="checkbox"/> Manufacturer's Guarantee Required	

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents

CONSULTANT	Eng / <i>Hussain Jawad</i>	Signature 	Date 6-7-10
CONTRACTOR	Eng / <i>ESSA.M.NASARAH</i>	Signature 	Date 6.7.10

BAYAN PALACE PHASE II

DESIGN, CONSTRUCTION, MAINTENANCE OF MEDIA CENTER BUILDING
AND REFURBISHMENT OF LIBERATION HALL FOR AFRICAN CONFERENCES AT BAYAN PALACE

M/S: AL - HANI CONSTRUCTION & TRADING CO - DESIGN BUILDER

TRANSMISSION OF MATERIAL FOR APPROVAL

CONTRACT: CONTRACT NO. AD/H/82

TO: The Associated Engineering Partnership (TAEP)

WE ARE SENDING HERewith
DOCUMENTS

Transmittal No.	Rev.
MAT-05 CIVIL	0
DATE: 30/03/2013	
SUBMITTED FOR	CODE
APPROVAL	1
YOUR INFORMATION	2
ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
INFORMATION	D

QTY	DWGS. SPEC. OR BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	*TYPE	CODE	
					Submittal ¹	Action ²
			MEDIA CENTER			
			APPROVAL FOR MATERIAL			
3	07130	1	DESERT SHEILD 40200- 4mm THICK 200gms POLYSTER	MD	1	B
			SUPPLIER: M/S. AWAZEL INDUSTRIES, K.S.A			
			ATTACHED: CATALOGUE & PREVIOUS APPROVALS			

AL HANI CONSTRUCTION & TRADING CO.
P.M.
DATE 30.03.2013

Received by TAEP
Date:

The Associated Engineering Partnership (TAEP) Action:

A B C D

COMMENTS:

Approved as noted subject to:-

-) submit sample for study & action.
-) comply with manufacturer instructions (installation, precautions, storage, --- ets).
-) All site work according to the approved drawings.
-) Comply with contract documents & specifications requirements
-) A 10 years warranty must be submitted from the date of substantial completion.
-) submit test certificates.
-) Flood the roof to a depth of at least 25mm and leave for 48 hours.

R. E.
[Signature]
CC: AMIRI DIWAN
7-4-2013

1 Code to be entered by M/s Al Hani Construction & Trading Co.
2 Code to be entered by TAEP

* TYPE: AB- As Built Drawing MD - Manufacturer's Data
SM - Sample CT - Certificates
GT - Guarantee OT - Other
SD - Shop drawings DD - Developed Design

M/s. Al-Hani Construction & Trad. Co.

Date: May/10/2010

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES, ETC.

SUBMITTED FOR	CODE
APPROVAL	1
YOUR INFORMATION	2

CONTRACT: CONTRACT NO. SPA/159/01

ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
	D

TO: K.E.G
DESIGN CONSULTANT


WE ARE SENDING HERewith DOCUMENTS /DRAWINGS LISTED BELOW.

QTY	DWGS., SPEC. OR BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	*TYPE	CODE	
					Submittal ¹	Action ²
3	07130 2.02-B,C,D		Sheet Membrane Waterproofing	SM/MD CT/OT	1	A
		1	Awazel desert shield " DS40200 " 4mm thick bituminous membrane			
		2	Awazel Primer- D41 Primer for bitumen sheet mambrane			
		3	Awazel membrane shield "MS-60" 6mm thick bituminous protection board			
			Manufacturer : Arabian waterproofing Ind.Co. Riyad, KSA			
			As Specified			
			Subcontractor : Jassem A. Yusuf Al-Nisf & Co. Attached; Samples, Technical data, Approvals Test certificates			
				PROJECT MANAGER - DESIGN BUILDER	Received by K.E.G Date:	

K.E.G. Design Consultant to Enter Action Codes and Remarks, and Return to Design Builder

REMARKS:

approved



الجمهورية العربية السورية
Kuwait Engineering Group

Corrections or comments made relative to submittals during this review do not relieve the Design Builder from compliance with the requirements of the Contract. This check is only review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The Design Builder is responsible for confirming and correlating the design, all quantities and dimensions, selecting fabrication processes and techniques of construction; coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

COPIES TO

MPW
MPW - PE
Received by Design Builder

DATE: DATE:

Code to be entered by Design Builder
Code to be entered by K.E.G Design Consultant

SM - Sample CT - Certificates
GT - Guarante OT - Other

RECEIVED
02 JUN 2010
Am... 12.30

مشروع تطوير وتحديث مبنى الاستقبال الرئيسي بمنزلة الخيران السياحي

المالك : شركة المشروعات السياحية

طلب تقديم عينات ومواد

المقاول : مؤسسة البيت المعماري

عينة

ككتوج / رسومات

رقم طلب التقديم ١١

رقم التقديم السابق

التاريخ : ١٩/٩/٢٠٠٨

مراجعة رقم :

التاريخ :

ملاحظات	مكان الاستخدام	المرجع حسب المواصفات وجداول الكميات	التكولوج أو الرسومات	المصدر / المبدأ	عدد العينات	وصف المادة
	مبنى الاستقبال	اصال المزلن	مرفق عينات + كتالوجات	شركة النقبية لأعمال المزلن	1	عينات حلاق
<p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p> <p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p> <p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p>						
<p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p> <p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p> <p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p>						
<p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p> <p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p> <p>ملاحظة: يرجى إرسال العينات قبل تقديم الطلب.</p>						

ملحوظة: اعمد العينة لإعطي المقاول من التزلزله التقنيه الأخرى ووجب تقديم الكتلوج الأصلي + عند (٧) نسخة عدد كل طلب .
 • يسلم الأصل للمالك - نسخة لي (المقاول)

BAYT ABDULLAH – HOSPICE FOR CHILDREN

SITE TRANSMITTAL

of Shop Drawings, Materials etc.

Contractor : **Ahmadiyah Contracting & Trading Co.**

To : **Gulf Consult**

Transmittal No. : **ACT/BA/TR/MD/003**

Rev. **0**

WE ARE SUBMITTING HEREWITH/UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW (Delete as necessary)

ITEM No.	DRW., SPEC. OR BOQ. REF	GENERAL DESCRIPTION AND REVISION DETAILS IF ANY	TYPE +	COPIES	ACTION CODE *
1		<u>Product Data of Sub contractor –</u> Technical International Co. for Waterproofing Works for your review, comment & approval. 1. Bituminous Protective Paint (Awazel Primer D41) 2. 6 mm thick Protection Board 3. 4 mm thick Waterproofing Membrane (Awazel Desert Shield 40200)	Catalogue	1	A

BAYT ABDULLAH
 Hospice for Children

2:07
 17/05/08 12:15
Gulf Consult
RECEIVED

Contractor : *M. Iqbal*
15/5/08

Received by GC :

Date : 17.05.2008

Date :

GC'S REMARKS :

APPROVED

RAP
19/05/08

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.


GC Representative : *gll*

Received by Contractor :

Date : 19.05.08

Date :

<p>+ TYPE :</p> <p>SD : Shop Drawings SM : Sample GT : Guarantee MD : Manufacturer's Data CT : Certificates OT : Others</p>	<p>* ACTION CODE :</p> <p><input type="checkbox"/> A : <u>Approved</u> <input type="checkbox"/> B : Approved as Noted <input type="checkbox"/> C : Revise & Resubmit <input type="checkbox"/> D : Not Approved / Resubmit</p>
---	---



Our Ref: 440/08/KCMC/WF-rs(L)
 Date: 01st April 2008

Sayed Hamid Behbehani & Sons Co. W.L.L
P.O. Box: 3065
Safat – Kuwait

Attn: Mr. Muntasir Abu Omar
Project Manager

Project: Contract No. 16-KASP-07/08
KUWAIT CONTROL & METEOROLOGICAL CENTER (K.C.M.C.)

Subject: Awazel DS40200 as a Water Proof Membrane
Manufacturer: M/s Awazel Kuwait Co. Ltd.
Submittal No. 0048

Dear Sir,

We have reviewed your Submittal No. 0048 and inform you of our review results as follows:

Submittal: Awazel DS40200 as a Water Proof Membrane.


Received: 16th March 2008

Approval Status: **Approved as noted.**

Action required
 by Contractor: Re-submittal required

Engineer's Remarks: Please see the attached Submittal Approval Form.

Project Name : KCMC Project A/C 970	
Best Regards,	Coordinator
<i>W. Faulkner</i>	Planner
RG	Q.S
DM	Safety Officer
TM	Surveyor
CM	HVAC
William Faulkner	PLUMBING
Project Manager	ELECTRICAL
FOREMAN	



Encl: As stated above

CC: DGCA - Planning & Control Department
Mr. Mohamed Ahmed Ali – Team Leader KCMC



Planning & Control Department
Control Center Project

إدارة التخطيط والمتابعة
مشروع مركز التحكم

Date : 31 March, 2008.

Ref : DGCA/B2000/Stanley/SUB/667.0/08

Stanley Consultants Inc./JQEC,
P.O. Box 3789
Safat, 13038,
Kuwait.

Attention : Mr. William Faulkner – Project Manager

Cc : Mr. Ali Johar – DGCA-DE (Construction Department)

Subject: Contract No. 16-KASP-07/08
Kuwait Control and Meteorological Center (KCMC)
Awazel DS40200 as a Water Proof Membrane
Manufacturer: M/s. Awazel Kuwait Co. Ltd.
Submittal No. 0048

Dear Sirs,

With reference to your letter No. 353/08/KCMC/WF-rs(L) dated 19th March, 2008, regarding the above subject, enclosed please find the Original Submittal Approval Form No. 0048 dated 16.3.2008, duly signed by DGCA, for your necessary action.

Yours faithfully,

Director of Planning and Control Department




Abbas Jasem

Encl: As stated above.



SUBMITTAL APPROVAL FORM

Received by



DGCA DE Stamp

CONTRACT: 16-KASP-07/08

Transmittal No.: 0048

DESCRIPTION: Awazel DS40200
 As a water proofing membrane

Submittal No.: 0048

CONTRACT REFERENCE:
 (Drawing No./Spec's Reference)

Submittal Rev.: 00

Deviation from Contract: YES NO

APPROVAL STATUS

	Consultant/Engineer SC/JQCE initials/date	DGCA Planning initials/date	DGCA DE initials/date
Approved	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Approved as noted * resubmittal required	<input checked="" type="checkbox"/> <i>[Signature]</i> 19.3.08	<input type="checkbox"/>	<input checked="" type="checkbox"/> <i>A.J./27.3.08</i>
Rejected *	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
For Information Only	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Returned due to incomplete information	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REMARKS: *As per attached sheet*

* For additional comments see attached page(s)

DGCA CCPM


Approved Approved as noted Rejected


Signature: *[Signature]* Date: *30/3/08*

This approval status shall be interpreted as stated in the contract and shall not relieve the Contractor from his contractual obligations.

Kuwait Airspace System Plan
Kuwait Control & Meteorological Center (KCMC)
SUBMITTAL APPROVAL FORM

REMARKS:

1. Samples submitted along with Transmittal should be identified by Transmittal No. and signed by Contractor's Representative.
 2. D.S 40200 Manufactured by Awazel Company is approved and subject to tests when delivered to site.
 3. Contractor to provide Guarantee Certificate for 10 years as stated in Specifications.
- 



استشارات الجزيرة Al-Jazera Consultants

ARCHITECTS - PLANNERS - ENGINEERS
AHMAD AWAD AL-JIHAYEM - ARCH

مهندسون - مخططون - معماريون
أحمد عوض الجهيم - معماري

Ref.

Date :

الإشارة :
أش / 08/269
التاريخ :
2008/2/20

المحترم السيد المهندس / يحيى الغندور

تحية طيبة وبعد ...

المشروع: إنشاء وإجاز وصيانة فيلا السيد / منصور سالم النصار

بمنطقة اليرموك قطعة (3) - قسيمة (435)

الموضوع: مقال أعمال عازل الرطوبة للمشروع


بالإشارة إلى الموضوع أعلاه ومن خلال مراجعة مرفقات كتابكم رقم (MUSR-3) بتاريخ 2008/2/20 نفيديكم بأنه لا مانع من اعتماد السادة/ الشركة التقنية الدولية لأنظمة العزل لأعمال هذه الفيلا فقط.


شريطة التقيد بمواصفات وشروط العقد وتعليمات المهندس المشرف أثناء تنفيذ أعمال العقد أعلاه. وكذلك نفيديكم بأنه لا مانع لدينا من اعتماد مادة عازل الرطوبة AWAZEL DS MEMBRANES- DS40200 طبقا للمواصفات الفنية وتعليمات الجهاز المشرف بالمشروع.

يطلب تقديم مادة ألواح الحماية المطلوبة للإعتماد من نفس المصدر سماكة 6MM

وتفضلوا بقبول فائق الإحترام

دار استشارات الجزيرة


م. مسعد فتح الله


الملك العام / الإشراف / الموقع



Ref.

الرقم 9 / 118

Date

التاريخ 17/12/07

المحترمين

السادة | شركة 26 فبراير للمقاولات الإنشائية

تحية طيبة وبعد،،،

الموضوع: مقدار رقم 41/2007-2008
تصميم وإنشاء وإنجاز وصيانة خزانات
مياه ومنشآت الري بالشويخ

إشارة إلى الموضوع أعلاه .. وإلى كتابكم رقم 26ف/ج/3/2007 بتاريخ
2007/12/2 ، نفيديكم بأنه لآمانع لدينا من إعتداد مصادر المواد أدناه حسب
الآتي :-

- عازل طربال سعودي 4 مم شركة عوازل .
 - مانع تسرب (Ecj-250mm) Water Stop شركة البحر والبردويل .
 - صبغ أيبوكسي للعزل الداخلي (RE2005) شركة البحر والبردويل .
 - حديد تسليح (كويتي - سعودي) .
- وعليكم تقديم المواد للفحص عند التوريد وكفالة العازل حسب ماجاء بمستندات
العقد .

وتفضلوا بقبول فائق الإحترام ،،،

عن أمين عام الجامعة

16/12/07

الندوة القاني
مدير إدارة الإنشاءات والصيانة

م. 1/ع



Bader Al Mulla & Brothers Co. W.L.L.
Engineering Group
Civil Construction

Kuwait University
Construction Program
Major Projects Division



TRANSMITTAL OF MATERIAL, DRAWING, DOCUMENTS, SAMPLES ETC

Transmittal No. 01-039-0	
Rev. :	0
Date :	4-Jun-07
SUBMITTED FOR	CODE
APPROVAL	
YOUR INFORMATION	
Review & comments	✓
ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
	D

Design - Build Gate Houses, gates and
ence for Shuwaikh Campus

Contract No. KUCP-MPA/T-14/05-06

A/E M/S SOOR ENGINEERING BUREAU

ARE SENDING HERewith THE FOLLOWING DOCUMENTS THAT COMPLY WITH THE CONTRACT DOCUMENTS

QTY.	DRWS. SPEC. OR BOQ. REF.	ITEMS SEQ NUMBER	DESCRIPTION	TYPE	CODE	
					Submittal	Action
4	7115/2.02		Material Submittal for water proofing membrane (DS 40200)	OT	3	
			Manufacturer: AWAZEL Co., Saudi Arabia			
			Local supplier M/s Khajah Group			
			Attachment:			
			a) Product Data			
			b) Previous Approvals			
			c) Test Certificate			
			d) Sample			
Copies TO:						
UCP (The Engineer)						
UC (Site Engineer)						
			FOR CONTRACTOR	<i>[Signature]</i>		

IE to enter Action Codes and Remarks, and return to the contractor

REMARKS: Action B :- Approved as Noted

* Manufacturer AWAZEL Co., are Approved.

* Contractor to submit sample to test (membrane DS 40200)

* Deliver materials in original, unopened containers

* Store materials except in dry area and protect from water & direct sunlight.

rections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Copies TO:

UCP (The Engineer) - Transmittal Cover Only

UCP (Site Engineer)

VE Adnan Alahmad

FOR A/E

DATE: 10-6-07

TYPE: SD - Shop Drawings SM - Sample GT - Guarantee OT - Others
MD - Manufacturer's Data CT - Certificate

MATERIAL APPROVAL SUBMITTAL (MAS)

Project : AMAL AL KHALID	Contractor : First United Company
Owner's Rep : Mrs. Amal Ahmad Saoud al-khalid	Date : 4-4-2007
Consultant :	Reference : WATERPROOFING MEMBRANE

Proposed Material : MEMBRANE AWAZEL- DS40200 (TH:4MM) BITUMINOUS APP MEMBRANES REINFORCED WITH NON WOVEN POLYESTER MAT 200GM/M2 -ROLL SIZE 10*1-NORMAL UNITE WEIGHT(PLAIN), 4 KG/M2

Specified Manufacturers / Origin / Suppliers (1)...WATERPROOFING -MEMBRANE PROVIDE&APPLY WATERPROOFING MEMBRANE IMI DOUBLE LAYER WITH 5 CM TH PROTECTION SCREED AS PER DRAWINGS AND SPECIFIED UNDER RAFT FOUNDATION OR WITH 6MM TH PROTECTION BOARDS TO RETAINING WALL SURFACES AS PER DRW AS PER SPECIFIED	Proposed Manufacturer / Origin / Supplier DS MEMBRANES AWAZEL DS40200-المملكة العربية السعودية
	Drawing Ref. : SHEET NO 05 R3
	BOQ Ref. : DIV-7 B CIVIL WORKS/5/R
Specs. Ref. : SECTION 07110 2/4 PART 2-PRODUCT	CPM Ref. : BFD070120

Attachments [Tick as appropriate]

Catalogue <input type="checkbox"/>	Samples <input type="checkbox"/>	Test Certificates(old) <input checked="" type="checkbox"/>
------------------------------------	----------------------------------	--

Submitted by Contractor :	Date & Time : 5-4-2007
Received By Engineer :	Date & Time :

RE TO FILL	APPROVED <input checked="" type="checkbox"/>	APP. WITH COMMENTS <input type="checkbox"/>	REJECTED <input type="checkbox"/>
------------	--	---	-----------------------------------

RE's Remarks :

لا يمكن منح مع ضرورة العرض المزمع لغيره بالتنسيق مع اللجنة المختصة
 في المرفق بالرجوع إلى Sec. 07110 2/4

Distribution :	Issued By :	Received By :								
<table style="width: 100%;"> <tr> <td style="width: 50%;">Original</td> <td style="width: 50%;">Copy</td> </tr> <tr> <td>Owner's Representative <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Resident Engineer <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Contractor <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> </table>	Original	Copy	Owner's Representative <input type="checkbox"/>	<input checked="" type="checkbox"/>	Resident Engineer <input checked="" type="checkbox"/>	<input type="checkbox"/>	Contractor <input type="checkbox"/>	<input checked="" type="checkbox"/>	RE's Signature Date & Time 04/04/2007	Contractor's Signature Date & Time 04/04/2007
Original	Copy									
Owner's Representative <input type="checkbox"/>	<input checked="" type="checkbox"/>									
Resident Engineer <input checked="" type="checkbox"/>	<input type="checkbox"/>									
Contractor <input type="checkbox"/>	<input checked="" type="checkbox"/>									

**ABYAT MEGASTORE IN SHUWAIKH
TRANSMITTAL - MATERIAL**

CONTRACTOR : Ahmadiyah Contracting & Trading Co.
 SUBCONTRACTOR : _____
 CONSULTANT : OHA Engineering Consultant
 SUBJECT : Thermal & Moisture Protection.

TANS. No. 07105.004

REVISION (0)

DATE 14.03.2007

Item No.	Dwgs, Specs. BOQ Ref.	Description	Type**	Copies	Action*
	Page No.	Water Proofing Membrane for Slabs/Walls			
	III-4/7-1	Thickness = 4 mm	MD	2	(B)
		Type - DS 40200 Membrane	SM	2	
		Comparison sheet for specified/proposed attached.	OT	2	
		Manufacturer: M/s. Awazel, K.S.A.			

****Types:**

MD Manufacturer Data	CT Certificate	D Documents	CCS Contractor Construction Schedule
SD Shop Drawings	MPL Material Procurement Log	PL Proposals	PMT Payment
MS Method Statement	SL Submittal Log	INS Insurance	MR Monthly Report
GT Guarantee	MM Minutes of Meeting	OT Others	SM Sample

Project Manager: _____
 Date: _____

Shihab

Received By: _____
 Date: _____

view comments:

(B) APPROVED AS NOTED

- * water proofing membrane Type - DS 40200 is approved.
- * Manufacturer M/s. Awazel is approved.
- * you are requested to provide 15 years manufacturer's warranty.
- * You are requested to submit a 10 years guarantee effective from the date of substantial completion of the works against leaks occurring in membrane waterproofing works.
- * water proofing membrane should be executed by an approved Specialist Sub Contractor "To be Submitted for approval".

Resident Engineer _____
 OR
 Construction Manager _____
 Owner Representative _____
 Received By Contractor : *Saxo*

Date : 15/03/2007

Date : _____

Date : 17/03/2007

Date : 17/3/2007

***ACTION CODE:**

A: Approved
 B: Approved As Noted
 C: Not Approved
 D: Information Noted
 N: Review Not Required



SITE TRANSMITTAL of
Shop Drawings, Materials, etc.

TRANSMITTAL NO: 10
REV: 2

PROJECT Investment Dept. Tower	DIV/PACKAGE Parking	OWNER Investment Dept.	CONTRACTOR Neratic Cons. Co.
-----------------------------------	------------------------	---------------------------	---------------------------------

WE ARE SENDING HEREWITH

ITEM NO.	DRW., SPEC. OR BOQ. REF.	GENERAL DESCRIPTION AND REVISION DETAILS	TYPE +	COPIES	ACTION CODE *
1	DIV.7	Awazel DS 40200, Water Proofing Membrane	MD+SM	1	"B"

We certify that the items submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR: [Signature]
DATE: 1/18/2006

RECEIVED BY KEO: [Signature] 2:19pm
DATE: 01/18/06

KEO'S REMARKS:

*Approved as noted
water proofing membrane Awazel DS 40200 is approved
subject to compliance of the specification and the
written instruction of the manufacturer.
Submit another sample for documentation.*

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept

KEO RESIDENT ENGINEER: [Signature]
DATE: _____

RECEIVED BY CONTRACTOR: [Signature]
DATE: 2/18/2006

GGED [Stamp]	+ TYPE: SD: Shop Drawings	* ACTION CODE:
	SM: Sample	A: Approved
	GT: Guarantee	B: Approved as Noted
	MD: Manufacturer's Data	C: Not Approved
	CT: Certificates	D: Further Information Required
	OT: Others	



360° Kuwait Project



SUBMITTAL FORM MATERIALS

CONSULTANT : OHA ENGINEERING CONSULTANT
 CONTRACTOR : AHMADIAH CONTRACTING & TRADING CO.
 BID PACK No. :

Sub. No.: ACTC/MS/OHA/004 Rev. 0
 Date:
 Div./Section:
 Expected Reply:

To : The Engineer's Representative

We request approval of the following: **Waterproofing Membrane (AWAZEL DS 40 200) & Bituminous Protection Board (Membrane Shield MS60)**

SM: Sample MD: Manufacturer's Data CT: Certificate TT: Tests GT: Guarantee Cat: Catalogue OT: Others SD: Shop Drawing


Item No.	Dwg. No./BOQ	Item Description	Type	Copies	Action Code
1		Manufacturer's pre-qualification documents & Test Results		2	A
2		Technical Data Sheet for AWAZEL DS 40 200		2	B
3		Technical Data Sheet for Membrane Shield MS60		2	B
4		Comparison sheet of Awazel DS 40 200 & Bituplus P4200		2	A
5		Method statement for installation of waterproofing membrane R1		2	D
6		Shop drawing for Basement waterproofing Rev. 1		2	D
7		Samples of Awazel DS 40 200		2 Nos.	✓ A
8		Samples of Membrane Shield MS60		2 Nos.	A

Manufacturer : AWAZEL, Kingdom of Saudi Arabia

Details of information, catalogue cuts and the like attached are:

SAMPLES Enclose Submitted under separate cover Not Applicable

Contractor's Representative: [Signature]
 Date: 08/04/06




Engineer's Rep. Remarks: Refer to attached sheet

Engineer's Representative Signature: [Signature]
 Date: 10/4/06

Received by Contractor:
 Date:

** ACTION CODE :
 A. Approved B. Approved as Noted C. Revise & Resubmit D. Rejected

CC:



AHMADIAH 360 Kuwait Project		
Distribution	Action	Information
ACTC rep.		
P. Engr.		
Tech. Engr.		✓
C. Engr.		✓
Project Archt.		
Procur. Engr.		
Senior QS		
QA/QC		Form No. ACTC-08
Planner		
Safety		



360° Kuwait Project



SUBMITTAL FORM MATERIALS

CONSULTANT : OHA ENGINEERING CONSULTANT
 CONTRACTOR : AHMADIAH CONTRACTING & TRADING CO.
 BID PACK No. :

Sub. No. ACTC/MS/OHA/005 Rev. 0
 Date: 19th April 2006
 Div./Section:
 Expected Reply:

To : The Engineer's Representative

We request approval of the following:

SM: Sample MD: Manufacturer's Data CT: Certificate TT: Tests GT: Guarantee Cat: Catalogue OT: Others


Item No.	Dwg. No./ BOQ	Item Description	Type	Copies	Action Code
1		Inspection & Test Plan for Waterproofing - Rev. 01 - Application of Membrane (incorporating your comments).			A

Note : Inspection & Test Plan for waterproofing - Rev. 0, was submitted with our Transmittal No. ACTC/360/OHA/043/06 and was returned with some comments. The comments are incorporated and re-submitted herewith for approval.

SAMPLES
 Enclose Submitted under separate cover Not Applicable

For Ahmadiyah Contracting & Trading Co. [Signature]
 Date: April 19, 06

Received by Engineer :
 Date: 19 APR 2006



Engineer's Rep. Remarks:
Approved

Engineer's Representative Signature : [Signature]
 Date: 21/6/06

Received by Contractor :
 Date: 21/6/06

ACTION CODE :
 A. Approved B. Approved as Noted C. Revise & Resubmit D. Rejected

CC:

RECEIVED
 08 JUN 2006
2:10 pm

360 Kuwait Project	
Distribution	Action Information
ACTC rep.	
P Mgr.	
Team Mgr.	
C Mgr.	
Project Arch.	
Procur. Eng.	
Senior QS	
QA/QC	Form No. ACTC-08
Planner	
Safety	



KUWAIT UNITED DEVELOPMENT

SITE TRANSMITTAL of Shop Drawings, Samples, etc.

PROJECT : SHAAB TOWERS
CONTRACTOR : SAI GEN. TRAD. & CONT. CO.
TO : KUD Project Manager

TRANSMITTAL NO. 11 REV. 1

WE ARE SENDING HERewith / UNDER SEPARATE COVER, THE DRAWINGS/DOCUMENTS/
SAMPLES LISTED BELOW.

ITEM NO.	DRW. SPEC. OR BOQ. REF	DESCRIPTION	TYPE +	SUBMITTAL CODE *	ACTION CODE **
		Waterproofing materials fabricator (by ANAZEL Saudia)			
1	Section 071 10	Waterproofing Membrane-DS 40 200 (Samples & Catalogue)	SM	1	B
2		Protection Board - MS 60 (Samples & Catalogue)	SM	1	B
3		Bitumen Paint - D 41 (Catalogue)	SM	1	B
4		Waterproofing team of Sai Gen. Trad. & Cont. Co. will execute the above work.	OT	2	B

CONTRACTOR : _____
RECEIVED BY : _____

DATE : 6th March, 2006
DATE : _____

Consultant to enter ACTION CODE and REMARKS

Project Management
Consultant Remarks :

Follow project specifications for workmanship.

Initials [Signature] Date 13/03/06

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for continuing and covering all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Consultant Resident Engineer [Signature]
RECEIVED BY CONTRACTOR : _____

DATE : 13/3/06
DATE : _____

cc: **[KUD PROJECT MANAGER]**

+ TYPE: SD: Shop Drawings SM: Sample GT: Guarantee MD: Manufacturer's Data CT: Certificates OT: Others ✓	* SUBMITTAL CODE: 1: Submitted for Approval ✓ 2: Submitted for your information ✓ 3:	** ACTION CODE: A: Approved B: Approved as Noted C: Not Approved D: For Information
---	---	---

If KUD PM is resident then no need of cc to PM while submittal

Note: - KUD PM has to initial acknowledgement when the ST is submitted by the contractor to the
and likewise when ST is processed by RE and prior to issue to contractor

Distribution : Original CONTRACTOR Copy KUD P.M Copy CONSULTANT R.E

**DIVIDED ZONE AGREEMENTS & KUWAIT ISLANDS AND MEGA PROJECTS
DEVELOPMENT TEAM
AL-KHIRAN NEW TOWN INFRASTRUCTURE WORKS**

TRANSMITTAL SHEET

Shop Drawing

Material

Others

Consultant : **M/s. Jassim Qabazard Engineering Consultants.**
 Contractor : **Mohammed Abdulmohsin Al-Kharafi and Sons W.L.L.**
 Contract : **Construction Completion & Maintenance. Bulk Earth, Road, Landscaping, PSTP, Main Transformer Sub-Station, UG & OH Cable, Fresh Water, Tower water Main and Pump (Tender No 1/7002)**
 TO : **SITE OFFICE**

TRANSMITTAL NO. 148 - Rev. 0

DATE: 20th February 2005

SUBMITTED FOR	CODE*
APPROVAL	1
FOR INFORMATION	2

WE ARE SENDING HERewith / UNDER SPARATE COVER, THE DRAWINGS/DOCUMENTS/SAMPLES LISTED BELOW.
(DELETE AS NECESSARY)

ACTION	
APPROVED	A
APPROVED AS NOTED	B
NOT APPROVED	C
FOR INFORMATION	D

No. of Pages	DRAWING SPECIFIC SWS OR SWS REF.	ITEM SEQ NO.	DESCRIPTION	TYPE	CODE**	
					Submittal	Action
	SM 5		Exterior Membrane Water Proofing DS Membranes (DS-4200)	MT	1	
	Sec. 2		Manufacture by: ANAZEL, K.S.A.			
	Sections		Attachments:			
	And		- Previous Approvals			
	Modules		- Technical Data			
			- Test Result Certificates			
			- Sample			

COPIES: 3 copies

Eng. Ferook Al-Madi

Project Manager

FOR CONTRACTOR: NAME POSITION

RE to enter Action Codes and Remarks, and return to Contractor
REMARKS:

** Approval is subject to the following
Satisfactory laboratory testing of sample to be carried out
in presence of CCC in accordance with General specification*

(STATUS "B")

APPROVED AS SOURCE ONLY.

Contractor or manufacturer shall be responsible for and retain the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general compliance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and controlling all quantities and dimensions including fabrication processes and techniques of construction commencing from the start of the work, and performing his work in a safe and satisfactory manner.

<p>COPIES</p> <p>RECEIVED 1153/05</p> <p>DATE: 20/02/05</p> <p>BY: [Signature]</p>	<p>FOR RE</p> <p>FOR [Signature]</p>	<p align="center">RECEIVED</p> <p align="center">21 FEB 2005</p> <p align="center">AL-KHIRAN PROJECT</p> <p align="center">[Signature]</p>	<p align="right">20/02/05</p> <p align="right">21/2/05</p>
--	--------------------------------------	--	--

*TYPE: SM - Shop Drawing, SN - Sample, CT - Certificate



SAFAT CENTER
SITE TRANSMITTAL
 of Materials, Samples, Etc..



M.C. / C.M. : Al-Ahlia Contracting Group

No. 001

Contractor : Al-Bahar & Bardawil Specialities
 Ref : B&B/OT/07/001

Rev. No. 1

TO : Resident Engineer
 Nezar Al-Anjari Consulting Bureau

WE ARE SENDING HERewith / UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS/
 SAMPLES LISTED BELOW. (Delete as necessary)

ITEM NO.	DRW., SPEC. OR BOQ. REF	DESCRIPTION	TYPE +	ACTION CODE*
1	07110	SPECIFICATION COMPARISON SHEET BETWEEN PARALON NT-4 & DESERT SHEILD MEMBRANES (DS 40200) from M/s. Awazel Co.	OT	B

CONTRACTOR:

[Signature]

DATE: 13/02/06

RECEIVED BY M.C. / C.M.:

[Signature]

DATE: 13/2/2006

RECEIVED BY NAB:

[Signature]

DATE: 13/2/2006

NAB to enter ACTION CODE and REMARKS

NAB REMARKS:

(DS 40200) مواصفات Paralon NT4 من الشركة التي تم استخدامها في الموقع
 لا تتطابق مع المواصفات التي تم استخدامها في الموقع
 ① المواصفات التي تم استخدامها في الموقع هي المواصفات التي تم استخدامها في الموقع
 ② المواصفات التي تم استخدامها في الموقع هي المواصفات التي تم استخدامها في الموقع
 ③ المواصفات التي تم استخدامها في الموقع هي المواصفات التي تم استخدامها في الموقع
 ④ المواصفات التي تم استخدامها في الموقع هي المواصفات التي تم استخدامها في الموقع

Resident Engineer:

[Signature]

DATE: 13/2/2006

RECEIVED BY M.C. / C.M.:

[Signature]

DATE: 13/2/06

RECEIVED BY Contractor:

13/2/06

DATE: 13/2/06

* TYPE: SD: Shop Drawings	* ACTION CODE:
SM: Sample	A: Approved
GT: Guarantee	B: Approved as Noted
MD: Manufacturer's Data	C: Not Approved
CT: Certificates	D: Resubmit
OT: Others	

**DIVIDED ZONE AGREEMENTS & KUWAIT ISLANDS AND MEGA PROJECTS
DEVELOPMENT TEAM
AL-KHIRAN NEW TOWN INFRASTRUCTURE WORKS**

TRANSMITTAL SHEET

Shop Drawing

Material

Others

Consultant :	M/s. Jassim Qabazard Engineering Consultants.	TRANSMITTAL NO. 148 - Rev. 0	
Contractor :	Mohammed Abdulwahid Al-Kharafi and Sons W.L.L.	DATE: 20 th February 2005	
Contract :	Construction Completion & Maintenance. Bulk Earth, Road, Landscaping, PSTP, Main Transformer Sub-Station, UG & OH Cable, Fresh Water, Tower water Main and Pump (Trakriri Wn 1/2/02)	SUBMITTED FOR	CODE*
		APPROVAL	1
		FOR INFORMATION	2
TO :	SITE OFFICE	ACTION	
WE ARE SENDING HERewith / UNDER SPARATE COVER, THE DRAWINGS, DOCUMENTS/SAMPLES LISTED BELOW. (DELETE AS NECESSARY)	APPROVED		B
	APPROVED AS NOTED		
	NOT APPROVED		C
	FOR INFORMATION		D

No. of Pages	DRAWING SPECIFIC SYMBOL OR DOC. REF.	ITEM SEQ NO.	DESCRIPTION	TYPE	CODE**	
					Submital	Action
	EN 5		Exterior Membrane Water Proofing DS Membranes (DS 4020)	MT	1	
	Sec. 2		Manufacture by: ANAZEL, K.S.A.			
	Accessories		Attachments:			
	And		- Previous Approvals			
	Materials		- Technical Data			
			- Test Result Certificates			
			- Sample			

COPIES: 3 copies


 Eng. Fawaz Al-Madi
 Project Manager

FOR CONTRACTOR: NAME POSITION



RE to enter Action Codes and Remarks, and return to Contractor
REMARKS:

*Re Approval in Subject to the following
satisfactory laboratory testing of sample to be carried out
in accordance with general specification*

(STATUS "B")

APPROVED AS SOURCE ONLY.

Contractor is responsible to ensure the contractor complies with the requirements of the drawings and specifications. This check is only for general compliance with the design intent of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and controlling all quantities and dimensions, selecting fabrication processes and techniques of construction, and performing his work in a safe and satisfactory manner.

COPIES		FOR RE	FOR <i>Costs</i>		 21/02/05
RECEIVED	1155/05				
DATE	20/02/05				
BY					

* Code to be entered by Contractor
* Code to be entered by REC

TYPE: SP - Shop Drawing SM - Sample CT - Certificate

قسم العقود والإشراف
 ممثل المالك : شركة النخيل المتحدة العقارية
 مشروع : إنشاء وإتجاز وصيانة مبنى القطاع التجارى
 ليبيت التمويل الكويتى بمنطقة الشويخ - (تسوية 100)

المستلم : 02
 العينة المقدمة : عازل رطوبة لحوائط وارضيات السرداب
 مصدر العينة : عوازل السعودية

طلب اعتماد عينة

(WATER PROOFING MERRBRANE)

الاستشاري : دار الكويت للاستشارات الفنية
 المقاول : شركة المدير الكويتى

المواصفات العامة	جداول الكميات	المخططات	المواصفات الخاصة	ممثل المقاول:
D.S 40 200	III-4/DIV.7/1/0-B	S-03	البيان	عازل رطوبة سمك 4 مللى لحوائط وارضيات السرداب
				عينة 14 قطعيات شتاعة

مطابقا للمواصفات	A	مطابقا للمواصفات مع ملاحظات	C	غير مطابقا للمواصفات	D	مطلوب استكمال المستندات للنظر في الاعتماد
------------------	---	-----------------------------	---	----------------------	---	---

ملاحظات :
 صياغة مستخرج من ذلك لتوافق مع المواصفات الخاصة
 بصورته المرفقة

مهندسى الخدمات :	استلام الاستشاري :
المهتمون بالموقع	التاريخ : 2008/06/25 الساعة 10:40
ممثل المالك :	التاريخ : 2008/6/26 الساعة 10:40

الاصول : المقاول
 موزعة : المالك
 KTCB/ISO/C&S/SH#005-02

ملحوظة : هذه المراقبة لادنى اعطاء المقاول من مسؤولياته حسب ما هو وارد بالمستندات التعاقدية
 دار الكويت للاستشارات الفنية

**"THE AVENUES"
ENGINEER: PAN ARAB CONSULTING ENGINEERS (PACE)**

REQUEST FOR ALTERNATIVE OR SUBSTITUTION

CONTRACT NO. : 1091
CONTRACTOR : Alghomem International General Trading & Contracting Co.

NO. : AS/07/12
DATE : 25/5/16

TO : PAN ARAB CONSULTING ENGINEERS CC RE A/E

PROPOSED ALTERNATIVE OR SUBSTITUTION:

PRODUCT METHOD OF FABRICATION METHOD OF INSTALLATION

SPECIFIED PRODUCT Bluplus P4200
PROPOSED PRODUCT Amazel DS40200
SPEC. SECTION @ technical correspondence REF # HWCOMER4657/25705 ARTICLE # 2
SPECIFIED MANUFACTURER M/S Polytr Industries Limited
PROPOSED MANUFACTURER M/S Amazel Co Ltd
BRIEF PRODUCT DESCRIPTION waterproofing membrane

REASON FOR PROPOSED ALTERNATIVE OR SUBSTITUTION

COST AND TIME SAVINGS At no extra cost and or time to the Employer

COST	NO	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	AMOUNT (KD) (DEDUCTION)
TIME	NO	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	DAYS

ATTACHMENTS
Bluplus P4200 catalogue

Technical and cost comparison sheets must be attached with this request, they will not be returned. Contractor shall be bound to SAG the 3 days term. From what only and as required to Contractor with SAG upon. (SAG CM or PM - SAG can also mark the request flagged as obsolete material)

WE (THE MAIN CONTRACTOR) CERTIFIES AND UNDERTAKES THAT:

- State compliance will be obtained for proposed alternative or substitution as per attached proposal.
- State compliance covers and claims of replacement parts, as applicable to schedule.
- Cost data of stated items is complete and correct. No claims - what is shown - will be raised. For any additional cost and or time required to this request.
- Proposed alternative or substitution does not affect structure and structural response.
- The cost for all required changes to design, including materials and related activities approved, covered by the request is to fully the responsibility of its extra cost and or time to the employer.
- Continuation, deletion, and changes in the Bill of Materials necessary for design alternative or substitution will be complete in response.
- WE UNDERSTAND THAT THIS REQUEST WILL NOT BE REVIEWED UNLESS IT FULLY COMPLIES WITH SECTION 1000 DOC 01-1


WE FURTHER ACKNOWLEDGE THAT APPROVAL FOR ALTERNATIVE OR SUBSTITUTION DOES NOT WAIVE OUR OBLIGATIONS TO THE EMPLOYER AS DETAILED IN SECTION 1000 IN DOC 111-2 AND ANY OTHER RELATED CONTRACT DOCUMENTS.

CONTRACTOR'S REP

DATE/TIME 25/5/16

RECEIVED BY RE

DATE/TIME



REVIEW AND ACTION BY PACE

Approved Not Approved Approved as Noted Incomplete Data. Res

COMMENTS

Subject to compliance with related Contract Documents.

MABANE

DATE/TIME: 28/05/16

THE APPROVAL OF ANY ALTERNATIVE OR SUBSTITUTION REQUEST SHALL BE SOLELY AT THE DIRECTION OF THE DIRECTOR UNDER SECRETARY OF PACE AND SUCH APPROVAL SHALL IN NO WAY RELIEVE THE CONTRACTOR OF ANY OF HIS LIABILITIES AND OBLIGATIONS UNDER THE CONTRACT

RECEIVED BY CONTRACTOR:

DATE/TIME:

EMPLOYER

RESIDENT ENGINEER

CONTRACTOR

AL-RAI INTEGRATED REAL ESTATE PROJECT

"THE AVENUES"

ENGINEER: PAN ARAB CONSULTING ENGINEERS (PACE)

TRANSMITTAL FOR MATERIAL DATA, SAMPLES, MOCK-UPS



CONTRACT NO 1091	NO : OT/07/292
CONTRACTOR <i>M/s Alghanim International General Trading & Contracting Co</i>	DATE : 9/5/2005

C.

V. : **0**

TO MR. JABR BADDAR, RESIDENT ENGINEER

WE ARE SENDING HEREWITH PREVIOUS APPROVALS AND TEST REPORT OF ITEM LISTED BELOW.

WE CERTIFY THAT THE ITEM LISTED BELOW IS IN STRICT ACCORDANCE WITH THE CONTRACT DOCUMENTS.


SUBMITTED FOR	
APPROVAL	
YOUR INFORMATION	
ACTION	
APPROVED	
APPROVED AS NOTED	
APPROVED AS NOTED RESUBMIT	
NOT APPROVED	
INFORMATION REQUIRED	
FOR INFORMATION ONLY	

CODE	
1	
2	
CODE	
A	
B	
BR	
C	
CR	
D	

QTY	RMS, SPEC. O BOQ. REF.	ITEM SEQ NUMBER	DESCRIPTION	TYPE	CODE
					Submittal
3	Tender Correspondance REF: HK/COM/ER 4557/657/05 Item 2		<u>WATERPROOFING MEMBRANE</u>		
		1	Additional documents for the membrane Type DS 40200 submitted vide trans#MD/07/263 DATED 4/5/2005.	OT	2

COPIES TO: Employer SUB- CONTRACTOR **M/s AL-HAMRA KUWAIT**

Contractor Resident Engineer *[Signature]*



RE to enter Action Codes and Comments, and return to Contractor

Refer and comply with:

(1) Item No. 2 of M/s Al Hamra letter HK/COM/ER4557/657/05 dated 29/03/05 or

(2) Comply with 01030 and 01630 Volume IV A of Contract Documents.

Sections

B

3


Corrections of comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the info in contract documents. The contractor is responsible for confirming and correcting all quantities and dimensions selecting fabrication processes of the construction, coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

COPIES TO: Employer *[Signature]*

Contractor Resident Engineer R.E.

*1 Code to be entered by Contractor
*2 Code to be entered by R.E.

TYPE: SD - Shop drawings
SM - Sample
OT - Copy only



swings and on given techniques

105

ATE

AL AHLI BANK OF KUWAIT - MANSOURIYA BRANCH

mission of drawings, materials, samples, etc.

ject : Al Ahli Bank of Kuwait
Mansouriya Branch


: Mr. Varghese Niran
: Resident Engineer
: Gulf Consult

m : Mr. Imad H. Assi
: Project Manager
: Construction Management & Building Co.


Transmittal No. **18**

Date 14/05/2005	Rcv.
Submitted for *	Code
Approval	1
Your information	2
ACTION	Code
Approved	A
Approved as Noted	B
Revise & Resubmit	C
Rejected	D

ECS Ref.	DRAWG. Ref.	B.O.Q. Ref.	DESCRIPTION	TYPE	*	Action
500		D. 7	① DS MEMBRANES (DS 40200) AWAZEL Made in Saudi	SM		B
			② MEMBRANE SHIELD MS-60 AWAZEL Made in Saudi			

ject Coordinator	Contractor's P.M Signature	Consultant	Owner
		In Ref.	By
		File	Received
		Dist	Arch
		Struc.	Elect.
		Mech	Q.S
		Sign	Sch

onsultant's Remarks	Initials
As listing as prepared to be done	RE
	Arch
	SE
	ME
	EE
	Q.S
	Sched

opies to : ABK for information R.E's Signature  Date : **24/05/2005**

ceived by Contractor Date :

LEGEND : SD - Shop Drawing, MD - Manufacturer's Data/Catalogues,
CT - Certificate, SM - Sample, GT - Guarantee, OT - Others, R - Reports.

MATERIAL & DATA SUBMITTAL

SUB-CONTRACTOR	ALGHANIM INTERNATIONAL GEN. TRDG. & CONT. CO. WLL	AI-3013-MDS NO:	069
ORIGINATOR	VINOD PAUL	ISSUE DATE:	16/1/2010
REFERENCE DRAWING, SPECIFICATION MATERIAL OR LOCATION		DISCIPLINE	CIVIL

Section 5C.10. (Civil and Architectural Works)

BRIEF DESCRIPTION OF MATERIAL / DATA BEING SUBMITTED

- Material description : Roof Water proofing System.
- Country of origin: Saudi Arabia.
- Manufacturer/supplier :Riham
 - a) DS40200, Awazel 4mm thick, water proofing membrane.
 - b) Awazel Protection Boards, MS60 & MS40(6mm+4mm)
 - c) Aercel, Lightweight concrete forming agent.
 - d) Master board insulation, 32-35 kg/M³ density; 100mm thick

HYUNDAI HEAVY INDUSTRIES
SABIYA CCGT POWER PLANT PROJECT OFFICE

08 MAR 2010
ISSUED

FOR MATERIAL ONLY-DOES MATERIAL FULLY COMPLY WITH SPECIFICATIONS	YES	X	NO
--	-----	---	----

OWNER SPECIFICATION AVAILABLE WITH AI

HYUNDAI HEAVY INDUSTRIES
SABIYA CCGT POWER PLANT PROJECT OFFICE

10 APR 2010
ISSUED

ESSENTIAL IMPACT	SCHEDULE:	YES		NO	X	COST:	YES		NO	X
------------------	-----------	-----	--	----	---	-------	-----	--	----	---

RESPONSE

<input type="checkbox"/>	A	Proceed
<input type="checkbox"/>	B	Proceed, change as noted and resubmit
<input type="checkbox"/>	C	Do not proceed, change as noted and resubmit
<input type="checkbox"/>	D	Information only
<input type="checkbox"/>	Q	Drawing / Data quality below standards, correct & resubmit
<input checked="" type="checkbox"/>	O	OTHER - Explain below


- ITEM (a) IS ACCEPTABLE
- ITEM (b) IS NOT ACCEPTABLE / RESUBMITTED & APPROVED
- ITEM (c) LACKS TECHNICAL DATA TO BE EVALUATED / REJECT
- ITEM (d) IS ALREADY APPROVED IN A SEPARATE SUBMITTAL

SITE INSTRUCTION REQD	NO	X	CSI NO.
RECEIVED ON BEHALF OF HHI			DATE
RESPONDER'S SIGNATURE / DATE			DATE
DATE RETURNED TO SUB-CONTRACTOR			DATE

RECEIVED
Document Sub-Contractor
10 APR 2010

NOTE: HHI's response to this MDS does not constitute authorization to perform a change to the Contract. Sub-Contractor may proceed in accordance with the response only on the basis that Sub-contractor agrees that it is not a change. If the sub-Contractor believes that the response constitutes a change, sub-contractor shall await receipt of the Site Instruction. Where no Contractor Response (CSI) is indicated, Sub-Contractor shall notify HHI, and shall not proceed until authorized in writing.

By:.....
SABIYA CCGT PROJECT
ALGHANIM INTERNATIONAL



Ref. No. PUN/04/859/2004/008

10th November 2004

Al Ghamim International Trading & Contracting Co. W.L.L.
 P.O. Box 2118 Safat
 13022 Kuwait.



Attn: Mr. Fadi Haddad
 Project Director

Sub: **Al Rai Integrated Real Estate Project - 'The Avenues'**
Substructure Water Proofing System

Dear Sirs,

Please refer to your submittal CIV/MAT/TR/806/04 dated 7th November 2004.

To expedite the progress of Works at site, please be informed as stated below:

- 1) The 6 mm thick protection board for the vertical waterproofing membrane, type 'PC-3' from M/s W.R. Meadows, USA is accepted.
- 2) (a) The 4 mm thick waterproofing membrane, type 'Lotus 4' from IMPER, Italy is only accepted subject to laying two (2) layers in the opposite directions.
- (b) The 4 mm thick waterproofing membrane, type 'DS 40200' from AWAZEL Co. Ltd of KSA is only accepted, subject to laying two (2) layers in opposite directions.

All the other requirements of the Contract Specification are to be adhered to.

The formal return of transmittal documents will follow shortly and note that all the materials described above are classified as 'alternatives' with the relevant Contract clauses applicable.

All further submittal responses shall be conveyed by return of the duly completed appropriate forms.

Yours faithfully,
PAN ARAB CONSULTING ENGINEERS

Robert Toulson

Robert Toulson
 Engineer's Representative

Received
 COP. 9
 11-11-2004

ALGHAMIM INTERNATIONAL		
Tickets	File No.:	
	A	C
PD		/
PM		/
DPN (M)		/
TR (M)		/
PC 12.1/14		/
M & P	/	
QA/QC		/
SAFETY		
ELE/MECH		
DNB		
DCM		
Aut.		
H.O.		
OTHERS		

OFFICE
 Al Ghamim
 Safat
 P.O. Box 2118
 Safat
 13022
 Kuwait
 Tel: 973 2339117
 Fax: 973 2339117
 Email: info@pana.com

BAHRAIN OFFICE:
 P.O. Box 10207
 Manama, Bahrain
 Telephone: 333073
 Fax: 333083
 Tel: 973 2339117
 Email: info@pana.com

مكتب العربي
 للاستشارات
 الهندسية ذ.م.م.
 صباح الرئيس
 و حامد عبد السلام
 شبيب
 0022 973 2339117
 0022 973 2339117

**Construction of Mrs.Huda Shawwa Qaddumi Private Villa
Garnata.**

**Submittal
Form**

Project Manager: Project Analysis and control system (PROJACS).
Consultant: AL-BANNAI Consultants.
Contractor : ALDaleel for General Trading & Contracting Co.

Submittal Form No: 2
Date: 4/9/2004
Trade: Civil
CC: PROJACS

Item No.	Specs,B.O.Q Reference	DESCRIPTION	*TYPE	**ACTION
1		Membrane DS 40200	SM	A
2		Membrane shield MS 60	SM	C
3		Testing record DS 40200	CT	D
4		Data sheet 40200	MD	D
5		Data sheet ms 60	MD	D

CORRECTIONS OR COMMENTS MADE RELATIVE TO SUBMITTALS DURING THIS REVIEW DOES NOT RELIEVE THE CONTRACTOR FROM COMPLIANCE WITH THE REQUIREMENTS OF THE DRAWINGS AND SPECIFICATIONS. THIS CHECK IS ONLY FOR REVIEW OF GENERAL CONFORMANCE WITH THE DESIGN CONCEPT OF THE PROJECT AND GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTACT DOCUMENTS. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRMING AND CORRECTING ALL QUANTITIES AND DIMENSIONS, SELECTING FABRICATION PROCESS AND TECHNIQUES OF CONSTRUCTION; COORDINATING HIS WORK WITH THAT OF OTHER TRADES, AND PERFORMING HIS WORK IN SAFE AND SATISFACTORY MANNER

Contractor Fawaz Signature [Signature] Date 4/9/04.

Consultant Project Manager Remarks: Received 4/9/2004
A sample of cold applied bitumen to submit for approval
included with technical data sheet.

Consultant Project Manager Signature [Signature] Date 7/9/2004

*TYPE	**ACTION CODE
SD Shop Drawing	A Approved
SM Sample	B Approved as Noted
MD Manufacture Data	C Not Approved
GT Guarantee	D For Information
CT Certificate	
OT Others	

Distribution

Received
[Signature]
7/9/04

CONSULTANT NAME: Taher Consultant Engineering Center
 PROJECT NAME: مشروع إنشاء وإنتاج وصيانة مبنى إدارة حجرة نموذجي ومبنى الهجرة - محافظة القروانية
 PROJECT LOCATION: PARAWANIA - REGEE - BLOCK 18

O & G ENGINEERING W.L.L.

TRANSMISSION OF DRAWINGS, DOCUMENTS, SAMPLES ETC

RE: مشروع إنشاء وإنتاج وصيانة مبنى إدارة حجرة نموذجي ومبنى الهجرة بمحافظة القروانية
 TO: TAHER CONSULTANT ENGINEERING CENTER

CONTRACT NO: (711/2011-2012)

WE ARE SENDING HERewith / UNDER SEPARATE COVER THE DRAWINGS/ DOCUMENTS/ SAMPLES LISTED BELOW (DELETE AS NECESSARY)

QTY	DRWS, SPEC OR BOQ REF	ITEM SEQ NUMBER	DESCRIPTION	#TYPE	CODE	
					Submittal	Action
3	SPEC	DIV-7 SEC7110	Comparison Sheet Water Proofing Membrane (Awasel - Paralon) -3 copies of Comparison Sheet + Cataloge		OT	

COPIES: _____
 OWNER: _____
 CM: _____

FOR O & G ENGINEERING W.L.L.
 FOR TAHER CENTER to enter Action, Codes and Remarks, and return to CONTRACTOR

Approved as noted Action (B)

مستند مشروع
 م. أحمد الشاذلي
 مدير

مستند مشترك على ذلك!
 * إكمال جميع القوائم المطلوبة وتقديم شهادات الضمان وفقاً للوائح المطلوبة
 * تقديم المخططات الفنية وطريقة التنفيذ للدراسة وإنتاجها وفقاً للبيانات الفنية

Corrections and comments made relative to submittals during the review do not relieve the Contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general conformance with the information given in the submittal documents. The contractor is responsible for continuing and correcting all quantities and dimensions, selecting functional processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

ISSUED TO: _____
 OWNER: Taher Consultant Engineering Center
 FOR THE (TAHER CONSULTANT ENGINEERING CENTER) _____ DATE: 19/2/2012

* Code to be entered by CONTRACTOR: SD - Shop Drawings, MS - Manufacturer's Data
 ** Code to be entered by R/E (Taher Consultant Engineering Center): SA - Sample, C1 - Consistent, GT - General

التاريخ : 08 / 12 / 2013 م

المرجع : KEB/12030/1135

المحترمين

السادة/ شركة ناسا الإنشائية

المحترم

عناية المهندس/ مروان السيد

المدير التنفيذي

تحية طيبة وبعد،،،

المشروع : إنشاء وإنجاز وصيانة مجمع " Trio Mall "

على القسيمة رقم (30) قطعه "المركز الإداري والتجاري" بمنطقة خيطان

الموضوع: مواد العازل

بالإشارة الى المشروع أعلاه، وإلى كتابكم مرجع رقم (NASA/TMP/KEB/L-10/2013)

بتاريخ 2013/11/27، نفيديكم علماً بإعتمادنا للمواد التالية:-

1. العازل مميرين - عوازل 40200 -.

2. الواح الحماية البتومينية - MS60 -.


شريطة الإلتزام التام بالموصفات والشروط التعاقدية.

مرسل للعلم وإتخاذ اللازم،،،

وتفضلوا بقبول فائق التقدير والاحترام ،،،

م/ سامي طالع

رئيس قسم الاشراف



نسخه إلى:-

- مالك المشروع.
- المدير التنفيذي.
- ملف المشروع.

FORMAT NO. 4A

اسم المشروع
المدرسة المتحدة الامريكية

Kuwait United Construction Management
K.U.C.M.

American United School at Sabah Al-Salem Branch

CONSULTANT : LIWAN Arch'tl Engineering Consultant DATE : 01.05.2012
 CONTRACTOR : Al Amarat Al-Jadidah Trading & Contracting Co.
 PACKAGE : BP-1 (Excavation, Shoring, Dewatering, Raft Foundations & Basement Walls)

REQUEST FOR ALTERNATIVE OR SUBSTITUTION (A/S-1)

Contractor Signature: _____ A/S No. 001

SUBJECT: Bituminous Membrane DATE: 01.05.2012

"The Contractor shall comply with the requirements of Doc. III-2, Section 01631 prior to submission of this request"
 DESCRIPTION OF CONTRACT ITEM FOR WHICH ALTERNATIVE OR SUBSTITUTION IS PROPOSED:

Specification Title: Modified Bituminous Membrane
 Section: 07133 Page: 2/5 and 3/5 Article/Paragraph: 2.01

REASON FOR PROPOSED ALTERNATIVE OR SUBSTITUTION:
Required water proofing material for the project is not available in local market.

PROPOSED ALTERNATIVE OR SUBSTITUTION:
 Product Method of Fabrication Method of Installation
 Manufacturer: Awazel Co. Address: P. O. Box 2955, Riyadh 11461 Phone #: 966 1 476 2876
 Trade Name: AWAZEL Model #: DS 40200

History New Product 2-5 Years Old 5-10 Years Old More than 10 years old

Difference between proposed alternative or substitution and specified:
Comparison sheet attached.

Point-by-point comparative data sheet is REQUIRED and ATTACHED as per form No. 4
 Proposed alternative or substitution affects other parts of Work: No Yes; explain

SIMILAR INSTALLATION OF PROPOSED ALTERNATIVE OR SUBSTITUTE:
 Project: Company Profile attached included work executed. Engineer: _____
 Address: _____ Owner: _____
 Date installed: _____

FORMAT NO. 4B

اسم المشروع
المدرسة المتحدة الامريكية

Kuwait United Construction Management
K.U.C.M.

American United School at Sabah Al-Salem Branch

CONSULTANT : LIWAN Archt'l Engineering Consultant DATE : 01.05.2012
 CONTRACTOR : Al Amerat Al-Jadidah Trading & Contracting Co.
 PACKAGE : BP-1 (Excavation, Shoring, Dewatering, Raft Foundations & Basement Walls)

REQUEST FOR ALTERNATIVE OR SUBSTITUTION (A/S-2)

Contractor Signature: _____ A/S No. 01.05.2012

SUPPORTING DATA ATTACHED:

Product Data Drawings Tests Reports Samples Others

THE CONTRACTOR CERTIFIES AND UNDERTAKES THAT:

- Same warranty will be furnished for proposed alternative or substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable is available.
- Cost data as stated above is complete. Claims for additional costs related to accepted alternative or substitution which may subsequently become apparent are to be waived. Other costs to other disciplines and/or contractors shall be borne by the Contractor
- Proposed alternative or substitution does not affect dimensions and functional clearances.
- The cost for all changes to design, including architectural or engineering design, detailing, and construction cost including authorities approvals, caused by the requested alternative or substitution shall be fully the responsibility of the Contractor .
- Coordination, installation, and changes in the Work as necessary for accepted alternative or substitution will be complete in all respects.

THE CONTRACTOR'S REP: _____ DATE & TIME: _____
 RECEIVED BY: _____ DATE & TIME: _____

REVIEW AND ACTION BY THE ENGINEER:

- Alternative of Substitution approved - Make submittals in accordance with Specification Section 01300.
- Alternative of Substitution approved as Noted - Make submittals in accordance with Specification Section 01300.
- Alternative of Substitution rejected - Use specified Materials/Method.
- Alternative of Substitution request received too late - Use specified Materials/Method.
- Incomplete Date - Resubmit.

Additional Comments: 1- Comply with manuf. requirements of spec.
2- Random Samples from delivered materials has to be tested before applying
3- Method of statement of shop drawings has to be submitted

THE ENGINEER: _____ DATE & TIME: 5/5/2012

The approval of any alternative or substitute product / method shall be solely at the direction of the Engineer and such approval shall in no way relieve the contractor of any of his liabilities and obligations under the contract. The approval does not en

RECEIVED BY CONTRACTOR: _____ DATE & TIME: 5/5/2012

Distribution: Employer PM Engineer Contractor



SITE TRANSMITTAL of Materials

TRANSMITTAL NO: SM-10

REV: 01

PREPARED FOR: MAC Consultants

PROJECT	DIV/PACKAGE	OWNER	CONTRACTOR
Grains Silo 2009		Kuwait Flour Mills & Bakeries CO.	Alghanim International Co.

WE ARE SENDING HERewith / UNDER SEPARATE COVER, THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW. *(Delete as necessary)*


ITEM NO.	DRW., SPEC.	OR BOQ. REF	GENERAL DESCRIPTION AND REVISION DETAILS	TYPE +	COPIES	ACTION CODE*
1	WP/ROOFS	DS40200	4MM THICK BITUMINOUS MEMBRANE Manufacturer: Awazel (KSA)			B

We certify that the items submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR:

RECEIVED BY MAC:

DATE: 24-1-2012



MAC REMARKS :

- The water proofing membrane (DS-40200) manufactured by Awazel is approved ~~subject~~ to follow the manufacturer's application instructions
- Awazel bituminous primer must be submit for approval.

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication process and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.


MAC RESIDENT ENGINEER: For
DATE: 24 Jan 12

RECEIVED BY CONTRACTOR:

DATE:

- + TYPE:
- SD: Shop Drawings
 - SM: Sample
 - GT: Guarantee
 - MD: Manufacturer's Data
 - CT: Certificates
 - OT: Others

- * ACTION CODE:
- A: Approved
 - B: Approved as Noted
 - C: Not Approved
 - D: Further Information Required



SITE TRANSMITTAL FORM

of Shop Drawing , Certification ,Etc.

TRANSMITTAL NO: 009

DATE :29-12-2014

CONTRACTOR : Al-Bahar Construction
PROJECT :Markaz Residential Complex
CONTACT NO. : +96522436005
TO : SSH INTERNATIONAL

WE ARE SENDING HERE WITH /UNDER SEPARATE COVER , THE DRAWING /DOCUMENTS/ SAMPLE LISTED BELOW

ITEM NO	DRW, SPEC. OR BOQ .REF	DESCRIPTION	TYPE+	ACTION CODE*
1	Div 7	Water profit mempraine Awazel.	SM	*B*
	Spec071313	Awazel Kuwait Co.LTD	MD	
		Primer Awazel		
		Water profit mempraine DS 40200 4 mm thickness		
		Protection board M (S 60) 6 mm thickness		

CONTRACTOR:

RECEIVED BY

[Signature]
Mohamed Noaman

Date :

Engineer' representative To Enter Action Code And Remarks

REMARKS:

*Approved as noted.
Refer to attached comments.*

DICC.Eng :

R.E

Date :

6/1/2015

Date:

6/1/15

Corrections Or Comments Made Relative To Submittals During This Review Does Not Relive The Contractor From Compliance With The Requirements Of The Drawing And Specification. This Check Is The Only For Review Of General Compliance With The Information Given In The Contract Document .The Contractor Is Responsible For Confirming And Correlating All Quantities And Dimensions ,Selecting Fabrication Process And Techniques Of Construction; Coordinating His Work With That Of Other Trades ,And Performing His Work In A Safe And Satisfactory Manner



RECEIVED BY CONTRACTOR :


CC:[COMPANY]

- +TYPE SD: Shop Drawing
- SM: Sample
- GT: Guarantee
- MD: Manufacturer's data
- CT: Certificates
- OT: Other

***ACTION CODE**

- A: Approved
- B: Approved as Noted
- C: Not Approved
- D: Further Information required





Al Manshar Project		
Distribution	Action	Info
DMD		
Project Director		
Project Manager		
Sr.QS/QCA		
Const. manager C		
Construction Manager F		
MEP Coordinator		
Procurement		
Section Engineer		
Planning		
Safety Officer		



**SITE TRANSMITTAL OF
Shop Drawings, Materials, etc.**

TRANSMITTAL NO : MRE/BP2/MD/0010

REV : 1

To: KEO International Consultants

PROJECT	DIV/PACKAGE	OWNER	CONTRACTOR
Al Kout Fahaheel, Kuwait	BP 02 Main Works	Tamdeen Real Estate Co.	Ahmadiyah Contracting & Trading Co.

WE ARE SENDING HERewith THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW FOR YOUR REVIEW.

ITEM NO.	DRW., SPEC. OR BOQ. REF	GENERAL DESCRIPTION AND REVISION DETAILS	TYPE (I)	COPIES	ACTION CODE (II)
		Material Data Sheet for Bitumenous Membrane for waterproofing (equivalent to specified material - see attached)	MD	1+2	"B"

We certify that the items submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR: _____
DATE: 13/8/14

RECEIVED BY KEO:
DATE: 13/8/14

KEO'S REMARKS: * B :- No objection subject to.
* Comply With Contract requirement.
* project Warranty to be Submitted @
"Section 075200 - Item 1.09"

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of his Contract, drawings and specifications. This review is only in respect of general conformance with the design intent of the project and general compliance with the information given in the Contract documents. The contractor remains responsible, among other things, for the design of the project or such parts of the project he has design responsibility for (if design forms part of the Contract), for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner, all in accordance with the Contract.

KEO CM / RE:
DATE: 20/8/2014

RECEIVED BY CONTRACTOR:
DATE: 20/08/14


- (i) TYPE: SD: Shop Drawings
- SM: Sample
- GT: Guarantee
- MD: Manufacturer's Data
- CT: Certificates
- OT: Others

- (ii) ACTION CODE:
- A: No objection
- B: No objection subject to incorporation of all comments as noted
- C: Rejected, to be resubmitted
- D: Further Information required

cc: Mr. Taleb Al Shaghay - Employer's Representative



Combined Group Contracting Co.



AL DIWAN AL AMIRI

Design Development, Rehabilitation and Maintenance for Al-Salam Palace

Contract No. : 90 / هـ / 1 د

REQUEST FOR SUBSTITUTION / ALTERNATIVE

CLIENT : AL DIWAN L ALAMIRI
 ENGINEER'S REP. : AL-SOOR RFS NO. : RFS / 1- Rev. 1
 CONTRACTOR : COMBINED GROUP CO. DATE : 20/12/2014
 TO : AD - PROJECT ENGINEER
 SUBJECT : **WATER PROOFING MEMBRANE SYSTEM**

TYPE OF FORM SUBSTITUTION ALTERNATIVE

ITEM TO BE SUBSTITUTED / ALTERNATIVE:

Specification Title : PVC SHEET MEMBRANE WATERPROOFING

Section : 07 11 50 Page : III-2/07 11 50/1 Article/Paragraph : _____

REASON OF SUBSTITUTION / ALTERNATIVE :

- * PVC has no previous record for 20 years in Kuwait.to prove its performance
- * The underground water has no aggressive substances
- * Bitumen membrane & its applicators is readily available in the local market (Please see the system comparison)

PROPOSED SUBSTITUTE / ALTERNATIVE :

Manufacturer : Awazel Arabian Waterproofing Address : Saudi Arabia Phone # : 96614782876

Trade Name : AWAZEL Model # : D41+DS40200+MS60

Installer : Al-Hamra Kuwait Co. Address : Kuwait Phone # : 24344025

History New Product 2-5 Years old 5-10 Years old More than 10 years old

Difference between proposed substitution/ alternative and specified products

The specified is PVC membrane 2mm , and the proposed is bitumenous membrane 4mm - 2 layers for basements of carpark with 6mm protection board, one layer above B1 Roof.

Point-by-point comparative data attached - REQUIRED BY THE ARCHITECT

SIMILAR INSTALLATION OF PROPOSED SUBSTITUTE / ALTERNATIVE :

Project : Has been used in Kuwait projects Engineer's Rep. : Approvals attached in previous

Address : _____ Employer : submittal RFS/1 dated 17/11/2014

Date Installed : _____

Proposed substitution affects other parts of Work : No Yes; explain

COST & TIME IMPACT:

COST: Additional Saving Amount, KD 0.000

TIME: Additional Non Days 0



مكتب سامي البسام للإستشارات الهندسية
SAMI ALBASSAM ENGINEERING
Architects • Engineers • Planners مماريون • مهندسون • مخطوومدن

إشارة رقم: SAB.Judge.Hs.0226

التاريخ : 2013/11/11

المحترمين
المحترم

السادة / مجموعة هاي سلانت للمقاولات
عناية المهندس/ عبدالله محمد قضيب " مدير المشروع"
ص.ب: 21491 الصفاة - 13.75 الكويت- تليفون 22915503 - فاكس 22915504

تحية طيبة ... وبعد ،،،

المشروع: عقد رقم : و ع / 2 / 2011 / 2012
إنشاء وتنفيذ وتشغيل وصيانة مبنى نادي القضاة
الموضوع : طلب اعتماد مادة العازل للأساسات والأسطح

بالإشارة إلى الموضوع أعلاه ، ورداً على كتابكم إشارة رقم هـ س/ن ق/س ب/175/2013 بتاريخ 2013/11/6 بشأن اعتماد مواد أعمال العازل المائي للأساسات والأسطح ومصدرها شركة صناعات العزل العربية (عوازل) المشتمل على :-

- Primer - D41 .
- 4mm membrane – Desert Shield DS 40200 .
- 6mm Protection board – membrane shield MS60 .

نفيدكم علماً بأنه ليس لدينا مانع من اعتماد نظام العزل المتكامل (Action B) شريطة التقيد بالآتي :-

- 1- التقيد بتعليمات الشركة المصنعة .
- 2- تقديم عينات للاعتماد قبل التوريد بالموقع
- 3- عمل كافة الاختبارات اللازمة حسب تعليمات الاستشاري والتقيد بكافة المواصفات والاشتراطات التعاقدية .
- 4- تنفيذ طبقات العازل للأماكن المشار إليها أعلاه حسب ما هو وارد بالمخططات التعاقدية .

وتفضلوا بقبول وافر الاحترام والتقدير،،،

مهندس / فتحي عبدالعظيم

المهندس المقيم





Shapoorji Pallonji

شاپورजी पालंजी (ش.م.م.)
Mideast (L.L.C.)



AL SAGER
CONSTRUCTION

MINISTRY OF HEALTH
HOSPITAL EXPANSION PROJECTS



DOCUMENT TRANSMITTAL FORM (DTF)

Contract No: 18/2011/2012-11

Project: Design, Construction, Equipment,
Furniture and Operational Maintenance for the
New Al Sabah Hospital

TO: Ministry of Health (MOH)

ATTN: Eng. Hashim

TRN NO: MDL-ALSABAH-CE-0002

REV: 2

FROM: JV of Al Sager-Shapoorji Pallonji

DATE: 08-June-2015

Copy Distribution

Ministry of Health

PM

Consultant

Other

WE ARE SENDING:		SUBMITTED FOR:		ACTION TAKEN:	
<input checked="" type="checkbox"/>	Documents	<input checked="" type="checkbox"/>	Approval	<input type="checkbox"/>	A - Approved
<input type="checkbox"/>	Drawings/Sketch	<input type="checkbox"/>	Review & Comments	<input checked="" type="checkbox"/>	B - Approved as noted
<input type="checkbox"/>	Report	<input type="checkbox"/>	As Requested	<input type="checkbox"/>	C - Approved with comments, Revise & Resubmit
<input type="checkbox"/>	Variation	<input type="checkbox"/>	Information / Records Only	<input type="checkbox"/>	
<input type="checkbox"/>	Test Certificate	<input type="checkbox"/>	For Necessary Action	<input type="checkbox"/>	D - Not Approved
<input type="checkbox"/>	Test Results	<input type="checkbox"/>	Other:	<input type="checkbox"/>	E - Information Required, Revise & Resubmit
<input type="checkbox"/>	Sample				
<input type="checkbox"/>	Other:				

Item No.	Draws, Spec or BOQ Ref.	Item Seq. No.	Description of Submittal or Document Title	Copies
1	MOH Letter Ref # 598 dated 31.05.2015		Re-submission of Material Submittal for product approval for Bituminous Water Proofing Membrane Material from Awazel Kuwait Co. Ltd. Bituminous Membrane - Awazel Desert Shield DS40200 Bituminous Protection Board - Awazel Membrane Shield Primer - Awazel Primer D41. Enclosures - Product Data Sheet, Test Certificates & Approval Certificates.	2

Subcontractor Name:	Project Manager Name:	Main Contractor:	JV of Al Sager Shapoorji Pallonji
Signature:	Signature:	Project Director Name:	Eng. Aymaan Gouda
Received By Recipient	Date	Title	


REMARKS

Action: - B: Approved as noted

Refer to the attached comments.

 RESIDENT ENGINEER NEW AL SABAH HOSPITAL PROJECT	 Narendra Deshpurkar PM	 Eng. Salem Yaseen PE/MOH	
--	-------------------------------	---------------------------------	--

Corrections and comments made relative to submittals during this review do not relieve the Contractor from compliance with the requirements of the contract documents. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for conformance



التاريخ 07/12/2015

إشارة : MSH/TAY/SAK/179

المحترمين

السادة / شركة سديم الكويت

المحترم

عناية المهندس /أيمن عبد السلام (مدير المشروع)


المشروع /إنشاء وإنجاز وصيانة برج الطيب السالميةقطعة (6) قسيمة (37) ملك السيد /عبدالله عيسى حسين اليوسفيالموضوع : تجديد اعتماد العازل المائي الطربال

بالإشارة إلى الموضوع أعلاه ، وبناء على كتابكم SAK/TAY/MSH/432/15 بتاريخ 2015/12/02 بخصوص طلبكم بتجديد اعتماد الطربال انتاج مصنع شركة صناعات العزل العربية – السعودية نوعية AWAZEL DS 40200 والبرايمر AWAZEL PRIMER – D41 للاستخدام كعازل مائي للحمامات والأسطح والبلكونات ، وبالإطلاع على المقارنة الفنية المقدمة واعتماده السابقة نعلمكم بأنه لا مانع لدينا من اعتماد المواد المشار إليها سابقا وسيتم القيام بالاختبارات اللازمة حين توريد المواد .

شاكرين لكم حسن تعاونكم ،،،،،،،،،،

المهندس المقيم

م / عبدو محمد بيطار



نسخة:

ممثل المالك

شركة بروجاكس

Al Tayeb Project				
Sadeem Al-Kuwait				
S.N.	Post	Act.	Info	Sign./Date
1	Project Eng.			
2	Planning Eng.			
3	Arch. Eng.			
4	Site Eng.			
5	Civil Eng.			
6	Q.S			
7	Safety			
8	SAK H.Q			
9	File			

شركة بروجاكس

Project: PIFSS AT JAHRA
 Project Manager: Wafar Real Estate


Consultant: Al Habsbi Consultants Office
 Contractor: Al-United General Trading
 Sub-Cont:

TRANSMITTAL FORM - MD

Date : 18.01.2016 Day : Monday Transmittal No. : PIFSS/FUC/JH/MD/003 Rev - 0

We are hereby sending the following under separate cover (Engineer to enter ACTION code)

Item No.	DRWS SPEC. or BOO Ref.	Description	Quantity	Type	Code	Action
1	07130	Waterproofing Membrane - DS 40200 Technical Data sheet M/s. Awazel Kuwait Co.	2	MD	1	B



SUBMITTAL CODE			ACTION CODE		
SD	Shop Dwr.		1	Submitted for Approval	Approved
SM	Sample	PD	2	Submitted for Information	Approved as Noted
LET	Letter	SCH	3		Revise. & Resubmit.
GT	Guarantee	CT			Rejected
OT	Other				

Cont. Representative Signature: *[Signature]*

RE's Remarks
 APPROVED as noted "B"
 1- Comply with manufacture instructions for installation.
 2- Comply with all Contract Documents.
 3- Submit Shop Drawings and installation method as per Specs.
 4- Submit 10 years guarantee effective from the date of substantial completion of the work against leak and any other defects occurring in membrane water proofing works.
 5- material to be tested in approved laboratory
 eng. I. Shadi *[Signature]* 21.1.2016

Corrections or comments made relative to the submission during this review does not relieve the Contractor from compliance with the requirements of the drawings and the Specifications. This check is only for review of general concept of the project and general compliance with the information given in the contract documents. The Contractor is responsible for confirming and correlating selection, fabrication process and techniques of construction, co-ordinating his work with that of other trades and performing his work in safe and satisfactory manner.

Resident Engineer	Original RECEIVED 24 JAN 2016	Issued By (Resident Engineer)	
		Name: <i>[Signature]</i>	Date: 1 JAN 2016
Contractor	Signature: <i>[Signature]</i>	Time:	
Received by the Contractor	Signature: <i>[Signature]</i>	Date: 24/1/2016	
Name:	Signature:	Time:	



MATERIAL APPROVAL REQUEST



Project : Clean Fuels Project (0-6798-20-000)	Rev : F1
MAR No. : RAM-BLD-079	DATE : 13-Jan-16

CONTRACT TITLE : KNPC CLEAN FUELS AT MAA Refinery

1 Category: Temp Cvl Bld Mech Pip
 Elec Instr Ins Pnt Others ()

2 Purpose / Location of Material (Site & Unit details) : Roof Waterproofing for all building

3 Proposed Material and Vendor Details : Awazel Desert Shield 40200) and Primer for Roof (Awazel D 41)

- 1) Description of Material : Water Proofing Membrane (Awazel Desert Shield 40200) and Primer for Roof (Awazel D 41)
- 2) Manufacturer & Country : M/s : Awazel Arabian Waterproofing Ind Co- KSA
- 3) Vendor /Supplier /Stockist & Country : M/s : Al-Bahar & Bardawil Specialities Co.

4 Specification Requirement / Details :

5 Deviation to Specification :

- Attachment 1: Manufacturers Data Sheet
- Attachment 2 : Manufacturers profile
- Attachment 3 : Material Technical Specification & Drawings
- Attachment 4 : Previous Approvals
- Attachment 5 : MSDS

Supplier VEC Approved

Yes No Not categorized in VEC List Categorized in CEC list (category 6, Type 01, Sub- Type B5,Code 1032)

VEC Product code : _____

Vendor code : _____

<p>* Sub-Contractor (If applicable)</p> <p>Name of Subcontractor : SHBC</p> <p>Submitted by : Mr. Nader Hab El Rih</p> <p>Designation : Project Manager</p> <p>*Signature : _____ *Date : 13-Jan-16</p>	<p>* Contractor (Responsible OC: JGC / GS (SK))</p> <p>Reviewed by : M. H. Kim</p> <p>Designation : CM</p> <p>*Sign : _____ *Date : 14/1/16</p>
--	---

*** COMPANY**

Approved Approved with comment Not Accepted

Comments : _____

المحترمين
المحترم

السادة/ شركة عوازل الكويت لمواد البناء
عناية السيد/ مدير الشركة
تحية طيبة وبعد،،،

**الموضوع/ دراسة اعتماد مواد عازل مائي
إنتاج شركة عوازل السعودية**

بالإشارة إلى الموضوع أعلاه ، وإلى كتابكم بخصوصه رقم 2016/2/2 بتاريخ 2016/2/9 بشأن دراسة اعتماد مواد عازل مائي من إنتاج شركة عوازل السعودية، نفيدكم بالموافقة على اعتماد المواد التالية:

1. عازل مائي نوع DS 40200 سمك 4مم وتسليح بوليستر 200 جم/م².
2. ألواح حماية MS60 سمك 6مم.

إنتاج شركة عوازل السعودية مع الالتزام بالشروط التالية:

- أن يتم التقدم بهذه المنتجات من خلال المقاولين الرئيسيين المتعاقدين مع الوزارة.
- الالتزام بالموصفات العامة لوزارة الأشغال والموصفات الخاصة للعقد المطلوب استخدام هذه المواد فيه.
- يتم إجراء الاختبارات والفحوصات اللازمة على المواد الموردة للمواقع والتأكد من مطابقة النتائج للمواصفات المطلوبة قبل الاستخدام.
- يحق للوزارة إلغاء هذا الاعتماد حال ظهور أي عيوب في المواد المستخدمة خلال فترة الصلاحية.
- الالتزام بالقرار الوزاري رقم (6) لعام 1987 والقرار المعدل له رقم (282) لعام 2000 بشأن إعطاء الأولوية في المشتريات الحكومية للمنتجات الوطنية والمنتجات ذات المنشأ الوطني.
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه ويراعي التجديد في حينه.

وتفضلوا بقبول فائق الاحترام،،،،

مدير إدارة الشؤون الهندسية

سعود حشف المطيري
مدير إدارة الشؤون الهندسية ندياً

Transmittal No. MD/002/15

Date: 22/11/2015


APPROVED	C	NOT APPROVED	تاريخ: 22/11/2015
APP AS NOTED	D	RESUBMITT	عدد: 1
ملاحظات	ملاحظات		

Section 07130 / Item 2.01 (A,B,F)

المواد	الكمية	ملاحظات	رقم الملف: 288 / 1/1
المواد	الكمية	ملاحظات	اسم الملف: B.O.T على انارة نزع الناعية المتكاملة لاجل ال B.O.T
المواد	الكمية	ملاحظات	اسم الملف: شركة الناعية المتكاملة
المواد	الكمية	ملاحظات	اسم الملف: مؤسسة الناعية المتكاملة

- 1- عدد 2 عتبه طريق + عدد 2 كتلجج والاكتانات
- عدد 2 صرورة من الوراكتانات
- 2- عدد 1 كتلجج مع الاكتانات
- عدد 2 عتبه حياة + عدد 2 كتلجج والاكتانات
- 3- عدد 2 صرورة من الوراكتانات

TYPICAL DETAILS # STR-002



UBC UNITED BUILDING COMPANY

Div. 07 Section 07130 (7.3.1, 7.3.2, 7.3.3, 7.3.4, 7.4.1)

ملاحظات


ملاحظات

Handwritten signature and date: 22/11/2015

- 1- DS40200 سائكة 4 مللي طريق 1
- 2- D41 رابور 4 مللي
- 3- MS60 حياة 6 مللي

Handwritten signature and date: 25/11/2015

المواد	الكمية	ملاحظات	رقم الملف
المواد	الكمية	ملاحظات	رقم الملف
المواد	الكمية	ملاحظات	رقم الملف

Proj. No.: RA-238 CONSTRUCTION, COMPLETION AND MAINTENANCE OF THE ROADS, BRIDGES, STORM WATER DRAINAGE, SEWERS AND OTHER SERVICES FOR THE ROAD CONNECTING MINA ABDULLAH AND WAFRA	Employer: MINISTRY OF PUBLIC WORKS ROAD ADMINISTRATION DEPARTMENT STATE OF KUWAIT	Request No. RA238-SAM-GEN-STR-0011-00
Engineer's Representative:  dar al-handasah shair and partners s.a.l.	Contractor: MUSHRIF TRADING & CONTRACTING CO. INCORPORATED	Date 16 / 03 / 2016

Submittal for Approval of Materials ✓

1. Material description (one item only on this form) :

WATERPROOFING SYSTEM MATERIALS: 1). AWAZEL PRIMER D41 2). AWAZEL SELF ADHESIVE MEMBRANE 1.6 CLPE
3). AWAZEL DESERT SHIELD 40200 4). AWAZEL MEMBRANE SHIELD - MS 60

Area of application : BRIDGE, BOX CULVERTS, VALVE CHAMBERS & MEDIAN BARRIERS HAVING CONTACT WITH SOIL AS SHOWN ON DRAWINGS.
Drawing ref. : K10091-0100D-PK1-TD-BR-003 & 005 B.O.Q. Ref. No.: Section-5, Item: 516
Specification Ref. : MPW GENERAL SPECS: SEC-5, CLAUSE: 516.04 Standards : ASTM

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. **Manufacturer / supplier**
Company Name : ARABIAN WATERPROOFING INDUSTRIES CO (AWAZEL).
Address : SECOND INDUSTRIAL CITY, ROAD NO.173, P.O. BOX 2955, RIYADH 11461, KSA.
Local Agent : AWAZEL KUWAIT CO, KUWAIT.


3. **Delivery :**
Country of origin : KINGDOM OF SAUDI ARABIA, KSA.
Availability
 Locally Manufactured Overseas

Delivery : Ex-works/ total duration []
Estimated time of arrival on site []


Program : Date material required on site []
Latest date for order []

MUSHRIF - RA/238
20 MAR 2016
RECEIVED

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : Engr. Tony Curran Signature 

4. Engineer's Representative comments: <i>Prior to use material shall be tested & shall be in compliance with General Spec 516.04</i> <i>2) Delivered material shall be notified for inspection.</i> <i>3) Compliance Certificate shall be submitted with the consignment.</i> <i>4) Location to be used as per approved dwg.</i> <i>5) Storage & Application as per mfg's instruction.</i> <i>6) Detailed method statement & ITP to be submitted for approval. N/A</i>	<input type="checkbox"/>	Approved
	<input checked="" type="checkbox"/>	Approved as noted
	<input type="checkbox"/>	Revise and resubmit
	<input type="checkbox"/>	Rejected
	<input type="checkbox"/>	Sample required
	<input type="checkbox"/>	Tests required
<input type="checkbox"/>	Additional information required	
<input type="checkbox"/>	Manufacturer's guarantee required	

Signature  Date: 16/03/2016

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents

RECEIVED
16 MAR 2016
RA-238/DAH/SAM/1.0/0116
RA/238



SITE TRANSMITTAL

TRANSMITTAL NO : MD-07-0328

REV : 02

To: HOK in association with KEO

Project	Owner	Design, Verification and Supervision Consultant	Contractor JV
Al-Amiri Hospital Expansion Contract No. 57/010/2011	Ministry of Health	HOK in association with KEO	ASCO, Pizzarotti, Al Essa, Studio Altieri, Gattan Architects

WE ARE SENDING HERewith THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW FOR YOUR REVIEW.

ITEM NO.	DRW., SPEC. OR BOQ. REF	GENERAL DESCRIPTION AND REVISION DETAILS	TYPE (i)	COPIES	ACTION CODE (ii)
1	Division 07	Waterproofing Membrane 4mm for Roof system Source : AWAZEL KSA (DS40200)	MD/SM	3 Hard copies	B
2		Primer for Waterproofing Membrane Source : AWAZEL KSA (Type: Primer D41) - Specification compliance sheet and technical' - Technical comparison PVC vs Bituminous membrane - Previous Approvals - Samples (Submitted in Rev.01)			



We certify that the items submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR JV:

DATE: 30/3/2016

RECEIVED BY HOK-KEO:

DATE:



HOK-KEO'S REMARKS :

"APPROVED AS NOTED"

REFER TO OUR COMMENTS ON ATTACHED SHEET

16
7/4

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of his Contract, drawings and specifications. This review is only in respect of general conformance with the design intent of the project and general compliance with the information given in the Contract documents. The contractor remains responsible, among other things, for the design of the project or such parts of the project he has design responsibility for (if design forms part of the Contract), for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner, all in accordance with the Contract.

HOK-KEO :


RECEIVED BY CONTRACTOR JV:

DATE: 7/4/2016

DATE: 7/4/2016

- (i) TYPE: SD: Shop Drawings
- SM: Sample
- MD: Manufacturer's Data
- OT: Others

- (ii) ACTION CODE:
- A: Approved
- B: Approved as noted
- C: Not Approved





٢٧٩/١٨
ع.١٥ / ١١١١٠

شهادة اعتماد

AWAZEL DS 40200

اسم الشركة / المصنع :

شركة عوازل الكويت لمواد البناء.

العنوان :

فاكس : 24826801-25755632

ت : 25712224 - 24826677

ص.ب: 42137 الشويخ - 70652 الكويت

تاريخ الانتهاء

2017 / 11 / 1

تاريخ الإصدار

2015 / 11 / 2

وصف المواد المعتمدة :


- AWAZEL DESERT SHIELD 40200 : App modified bituminous membrane, reinforced with non woven polyester mat , Type II, Grade S , 4mm thickness complies with ASTM D 6222.






إنتاج مصنع شركة صناعات العزل العربية - السعودية.

الإشتراطات:

- يتم التقدم بهذا المنتجات من خلال المقاولين المعتمدين بمسارين بوزارة الأشغال العامة شريطة ان تطابق مواصفات هذا المنتج المواصفات العامة لوزارة الأشغال والمواصفات الخاصة بالعقد الذي يرغب في استخدام هذا المنتج.
- هذا الاعتماد لا يعفي هذا المنتج من إجراء الفحوصات اللازمة والدورية عند التوريد لأي مشروع.
- تلتزم وزارة الأشغال العامة بتطبيق القرار الوزاري رقم (6) لعام 1987 والقرار المعدل له رقم (282) لعام 2000 والخاص بمنح الأولوية في المشتريات الحكومية للمنتجات الوطنية وذات المنشأ الوطني.
- هذا الاعتماد ساري المفعول لمدة سنتين من تاريخه ويراعى التجديد في حينه.
- في حال تغيير بلد المنشأ (السعودية) يعتبر هذا الاعتماد لاغياً.

إطلاع من قبل
مهندس
وكيل وزارة الأشغال العامة
لقطاع المركز الحكومي للشحوصات
وضبط الجودة والأبحاث
1



Proj. No.: RA-238 CONSTRUCTION, COMPLETION AND MAINTENANCE OF THE ROADS, BRIDGES, STORM WATER DRAINAGE, SEWERS AND OTHER SERVICES FOR THE ROAD CONNECTING MINA ABDULLAH AND WAFRA	Employer:   MINISTRY OF PUBLIC WORKS ROAD ADMINISTRATION DEPARTMENT STATE OF KUWAIT	Request No. RA238-SAM-GEN-STR-0011-00
Engineer's Representative:  daral-handasah shair and partners s.a.f.	Contractor:   MUSHRIF TRADING & CONTRACTING CO. (REG. NO. 1001)	Date 16 / 03 / 2016

Submission for Approval of Materials ✓

1. Material description (one item only on this form) :

WATERPROOFING SYSTEM MATERIALS: 1). AWAZEL PRIMER D41 2). AWAZEL SELF ADHESIVE MEMBRANE 1.6 CLPE
3). AWAZEL DESERT SHIELD 40200 4). AWAZEL MEMBRANE SHIELD - MS 60

Area of application : BRIDGE, BOX CULVERTS, VALVE CHAMBERS & MEDIAN BARRIERS HAVING CONTACT WITH SOIL AS SHOWN ON DRAWINGS.
Drawing ref. : K10091-0100D-PK1-TD-BR-003 & 005 B.O.Q. Ref. No.: Section-5, Item: 516
Specification Ref. : MPW GENERAL SPECS: SEC-5, CLAUSE: 516.04 Standards : ASTM


Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier
Company Name : ARABIAN WATERPROOFING INDUSTRIES CO (AWAZEL).
Address : SECOND INDUSTRIAL CITY, ROAD NO.173, P.O. BOX 2955, RIYADH 11461, KSA.
Local Agent : AWAZEL KUWAIT CO, KUWAIT.


3. Delivery :
Country of origin : KINGDOM OF SAUDI ARABIA, KSA.
Availability
 Locally Manufactured Overseas

Delivery : Ex-works/ total duration []
Estimated time of arrival on site []

Program : Date material required on site []
Latest date for order []



We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : _____ Engr. Tony Curran Signature 

4. Engineer's Representative comments:

1) Prior to use material shall be tested & shall be in compliance with General Spec 516.04

2) Delivered material shall be notified for inspection.

3) Compliance Certificate shall be submitted with the consignment.

4) Location to be used as per approved dwg.

5) Storage & Application as per mfg's instruction.

6) Detailed method statement & ITP to be submitted for approval. N/A

Signature _____ Date: 20/03/2016

<input type="checkbox"/>	Approved
<input checked="" type="checkbox"/>	Approved as noted
<input type="checkbox"/>	Revise and resubmit
<input type="checkbox"/>	Rejected
<input type="checkbox"/>	Sample required
<input type="checkbox"/>	Tests required
<input type="checkbox"/>	Additional information required
<input type="checkbox"/>	Manufacturer's guarantee required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

