



Shapoorji Pallonji

شاپورجي پالونجي ميدياست (ل.ل.ج.)
Mideast (L.L.C.)MINISTRY OF HEALTH
HOSPITAL EXPANSION PROJECTS

DOCUMENT TRANSMITTAL FORM (DTF)

Contract No: 18/2011/2012-11

Project: Design, Construction, Equipment,
Furniture and Operational Maintenance for the
New Al Sabah Hospital

TO: Soor Engineering

ATN: Eng. Mohamed Salah

TRN NO: SML-ALSABAH-CE-00029

REV: 0

FROM: JV of Al Sager-Shapoorji Pallonji

DATE: 26-September-2016

Copy Distribution

☐ Ministry of Health☐ PM☐ Consultant☐ Other

WE ARE SENDING:		SUBMITTED FOR:		ACTION TAKEN:	
<input type="checkbox"/>	Documents	<input checked="" type="checkbox"/>	Approval	<input type="checkbox"/>	A - Approved
<input type="checkbox"/>	Drawings/Sketch	<input type="checkbox"/>	Review & Comments	<input checked="" type="checkbox"/>	B - Approved as noted
<input type="checkbox"/>	Report	<input type="checkbox"/>	As Requested	<input type="checkbox"/>	C - Approved with comments, Revise & Resubmit
<input type="checkbox"/>	Variation	<input type="checkbox"/>	Information / Records Only	<input type="checkbox"/>	D - Not Approved
<input type="checkbox"/>	Test Certificate	<input type="checkbox"/>	For Necessary Action	<input type="checkbox"/>	E - Information Required, Revise & Resubmit
<input type="checkbox"/>	Test Results	<input type="checkbox"/>	Other:	<input type="checkbox"/>	
<input checked="" type="checkbox"/>	Sample				
<input type="checkbox"/>	Other:				

Item No.	Draws, Spec or BOQ Ref.	Item Seq. No.	Description of Submittal or Document Title	Copies
1	Section - 07140	1	Submission of Sample for Liquid applied polyurethane water proofing membrane MARISEAL 670 for approval.	2 Nos.
2		2	Manufacturer/Supplier: MARIS POLYMERS	


Subcontractor Name:		Main Contractor:	JV of Al Sager-Shapoorji Pallonji
Project Manager Name:		Project Director Name:	Eng. Ayman Gouda
Signature:		Signature:	

Received By Recipient	Date	Title
-----------------------	------	-------

REMARKS







ACTION : (B) Approved As Noted.

1. Subject to submit method statement for application of MARIS POLYMERS 670.
2. Follow the manufacturer's instructions for application of material.
3. Comply with the comments recorded on the transmittal # QUD-ALSABAH-CE-00055 dated 24-09-2016.

 Mohamed Salah Resident Engineer	PM	PE / MOH	Dir / MOH
---	----	----------	-----------

☒ Consultant☒ PM☐ MOH (THE ENGINEERS) - Transmittal Cover Only

Corrections and comments made relative to submittals during this review do not relieve the Contractor from compliance with the requirements of the contract documents. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of construction, coordinating his work with that of other trades.

     					
SAMPLE TAG					
Contract No: 18/2011/2012-11			Project Name : New Al Sabah Hospital		
Transmittal No. Date:		SML-ALSABAH-CE-00029-R0 26/Sep/2016			
Sample Name		Sample for Liquid applied Polyurethane water proofing Membrane MARISEAL 670			
Manufacture / Supplier		MARIS POLYMERS			
Details DOC III, DIV-3/Section 07140					
Approval Status	A	B	C	D	E
		✓			
Signature in accordance with matrix Revision 3	Contractor		Consultant	PM	MOH
	Date				

Project Logo 	Project Name : CONSTRUCTION OF 3 NEW SCHOOLS OF 33 SCHOOLS AT DOHA STAGE 9, PACKAGE 1 Project No. : H17	Form No. : P07-F10 / Rev. 01 / Feb. 2012
Client: 	Consultant: 	Contractor: 

MATERIAL APPROVAL REQUEST (MAR)

Submittal Contents: <input type="checkbox"/> - Material/Sample <input type="checkbox"/> - Mock-up <input type="checkbox"/> - Catalogue/Brochure <input type="checkbox"/> - others	MAR No. : HCCH17/MAR/CIVIL-099 Rev. 0 Date Submitted : 01/07/2015
--	---

Trade / Discipline: <input type="checkbox"/> - Civil <input checked="" type="checkbox"/> - Architectural <input type="checkbox"/> - Electrical <input type="checkbox"/> - Information Tech. (IT) <input type="checkbox"/> - Structural <input type="checkbox"/> - Mechanical <input type="checkbox"/> - Plumbing <input type="checkbox"/> - Others <input type="checkbox"/> - Landscape <input type="checkbox"/> - Interior Design	Date Required on Site: _____ Production Period : _____ Total Delivery Time: _____ Expected Arrival on Site: _____
--	--

Description of Material / Equipment: MARISEAL 670 (BITUMEN WATERPROOFING MEMBRANE) <div style="text-align: right; color: red; font-weight: bold; font-size: 1.2em;">JUL</div> <div style="text-align: center; border-top: 1px solid black; padding-top: 5px;">FOR LABORATORY ONLY</div>

References: a.) Specs. Ref. : _____ c.) QCS 2010 Ref. : _____ b.) Drawing Ref. : _____ d.) Statutory Req. : _____ c.) BOQ Ref. : _____ e.) Specified Vendors List : _____ Others : _____	
---	--



Manufacturer / Supplier Details: <input type="checkbox"/> - Locally Manufactured <input checked="" type="checkbox"/> - Imported a.) Local Supplier / Agent: Company Name : AL - ZAHER INSULATION OF BUILDING Address / Contacts : DOHA - QATAR	Country of Origin: GREECE b.) Manufacturer : Company Name : MARIS POLYMERS POLYURETHANE SYSTEMS Address / Contacts : _____
--	---

Prepared by: (Contractors PE or CM) ENG. AHMED AHDY (01/07/2015) <small>Name / Sign / Date</small>	Verified by: (Contractors QA/QC, QS, or Proj. Coordinator) ENG. EL SAYED FAHMY (01/07/2015) <small>Name / Sign / Date</small>	Recommended for Approval by: (Contractor's PM) ENG. EL SAYED FAHMY (01/07/2015) <small>Name / Sign / Date</small>
---	--	--

COMMENTS BY THE CONSULTANT

Material is Acceptable subject to - 1. Application to be done by Certified applicator Only (Submit PQ for Approval) 2. Method Statement to be submitted for Approval. 3. Guarantee of material & application to be submitted for Approval. 4. All works to comply with project Specs & Manufacturer Recommendations. 5. All works to be subjected to water leak Test Approval.

(Use a separate comments sheet when necessary, for easy traceability purposes do not forget to include the MAR No., Revision No. & corresponding date of this MAR to the comments sheet.)

Submittal Status: <input type="checkbox"/> - A - Approved <input checked="" type="checkbox"/> - B - Approved as Noted <input type="checkbox"/> - C - Revise and Resubmit <input type="checkbox"/> - D - Rejected			
Supervision Consultant Signature:  _____ <small>Name & Signature</small> RE or Senior Engineer <small>Designation</small>	 _____ <small>Name & Signature</small> Project Manager <small>Designation</small>	Client Approval / Endorsement (when required): _____ <small>Name & Signature</small> _____ <small>Designation</small>	_____ <small>Date</small>

Approval or comments to the submittals does not relieve the Contractor from their responsibilities. The assessment is to review the general conformance and compliance of the submittal to the contract and specification requirements.

DOCUMENT SUBMITTAL

Project:	(2B+G+41) ARWA RESIDENTIAL TOWER	Project No.	156
Client:	ARTIC (AI Rayyan Tourism Investment Co.)		
Consultant:	Meinhardt (Singapore) Pte Ltd - Qatar Branch	Contractor:	Derwind Trading & Contracting Co. W.L.L.

Reference No.	DTC/156/MAT-AR-57	Rev No.	0	Date:	10-08-2015
---------------	-------------------	---------	---	-------	------------

Discipline:	<input type="checkbox"/> Civil	<input type="checkbox"/> Architectural	<input type="checkbox"/> Electrical	<input type="checkbox"/> Mechanical	<input type="checkbox"/> Others (specify)
Submittal Type :	<input type="checkbox"/> Method Statement / Inspection & Test Plan <input checked="" type="checkbox"/> Test Result / Certificates <input type="checkbox"/> Reports <input type="checkbox"/> Pre-Qualification <input type="checkbox"/> Sketch <input type="checkbox"/> Program & schedule <input type="checkbox"/> Forms/ checklist <input type="checkbox"/> Quality Plan <input type="checkbox"/> Organization Chart <input type="checkbox"/> Others				
<input type="checkbox"/> Drawing <input type="checkbox"/> Design calculation <input checked="" type="checkbox"/> Data sheet <input type="checkbox"/> Material					

Description of Submittal: (Note: Material Submittals - the brand names, item codes, manufacturer & supplier with Country of Origin must be included)

MARISEAL 670
 Liquid Applied Polyurethane Waterproofing Membrane Solvent Free
 Manufacturer: MARIS POLYMERS SA
 Supplier: AWAZEL QATAR
 Country of Origin: GREECE

ATTACH: Data Sheet + sample ✓

Prepared & Checked By: (Contractor / Sub-Contractor) -AL YUSR **Project Manager: (DERWIND)**

Name:	AHMAD SALIM	Name:		Name:	MOHAMMAD TALKHAN
Designation:	Executive Director	Designation:		Signature:	
Signature:		Signature:		Date:	12/08/15
Date:	10-08-2015	Date:			

(CONSULTANT) - MEINHARDT'S COMMENTS

1. Method Statement has to be submitted.
2. Certified applicator only.
3. Mock-up Sample required.

<input type="checkbox"/> A - APPROVED	<input type="checkbox"/> B - APPROVED WITH COMMENTS	<input type="checkbox"/> C - REVISE & RESUBMIT	<input type="checkbox"/> D - REJECTED
<input type="checkbox"/> Comments Attached		<input type="checkbox"/> N - NOTED	

Reviewed By: **Approved By: (Project Manager)**

Name:	HAZEM AMIN	Name:	M. RAMIREZ
Signature:		Signature:	
Date:		Date:	16/08/15



DERWIND TRADING AND CONTRACTING

SITE: 123

PROJECT NAME: SINYAR TOWER

APPROVAL SUBMITTAL

SUBMITTAL NO.
DTC/123/MAT-AR-078

REV. 0

DATE OF SUBMITTAL: 07/09/2015

DATE REQUIRED: 21/09/2015

ENGINEER: Diwan Al Emara Architects

SUPPLIER: United Design Industry

TYPE OF SUBMITTAL

SHOP DWG. ☐

MATERIAL ☒

METHOD STATEMENT ☐

DOCUMENT ☐

SPECS. /
DWG NO.

DESCRIPTION

ACTION

ID Specs.

MATERIAL SUBMITTAL FOR MARISEAL 670
Liquid Applied Polyurethane Water Proofing Membrane For Wet Areas

☒ EQUAL / APPROVED

☐ SAMPLES

☐ LEAFLETS

☐ FOR INFORMATION

☐ SPECIFIED

☒ CATALOGUES

☒ TECH BROCHURE


MANUFACTURER

SUPPLIER

SUBMITTED BY DTC

Name : MARIS POLYMERS
Address : Industrial Area of Inofita
32 011 Inofita, Greece
Tel No. : +30 22620 32918-9
Fax No : +30 22620 32040

Name : AWAZEL INTERNATIONAL
CO. QATAR
Address : P.O. Box: 31741 Doha - Qatar
Tel No. : (+974) 4442 0571
Fax No : (+974) 4413 1294

By: For 
Name : Mohamed Talkhan
Title : Project Manager
Date : 07/09/2015

ENGINEER COMMENT'S:

We approved this material as an alternative material for water proofing for wet areas with these notes:-

- 1- Provide mock-up @ site for final approval before proceeding.
- 2- Submit pre-qualification of the sub-contractor.
- 3- Follow the manufacturer's instructions.

ENGINEER APPROVAL STATUS KEY

- ☐ A APPROVED - ORDER MAY PROCEED
- ☒ B APPROVED EXCEPT AS NOTED
- ☐ C REJECTED / RESUBMITTAL REQUIRED

ENGINEER (Signature): 

NAME / TITLE (Print): 08 Sep. 2015

APPROVED / ISSUED DATE: _____

07 SEP 2015 9:36

Ref: **DTC-MT/P-156-SO/AYE /AB/SUB/008-15**

16 August 2015

To: **M/S AL YUSR ENGINEERING W.L.L.**
Tel: 4411 6226
Fax: 4411 6336
P.O. Box 63751
Doha Qatar

Attn.: **Mr. Ahmed Selim**
Executive Director

Project: **(2B+G+41) Arwa Residential Tower**

Subject: **Material Submittal**

Dear Sir,

With reference to the above mentioned subject, kindly find attached herewith **Material Submittal** replied by the Consultant **M/S Meinhardt** for the project mentioned above in which details are written below:

SR No:	Reference	Description	Status
1	DTC/156/MAT-AR-47	MARISEAL 670	APPROVED WITH COMMENTS

You are hereby requested to attend/meet all comments mentioned vide the attached submittal/s and/or to revise the request for Consultant's approval.

This is for your information and action.

Best regards,



Mohamed Talkhan
Project Manager



Project Name: Abdul Wahab Gholam Tower		Project No: 39646	
Owner: Mr. Abdul Razzaq A. Wahab Gholam Hussain		AAWGT-SAK-MZP-MT-ARCH-020 15-Dec-15	
Submitted by: Eng. Zaid Aljarah		Date:	New Submittal:
Contractor's Representative Printed Name		Signature: [Signature]	Resubmital:
			Rev.
Description: MARISEAL 670 (Liquid-applied polyurethane waterproofing membrane used for waterproofing of Wet Areas)		Drawing Ref.:	Specification Ref.:
		Bill of Quantities Ref.:	N/A
		Other Ref.:	
Attachment: Technical Data Sheets		Test Certificates	Samples
Manufacturer/Supplier			
<input checked="" type="checkbox"/> From Approved Vendor List		<input type="checkbox"/> Equivalent or Approved	
Name of Manufacturer/Supplier: MARIS POLYMERS S.A.			
Address: P.O.Box: 5785 Doha, Qatar		Local Agent: Awazel International Qatar	
Agent Tel. No.: Tel: + 974 4452 1666		Fax No.: 974 4436 3812	
Delivery	<input type="text"/>	Country of Origin:	GREECE
Availability	<input type="text"/>	Mode of Transportation	
Locally Manufactured:	<input type="text"/>	Overland:	<input type="checkbox"/>
Overseas:	<input type="text"/>	Air Freight:	<input type="checkbox"/>
		Sea Freight:	<input type="checkbox"/>
Manufacturer		Programme	
Production Period:	<input type="text"/>	Latest Date of Orders:	<input type="checkbox"/>
Delivery Ex Works:	<input type="text"/>	Date Material Required:	<input type="checkbox"/>
Total Delivery Time:	<input type="text"/>	Expected Date on Site:	<input type="checkbox"/>
Approved: <input type="checkbox"/>	Revise & Resubmit: <input type="checkbox"/>	Additional Info. Required: <input type="checkbox"/>	
Approved as noted: <input checked="" type="checkbox"/>	Rejected: <input type="checkbox"/>	Rejected: <input type="checkbox"/>	
Comments: <div style="font-size: 1.2em; font-weight: bold; padding-top: 10px;">Refer to attached comments sheet.</div>			
Consultant: [Signature] Printed Name		[Signature] Signature	
Owner: Engineering Department Comments (if applicable)		Received By: [Signature] Date: 29-12-2015 Date	
Printed Name		Signature	
Date		Date	

Received by: Sak Trading & Contracting Co.

Printed Name Signature Date



Consultant Engineer's Comment Sheet

Project Name	: AL ABDUL WAHAB GHOLAM TOWER (2B+G+38)	Date	: 15-Dec-15
Client	: MR. AL-ABDUL RAZZAQ A. WAHAB GHOLAM HUSSAIN	PMSD Proj. Ref. No.	: AR 420
Contractor	: SAK TRADING & CONTRACTING CO.	Contract Project Ref.	:
Type of Document to which comments are made	: Material transmittal	Document / Drawing Ref. No.	:
Discipline	: <input type="checkbox"/> Architectural <input checked="" type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input type="checkbox"/> Electrical <input type="checkbox"/> Interior Design		
Subject / Location	: MARISAL 670	Submittal Reference	: AAWGT-SAK-MZP-MT-ARCH-020

Consultant's Comment

- > Must strictly follow the manufacturer's recommendations and specifications when applying the Material
- > Submit inspections for all stages of the work
- > Must Submit a method statement explaining the material application.

☐ Approved ☒ Approved as Noted ☐ Revise and Resubmit ☐ Rejected

Discipline:	Architectural	Structural	Mechanical	Electrical	Interior Design
Inspector's Name		HADI NASSAR			
Inspector's Signature					
Time		10:00 AM			
Date		29-Dec-15			

Senior Engineer/Project Manager
(Signature over Printed Name)

MZP Department Director





ABDUL WAHAB
GHOLAM TOWER



Document Submittal

From: Sak Trading & Contracting Co. Ref. No.: AAWGT-SAK-MZIP-DOCS-023
To: MZ & Partners Consultancy Date: 28-Nov-15
Attention: Arch. Hisham Gaddas Contractor's Representative: Eng. Zaid Aljarah
Project: Abdul Wahab Gholam Tower Signature: *[Signature]* 28/11/2015
Subject: Method Statement for Application of Mariseal System at wet areas

- ☐ 1 For Information ☒ 3 For Amendment ☐ 5 As Requested
☐ 2 For Review & Comments ☒ 4 For Approval ☐ 6 Other

Item	Doc. No.	Rev.	Document Title	Issue Type	Media	Copies
1	AAWGT-SAK-MZIP-DOCS-023	0	Method Statement for Application of Mariseal System at wet areas	4	Hard copy	1
			Attached approved applicator certificate and Pre-qualification Document of Al Yusr Gata Waterproofing & Concrete Repair W.L.L.			

Status

- ☐ A-Approved ☒ C-Revise & Resubmit ☐ E-Sample Required/Mock-up Necessary
☐ B-Approved as Noted ☐ D-Additional Info Required ☐ F-Other

Consultant's Comments:

Please refer to attached comments sheet.

MZIP		
SITE SUPERVISION DEPARTMENT		
Date:	28.11.15	
Discipline	Act.	Info.
P.M.		
Arch.		
Civil		
Mech.		
Elect.		
I.D.		
Planner		
Q.S.		
Head Office		
H.S.E.		
Sec/DC		
M/FILE		
S/FILE		
RECEIVED		

MZIP	
ARCHITECTURAL STRUCTURAL MECHANICAL ELECTRICAL SUPERVISION INTERIOR DESIGN	
28 NOV 2015	
Project Name:	AAWGT
Received by:	<i>[Signature]</i>
Time:	7:40pm
Site Supervision	

Commented by: *[Signature]* 01-Dec-15
Name & Signature: _____ Date: _____
Consultant's Representative: *[Signature]*
Name & Signature: _____ Date: _____

Received by: _____
Signature: _____
Date: _____
Sak Trading & Contracting Co.
RECEIVED
02 DEC 2015
BY: *[Signature]*



Consultant Engineer's Comment Sheet

Project Name	AL ABDUL WAHAB GHOLAM TOWER (2B+G+38)	Date	01-Dec-15
Client	MR. AL-ABDUL RAZZAQ A. WAHAB GHOLAM HUSSAIN	PMSD Proj. Ref. No.	AR 420
Contractor	SAK TRADING & CONTRACTING CO.	Contract Project Ref.	
Type of Document to which comments are made	Document submittal	Document / Drawing Ref. No.	
Discipline	<input type="checkbox"/> Architectural <input checked="" type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input type="checkbox"/> Electrical <input type="checkbox"/> Interior Design		
Subject / Location	Waterproofing works	Submittal Reference	AAWGT-SAK-MZP-DOCS-023

Consultant's Comment

- >Provide approved applicator certificate from Maris polymers and the ISO certificates
- >List information about the senior management and staff who are likely to be engaged on the project, Please include list of total staff available by category / trade
- >Submit prequalification documents, Materials to be used and the Method statement in separate submittals

RECEIVED
02 DEC 2015
BY: [Signature]

☐ Approved ☐ Approved as Noted ☒ Revise and Resubmit ☐ Rejected

Discipline:	Architectural	Structural	Mechanical	Electrical	Interior Design
Inspector's Name		Hadi Nassar			
Inspector's Signature		[Signature]			
Time					
Date		01-Dec-15			

Senior Engineer / Project Manager
(Signature over Printed Name)

MZP Department Director

